



Suggested Method for Determining Volume Accumulated in the Hoses

EVR BALANCE SYSTEMS ONLY

Suggested Instructions for performing weekly test:

1. **Ensure the dispenser is not authorized.** Dispensing fuel is not necessary to perform this procedure.
 2. Place graduated cylinder (> 100ml) with funnel inserted into it on ground. (The District recommends placing the graduated cylinder into a larger bucket or container to minimize spillage.)
 3. Install spout plug (VST nozzle use -P/N VST-STP-100) (Emco nozzle use- P/N 494635EVR) into the nozzle spout.
 4. Pull hose in a straight diagonal line down to funnel opening until all liquid in hose drains to the nozzle end (Fig. 1).
 5. While nozzle is still in the funnel opening, pull back on nozzle bellows and compress the lever to open the vapor path to allow liquid to be drained from the vapor path.
- Caution: Do not overfill graduated cylinder. If there is more than one full cylinder of liquid in the hose, empty cylinder into flammable liquids container and continue draining in the manner described in step 2.**
6. Enter volume of gasoline drained from hose on Attachment F, “Volume Accumulated in the Hoses” or District approved equivalent form (see instructions below) and dispose liquid according to company policy and applicable requirements.
 7. Repeat this procedure for each hose at the station once a week.




Fig. 1

Instructions for completing Attachment F, “Volume Accumulated in the Hoses”

1. Column A – Record the date the hose was drained
2. Column B – Identify the hose # that is being drained
Note: For unihose configurations only the dispenser # needs to be recorded (#1)
For “six pack” configurations the dispenser # and grade # need to be recorded (#1/87)
3. Column C – Record the name of the person draining the hose
4. Column D – The affiliation of the person (i.e.-Name of Company)
5. Column E – Record volume of gasoline accumulated in the hose

Column A	Column B	Column C	Column D	Column E
Date	Hose	Name	Affiliation	Volume (ml)
6/1/04	#1	John Doe	John’s Gas	10

Caution: Always use safety equipment while draining hoses. This equipment may include but is not limited to a safety vest, cones, caution tape, safety goggles, gloves, etc.

Questions on how to perform, “Volume Accumulated in the Hoses” may be directed to the San Diego Air Pollution Control District Compliance Division at (858) 586-2650.