SAN DIEGO AIR POLLUTION CONTROL DISTRICT
COMPLIANCE DIVISION
10124 OLD GROVE ROAD
SAN DIEGO CA 92131-1649
PHONE (858) 586-2650 FAX (858) 586-2651

APCD USE ONLY
SECTOR
ID#
NOV#

AIR TO LIQUID RATIO TEST, TP-201.5(Pre-EVR)

(Roots Meter)

☐ **Renewal Testing** (Contractor only) ☐ **Compliance Witness** (District only) ☐ **Compliance Testing** (District only) ☐ **Engineering Evaluation** (District only)

SOURCE INFORMATION		**TEST COMPANY INFORMATION**	
Facility (DBA)/Site Address:	Facility Representative/Title:	Test Company Name/Address	Test Company Representative
Print Name	Print Name	Print Name	Print Name
Street Address	Title ( )	Street Address	Signature ( )
City Zip	Phone No.	City Zip	Phone No.
District Test Witness:	☐ P/O ☐ S/A ☐ A/C Number:	Date of Test: Time of Test:	SCAQMD Cert No:

Roots Meter Serial #:	Phase II Executive Order #:	Non-test, Low Flow: (nozzle x grade)	Grade Points Tested: (nozzle x grade)
Roots Meter Cal. Date:	Allowable A/L & GPM Range:	Non-test, High Flow: (nozzle x grade)	Number A/L Passed: (nozzle x grade)
Phase II System Type:	Grade Points on Site: (nozzle x grade)	Non-test, other:	Number A/L Failed: (nozzle x grade)

Disp.# /Grade	Nozzle Make & Model #	Initial Dispenser Reading	Final Dispenser Reading	Gallons Dispd, (gallons)	Time in, seconds	Disp Rate GPM	Starting Roots acf	Ending Roots acf	Total Flow acf	A/L	Pass/ Fail

Test Notes: GPM = (gallons dispensed X 60 sec)/time dispensed A/L = (acf X 7.481)/gallons dispensed