



AIR POLLUTION CONTROL DISTRICT

10124 OLD GROVE ROAD
 SAN DIEGO, CA 92131
 PHONE (858) 586-2600
 FAX (858) 586-2601

ATTACHMENT B: TESTS FOR PHASE I AND/OR PHASE II GASOLINE ABOVEGROUND STORAGE TANK VAPOR CONTROL SYSTEM

Vapor Recovery System	Pressure Decay ^{1,2,4,5}	A/L TP-201.5 ^{4,5}	Additional Required Tests ^{4,5}
Standing Loss Vapor Recovery for New ASTs (VR-302-X)	TP-206.3	N/A	Leak Rate and Cracking Pressure of P/V Relief Vent Valves (TP-201.1E) ³
Standing Loss Vapor Recovery for Existing ASTs (VR-301-X)	TP-206.3	N/A	Leak Rate and Cracking Pressure of P/V Relief Vent Valves (TP-201.1E) ³
Convault (G-70-116-X)	TP-201.3A	N/A	
Bryant (G-70-128)	N/A	N/A	
Petrovault (G-70-130-X)	TP-201.3A	N/A	
Tank Vault (G-70-131-X)	N/A	N/A	
Trusco-Supervault (G-70-132-X)	TP-201.3A	N/A	
Hirt VCS-200 (G-70-139)	TP-201.3B	N/A	Verification of Liquid Removal (Exhibit 2)
Healy (G-70-140-X/G-70-192)	N/A	N/A	
Hoover-Lube (G-70-148-X)	TP-201.3A	N/A	
Vault (G-70-160/G-70-144-X)	TP-201.3A	N/A	
Hoover Containment/Fuelmaster (G-70-161/G-70-133-X)	TP-201.3A	N/A	
Fireguard (G-70-162-X)	TP-201.3B	N/A	
Envirovault (G-70-167-X/G-70-129-X)	TP-201.3A	N/A	
Bryant (G-70-168)	TP-201.3A	N/A	
Hasstech (G-70-175-X)	TP-201.3B	Yes	
Healy (G-70-187)	TP-201.3B	N/A	Vapor Return Line Vacuum Integrity (Exhibit 4) Vapor Pressure Regulation Test (Exhibit 5)
Hoover Vault (G-70-194)	TP-201.3B	N/A	
Oldcastle (G-70-200-X)	TP-201.3	N/A	Dynamic Pressure Performance (TP-201.4)

X: Most recent ARB certification of the applicable vapor recovery system.



AIR POLLUTION CONTROL DISTRICT

10124 OLD GROVE ROAD
SAN DIEGO, CA 92131
PHONE (858) 586-2600
FAX (858) 586-2601

- ¹ *The California Air Resource Board (CARB) Test Procedures TP-206.3, TP-201.3A and TP-201.3B shall be conducted between sundown and a half hour after sunrise to minimize interface from solar effects and barometric pressures changes. The San Diego Air Pollution Control District's TP-96-1 leak detection procedure may be used in lieu of TP-201.3A and TP-201.3B. TP-96-1 can be conducted at any time except when daytime temperatures exceed 100 °F, and there is direct sunlight on exposed metal vapor return or vent pipe(s) that are in contact with vapor space of the storage tanks and/or the aboveground storage tank(s). The District will also accept the results of leak tests based on soap solution, helium detection or vacuums provided that procedures have prior written District approval. Election of any test method (including optional tests) requires compliance with the performance standard for that test method.*
- ² *If the equipment is identified as BACT in the equipment description, only TP-96-1 will be accepted by the District.*
- ³ *Alternate TP-201.1E may be used in lieu of TP-201.1E when specified by the applicable Executive Order. Once the test has started, the same test shall be completed prior to conducting another test on the P/V Vent Valves (i.e. the results of TP-201.1E cannot be used as part of the Alternate TP-201.1E and vice versa).*
- ⁴ *Test results shall be submitted on current District approved test forms located at <http://www.sdapcd.org>.*
- ⁵ *Pre-testing of the vapor recovery system is an option for the applicant. This is done to identify and correct problems before the District witnesses official testing. Pre-testing can eliminate the time and expense of having to perform a second test and pursue a variance until a second test has taken place. The District recommends, but does not require, pre-testing.*