



## **ATTACHMENT F: INSTRUCTION AND REQUIREMENT**

1. *Column A – Day the hoses were inspected.*
2. *Column B – Identify the hose that is being inspected.*
3. *Column C – Name of person inspecting the hoses.*
4. *Column D – Affiliation of the person inspecting the flow rate.*
5. *Column E – Volume accumulated in the hoses in ml.*

***In accordance with California Code of Regulations, Title 17, Section 94006, the volume accumulated in the hoses shall not exceed 100 ml.***