



**AIR POLLUTION CONTROL DISTRICT**  
**COMPLIANCE DIVISION**  
**10124 OLD GROVE RD.**  
**SAN DIEGO CA 92131**  
**PHONE (858) 586-2600**  
**FAX (858) 586-2601**

**ATTACHMENT L: VAPOR RECOVERY TESTS FOR PHASE I EVR SYSTEMS AND BALANCE PHASE II EVR SYSTEMS  
 LOCATED AT GASOLINE DISPENSING FACILITIES EQUIPPED WITH UNDERGROUND STORAGE TANKS  
 REQUIRED TESTING**

	Vapor Recovery System	Pressure Decay	Phase I	Phase II Hanging Hardware	Phase II Processor	Phase II ISD
<b>PHASE I</b>	Phil Tite (VR-101-X) <sup>1,2</sup> OPW (VR-102-X) <sup>1,2</sup> CNI (VR-104-X) <sup>1,2</sup> Emco Wheaton (VR-105-X) <sup>1,2</sup>	TP-201.3 <sup>3,4</sup> <sub>8</sub>	Torque of Phase I Adaptors (TP-201.1B) Integrity of the Drop Tube/Drain Valve (TP-201.1C/ TP-201.1D) Leak Rate and Cracking Pressure of P/V Relief Vent Valves (TP-201.1E) <sup>5,6</sup>	N/A	N/A	N/A
<b>PHASE II</b>	VST EVR System w/o ISD w/ VST Membrane Processor (VR-203-X) <sup>1,2,7,d</sup>	TP-201.3 <sup>3,4</sup> <sub>8,9</sub>	N/A	Nozzle Vapor Valve Integrity (Exhibit 10) <sup>10</sup> Dynamic Back Pressure (TP-201.4, Method 1 & Exhibit 13) Liquid Removal Test (Exhibit 5, Option 2)	VST Hydrocarbon Verification (Exhibit 6) Vapor Pressure Sensor Verification (Exhibit 8) VST Processor Activation (Exhibit 9)	N/A
	VST EVR System w/ ISD w/ VST Membrane Processor (VR-204-X) <sup>1,2,7,d</sup>	TP-201.3 <sup>3,4</sup> <sub>8,9</sub>	N/A	Nozzle Vapor Valve Integrity (Exhibit 10) <sup>10</sup> Dynamic Back Pressure (TP-201.4, Method 1 & Exhibit 14) Liquid Removal Rate (Exhibit 5, Option 2)	VST Hydrocarbon Verification (Exhibit 6) Vapor Pressure Sensor Verification (Exhibit 8) VST Processor Activation (Exhibit 9)	ISD Operability Test (Exhibit 13)
	VST EVR System w/o ISD w/ Veeder-Root Vapor Polisher (VR-203-X) <sup>1,2,7,d</sup>	TP-201.3 <sup>3</sup> <sub>4,8,9</sub>	N/A	Nozzle Vapor Valve Integrity (Exhibit 10) <sup>10</sup> Dynamic Back Pressure (TP-201.4, Method 1 & Exhibit 13) Liquid Removal Rate (Exhibit 5, Option 2)	Vapor Pressure Sensor Verification (Exhibit 8) Vapor Polisher Operability Test (Exhibit 11) Hydrocarbon Verification (Exhibit 12)	N/A
	VST EVR System w/ ISD w/ Veeder-Root Vapor Polisher (VR-204-X) <sup>1,2,7,d</sup>	TP-201.3 <sup>3</sup> <sub>4,8,9</sub>	N/A	Nozzle Vapor Valve Integrity (Exhibit 10) <sup>10</sup> Dynamic Back Pressure (TP-201.4, Method 1 & Exhibit 14) Liquid Removal Rate (Exhibit 5, Option 2)	Vapor Pressure Sensor Verification (Exhibit 8) Vapor Polisher Operability Test (Exhibit 11) Hydrocarbon Verification (Exhibit 12)	ISD Operability Test (Exhibit 13)
	VST EVR System w/o ISD w/ Hirt Processor (VR-205-X) <sup>1,2,7</sup>	TP-201.3 <sup>3</sup> <sub>4,8,9</sub>	N/A	Nozzle Vapor Valve Integrity (Exhibit 7) <sup>10</sup> Dynamic Back Pressure (TP-201.4, Method 1 & Exhibit 6) Liquid Removal Rate (Exhibit 5, Option 2)	Hirt VCS 100 Processor Operability Test (Exhibit 8)	N/A
	VST EVR System w/o ISD w/ FFS Clean Air Separator (VR-209-X) <sup>1,2,7</sup>	TP-201.3 <sup>3</sup> <sub>4,8,9</sub>	N/A	Nozzle Vapor Valve Integrity (Exhibit 7) <sup>10</sup> Dynamic Back Pressure (TP-201.4, Method 1 & Exhibit 6) Liquid Removal Rate (Exhibit 5, Option 2)	Clean Air Separator Integrity Test (Exhibit 4) <sup>11</sup>	N/A

## ATTACHMENT L – INSTRUCTIONS AND REQUIREMENTS

*X and XX represent the most recent California Air Resources Board (CARB) certification of the applicable vapor recovery system.*

<sup>1</sup> Unless otherwise specified by a District’s representative, the tests for the Phase II Vapor Recovery System specified shall be conducted in the following order:

### EVR VST

<u>(VR-203-X/VR-204-X)</u>	<u>(VR-205-X)</u>	<u>(VR-209-X)</u>
<u>With VST Membrane Processor</u>	<u>With Hirt VCS 100 Processor</u>	<u>With FFS Clean Air Separator</u>
<u>With Veeder-Root Vapor Polisher</u>		
TP-201.1E	Exhibit 8 of VR-205-X	Exhibit 4 of VR-209-X
TP-201.1B	TP-201.1E	TP-201.1E
TP-201.1C or TP-201.1D	TP-201.1B	TP-201.1B
Exhibit 8 of VR-203-X/VR-204-X	TP-201.1C or TP-201.1D	TP-201.1C or TP-201.1D
Exhibit 10 of VR-203-X/VR-204-X	Exhibit 7 of VR-205-X	Exhibit 7 of VR-209-X
TP-96-1 and Exhibit 4 of VR-203-X/VR-204-X <b>OR</b>	TP-96-1 and Exhibit 4 of VR-205-X <b>OR</b>	TP-96-1 and Exhibit 8 of VR-209-X <b>OR</b>
TP-201.3 and Exhibit 4 of VR-203-X/VR-204-X	TP-201.3 and Exhibit 4 of VR-205-X	TP-201.3 and Exhibit 8 of VR-209-X
TP-201.4 (Methodology 1) & Exhibit 13 of VR-203-X/ Exhibit 14 of VR-204-X Exhibit 13 of VR-204-X	TP-201.4 (Methodology 1) & Exhibit 6 of VR-205-X Exhibit 5 of VR-205-X	TP-201.4 (Methodology 1) & Exhibit 6 of VR-209-X Exhibit 5 of VR-209-X
Exhibit 9 of VR-203-X/VR-204-X		
Exhibit 6 of VR-203-X/VR-204-X		
Exhibit 5 of VR-203-X/VR-204-X, Option 2		

<sup>2</sup> Test results shall be submitted on current District approved test forms located at <http://www.sdapcd.org> and maintained onsite.

<sup>3</sup> The CARB Test Procedure TP-201.3 (most recent version) shall be conducted between sundown and a half hour after sunrise to minimize interface from solar effects and barometric pressure changes. The San Diego Air Pollution Control District’s TP-96-1 (most recent version) leak detection procedure may be used in lieu of TP-201.3. TP-96-1 can be conducted at any time except when daytime temperatures exceed 100°F, and there is direct sunlight on exposed metal vent pipe(s) and metal manhole cover(s) that are in contact with vapor space of the storage tanks. The District will also accept the results of leak tests based on soap solution, helium detection or vacuums provided that procedures have prior written District approval. Election of any test method (including optional tests) requires compliance with the performance standard for the test method.

<sup>4</sup> If the equipment is identified as BACT in the equipment description, only TP-96-1 will be accepted by the District.

<sup>5</sup> Alternate TP-201.1E may be used in lieu of TP-201.1E when specified by the applicable Executive Order. Once the test has started, the same test shall be completed prior to conducting another test on the P/V Vent Valves (i.e. the results of TP-201.1E cannot be used as part of the Alternate TP-201.1E and vice versa).

<sup>6</sup> The P/V valve installed on the VST Membrane processor vent is not part of the Phase I system, and testing of this P/V valve is not required.

<sup>7</sup> Within 60 days of any identical dispenser replacement, as defined in District Rule 11, the permittee shall successfully conduct the following performance tests for the new dispenser(s). Any replacement that does not meet the identical definition per District Rule 11 will require an application for an Authority to Construct.

- a. Nozzle Vapor Valve Integrity Test per Exhibit 10 of ARB E.O. VR-203-X or VR-204-X, Exhibit 7 of ARB E.O. VR-205-X or VR-209-X, **OR** TP-201.2B.
- b. Dynamic Back Pressure Performance Test per ARB Test Procedure, TP-201.4, Methodology 1.
- c. Liquid Removal Test per Exhibit 5 of ARB E.O. VR-203-X, VR-204-X, VR-205-X OR VR-209-X.
- d. If applicable, Vapor Pressure Sensor Verification Test per Exhibit 8 of ARB E.O. VR-203-X or VR-204-X.
- e. If ISD is installed, ISD Vapor Flow Meter Operability Test per Exhibit 13 of ARB E.O. VR-204-X.

The permittee shall promptly record all information relating to the dispenser replacement and performance testing on Attachment I, “Inspection, Maintenance and Repair Log,” or an equivalent form. All test results and maintenance logs shall be maintained onsite for three (3) years from the test date and made available to the District upon request.

<sup>8</sup> Ensure all P/V valves, including the valve installed on the VST Membrane Processor vent, when applicable, have been removed and vent risers capped prior to conducting TP-96-1 and re-install the valves after the test has been completed.

<sup>9</sup> The pressure decay test for this system (TP-201.3 or TP-96-1) shall be conducted in conjunction with Exhibit 4 of ARB E.O. VR-203-X, VR-204-X OR VR-205-X, OR Exhibit 8 of ARB E.O. VR-209-X, as applicable.

<sup>10</sup> For engineering and annual testing, Exhibits 8 and 10 of VR-203-X or VR-204-X as well as Exhibit 7 of VR-205-X or VR-209-X shall be conducted while the vapor space of the gasoline dispensing facility is pressurized to 2.0” WC. This can be completed in conjunction with the pressure decay test. In addition, TP-201.2B may be used in lieu of Exhibit 10 of VR-203-X or VR-204-X as well as Exhibit 7 of VR-205-X or VR-209-X.

<sup>11</sup> If the station pressure is -2.00” wc or more negative, a vacuum test must be performed followed by a pressure test. If the pressure is less negative than -2.00” wc, a pressure test must be performed. Anytime a vacuum test is conducted a subsequent pressure test shall also be conducted immediately after the vacuum test.

**See Notes on Attachment L-1 for continued instructions and requirements regarding Attachment L.**



## ATTACHMENT L-1 INSTRUCTIONS AND REQUIREMENTS FOR RESPONDING TO ISD ALARMS

Displayed Message	ISD/PMC Monitoring Category	Veeder-Root Indicator Light	Cause	Troubleshooting Tests/Inspections <sup>a, d</sup>
ISD VAPOR LEAKAGE WARN	Containment	Yellow	7-Day Vapor Leakage Detection test warning	TP-96-1, TP-201.1E, TP-201.1C or TP-201.1D, as applicable; Verify the VR Vapor Polisher valve is operating in accordance with Table 6 of Section 16 of VR-204-X IOM
ISD VAPOR LEAKAGE FAIL	Containment	Red	7-Day Vapor Leakage Detection test - 8th consecutive failure	
ISD GROSS PRESSURE WARN	Containment	Yellow	7-Day Gross Over Pressure test warning	Check processor ball valve positions, verify processor is in the on and automatic vapor processor mode; Inspect boots for damage; Verify the VR Vapor Polisher valve is operating in accordance with Table 4 of Section 19 of VR-203-X IOM or Table 6 of Section 16 of VR-204-X IOM The following test procedures as listed in ARB E.O. VR-204-X: Exhibit 8, Exhibit 9, Exhibit 11
ISD GROSS PRESSURE FAIL	Containment	Red	7-Day Gross Over Pressure test -8th consecutive failure	
ISD DEGRD PRESSURE WARN	Containment	Yellow	30-Day Degradation Over-Pressure test warning	
ISD DEGRD PRESSURE FAIL	Containment	Red	30-Day Degradation Over-Pressure test - 30th consecutive failure	
ISD VP PRESSURE WARN <sup>b</sup>	Processor	Yellow	1-Day VP Over-Pressure test warning	
ISD VP PRESSURE FAIL <sup>b</sup>	Processor	Red	1-Day VP Over-Pressure test failure – 2 <sup>nd</sup> consecutive failure	
ISD VP STATUS WARN <sup>c</sup>	Processor	Yellow	1-Day Warning of VP Emissions or Duty Cycle	See Emissions and Duty Cycle troubleshooting guidelines
ISD VP STATUS FAIL <sup>c</sup>	Processor	Red	1-Day VP Status failure - 2 <sup>nd</sup> consecutive failure	
VP EMISSION WARN <sup>b, c</sup>	Processor	Yellow	1-Day Mass Emission warning	The following test procedures as listed in ARB E.O. VR-203-X/VR-204-X: Exhibit 6, Exhibit 9
VP EMISSION FAIL <sup>b, c</sup>	Processor	Red	1-Day Mass Emission failure – 2 <sup>nd</sup> consecutive failure	
VP DUTY CYCLE WARN <sup>b, c</sup>	Processor	Yellow	1-Day Duty Cycle warning	TP-96-1, The following test procedures as listed in ARB E.O. VR-203-X/VR-204-X: Exhibit 8, Exhibit 9, Section 16 of VR-203-X IOM (Setup Procedure)
VP DUTY CYCLE FAIL <sup>b, c</sup>	Processor	Red	1-Day Duty Cycle failure – 2 <sup>nd</sup> consecutive failure	
Hnn: FLOW COLLECT WARN	Collection	Yellow	1-Day vapor flow collection warning	Inspect boots for damage; TP-201.4, Methodology 1; Exhibit 5 and Exhibit 13 ARB E.O. VR-204-X
Hnn: FLOW COLLECT FAIL	Collection	Red	1-Day vapor flow collection failure - 2nd consecutive failure	

<sup>a</sup> Troubleshooting Tests and Inspections also include, but are not limited to, the lists referenced in the Veeder-Root ISD Troubleshooting Manual P/N 577013-819 located at [http://www.veeder.com/page/isd\\_manuals](http://www.veeder.com/page/isd_manuals) and the VST ISD Troubleshooting Guide 9513-003 located at [http://www.vsthose.com/pdf/troubleshooting\\_guide\\_1.0b.pdf](http://www.vsthose.com/pdf/troubleshooting_guide_1.0b.pdf).

<sup>b</sup> Facilities equipped with PMC shall only refer to these alarms. Facilities equipped with ISD shall refer to all alarms listed in the table.

<sup>c</sup> Applicable to facilities equipped with a VST Membrane Processor only.

<sup>d</sup> The permittee and/or designated contractor shall not clear alarm conditions upon any ISD/PMC alarm unless, at minimum, the applicable troubleshooting tests and inspections listed below have been successfully conducted in order to verify the cause of the ISD/PMC alarm and recorded in the maintenance and repair log. Other tests and/or inspections may be performed in lieu of those cited below provided the same ISD/PMC alarm does not occur within the next consecutive assessment period after resetting the alarm. All test results shall be maintained onsite for three (3) years from test date and made available to the District upon request.