

FOR YOUR INFORMATION

The Following Notice was Published by the District

**NOTICE OF PRELIMINARY DECISION
BY THE SAN DIEGO COUNTY AIR POLLUTION CONTROL DISTRICT
TO ISSUE AUTHORITY TO CONSTRUCT**

The San Diego Air Pollution Control District hereby gives notice that in accordance with Rule 20.2 of the District Rules and Regulations, the Air Pollution Control Officer has made a preliminary decision to issue an Authority to Construct to American Internet Services for the proposed installation of eight 917 hp diesel fired emergency engine generators, to be operated at 935 Lightwave Avenue in San Diego, California.

An evaluation of the air pollution impacts of this proposal was performed by the District, and it was determined that all applicable District Rules and Regulations will be met when the equipment complies with conditions prescribed by the District. An Air Quality Impact Analysis was conducted for Oxides of Nitrogen (NOx). Results indicate that the operation of this equipment will not result in the violation of any State or Federal ambient air quality standard or interfere with the attainment or maintenance of any State or Federal ambient air quality standard when operated as required by the District.

The Air Quality Impact Analysis is available for review at the Air Pollution Control District, 10124 Old Grove Road, San Diego, CA 92131. Please refer to Application Nos. APCD2010-APP-001333 thru APCD2010-APP-001340 on all correspondence regarding this project. Written comments concerning the District's proposed action may be submitted for a period of 30 days, commencing June 17, 2011, and ending on July 18, 2011. Questions regarding this notice may be directed to Evariste Haury at (858) 586-2745 or John Annicchiarico at (858) 586-2733.

.....
Published: June 17, 2011

EH:jl
06/16/11