

FOR YOUR INFORMATION

The Following Notice was Published by the District

**NOTICE OF PRELIMINARY DECISION
TO APPROVE A SOURCE OF AIR POLLUTION BY THE
SAN DIEGO AIR POLLUTION CONTROL DISTRICT**

The San Diego Air Pollution Control District hereby gives notice that in accordance with Rule 20.2 of the District's Rules and Regulations, the Air Pollution Control Officer has made a preliminary decision to issue an Authority to Construct to San Diego Gas and Electric Co. for proposed installation of two (2) 3315 bhp diesel fired emergency standby engine/generators, to be located at 10975 Technology Place, San Diego, CA 92127.

A preliminary determination has been made to allow limited operation of the engines for maintenance and testing purposes, with unlimited use during emergency situations. Usage of the engines in any other situations will not be permitted. An evaluation of the air pollution impacts of this proposal was performed by the District, and it was determined that all applicable District Rules and Regulations will be met when the equipment complies with conditions prescribed by the District. An Air Quality Impact Analysis was conducted for Oxides of Nitrogen (NOx). Results indicate that the operation of this equipment will not result in the violation of any State or federal ambient air quality standard.

The Air Quality Impact Analysis is available for review at the Air Pollution Control District, 10124 Old Grove Road, San Diego, CA 92131. Please refer to Application No. 2011-APP-001756 on all correspondence regarding this project. Written comments concerning the District's proposed action may be submitted for a period of 30 days commencing on December 20, 2011, and ending on January 18, 2012. Questions regarding this notice may be directed to Nick Horres at (858)586-2728 or via email to Nick.Horres@sdcounty.ca.gov, or John Annicchiarico at (858) 586-2733.

.....
Published: December 20, 2011

NH:jlm
12/19/11