

FOR YOUR INFORMATION

The Following Notice was Published by the District

**NOTICE OF PRELIMINARY DECISION
TO APPROVE A SOURCE OF AIR POLLUTION BY THE
SAN DIEGO COUNTY AIR POLLUTION CONTROL DISTRICT**

The San Diego Air Pollution Control District hereby gives notice that in accordance with Rule 20.2 of the District's Rules and Regulations, the Air Pollution Control Officer has made a preliminary decision to issue an Authority to Construct to Scale Matrix for proposed installation of two diesel fired emergency standby engines/generators, to be located at 5795 Kearney Villa Road in San Diego, CA.

A preliminary determination has been made to allow limited operation of the engine for maintenance and testing purposes, with unlimited use during emergency situations. Usage of the engine in any other situations will not be permitted. An evaluation of the air pollution impacts of this proposal was performed by the District, and it was determined that all applicable District Rules and Regulations will be met when the equipment complies with conditions prescribed by the District. An Air Quality Impact Analysis was conducted for Oxides of Nitrogen (NOx). Results indicate that the operation of this equipment will not result in the violation of any State or Federal ambient air quality standard.

The Air Quality Impact Analysis is available for review at the Air Pollution Control District, 10124 Old Grove Road, San Diego, CA 92131. Please refer to Application Nos. 2010-APP-001476 or 2010-APP-001477 on all correspondence regarding this project. Written comments concerning the District's proposed action may be submitted for a period of 30 days, commencing May 11, 2011, and ending on June 9, 2011. Questions regarding this notice may be directed to Nick Horres at (858) 586-2728 or via email to Nick.Horres@sdcounty.ca.gov, or John Annicchiarico at (858) 586-2733.

.....

Published: May 11, 2011

NH:jlm
05/10/11