

FOR YOUR INFORMATION

The Following Notice was Published by the District

**NOTICE OF INTENT
TO ISSUE A FINAL PERMIT TO OPERATE
FOR THE PALOMAR ENERGY PROJECT**

Notice is hereby given that, in accordance with Rules 20, 20.1 through 20.5 of the San Diego Air Pollution Control District's Rules and Regulations, the Air Pollution Control Officer has made a decision to amend conditions of a Final Determination of Compliance (FDOC) and issue a Permit to Operate for two power plant gas turbines, total 517 megawatts (MW) gross power output, as described in Application No. 976846 and amended under Application No. 984461, for the Palomar Energy Project , which is owned by SDG&E.

An Air Quality Impact Analysis was conducted for nitrogen of dioxide (NO₂), carbon monoxide (CO) and fine particulate matter (PM₁₀) for the FDOC. An additional Air Quality Impact Analysis was conducted for NO₂ emissions during various startup scenarios for this project. Results indicate that the operation of this equipment under any condition will not result in the violation of, nor interfere with, the attainment or maintenance of any State or Federal ambient air quality standard.

Written comments may be submitted for a period of 30 days commencing on July 16, 2007, to the Air Pollution Control District, 10124 Old Grove Road, San Diego, CA 92131. Please direct your comments to the attention of Evariste Haury. All information relevant to this action, including the applications, the District's evaluation and the FDOC are available for public review at this same address.

If there are any questions regarding this notice or further information is required, please contact Mr. Evariste Haury at (858) 586-2745.

Published July 16, 2007

EH:ls