



SAN DIEGO AIR POLLUTION CONTROL DISTRICT
COMPLIANCE DIVISION
10124 OLD GROVE ROAD
SAN DIEGO CA 92131-1649
PHONE (858) 586-2650

APCD USE ONLY	
SECTOR	
ID#	
NOV#	

VAPOR TO LIQUID VOLUME RATIO FOR HEALY PHASE II EVR SYSTEMS

Digital Roots Tri-Tester Equivalent Procedure of Exhibit 5 ARB EOs VR-201-XX and VR 202-XX

To be used for V/Ls obtained for Exhibits 9 and 10 ARB EOs 201/202

To calculate V/L use equation in footnote 10 and always use $\gamma=1$.

Final volume dispensed (read from dispenser totalizer) required to be 4.5-5.0 gallons.

Dispensing time/rate values not required on this form if obtained during 2 gallon V/L assessment.

Facility Name:_____ **A/C or PO Number:**_____ **Start Time of Test:**_____

(Record exact time of test in order to demonstrate proper test sequencing as required in Attachment A)

For ISD Alarm Response Purposes only: Hanging hardware visually inspected at the affected dispenser(s): Yes ☐ No ☐

[illegible]



APCD USE ONLY
SECTOR
ID#
NOV#

Digital Roots Tri-Tester Equivalent Procedure of Exhibit 5 ARB EOs VR-201-XX and VR 202-XX

(Record exact time of test in order to demonstrate proper test sequencing as required in Attachment A)

[illegible]
$$^7\text{Dispensing Rate: } Q_g = \left[\frac{G_f - G_i}{t} \right] \times 60, \text{ in gallons per minute}$$
$$^{10} V / L = \left[\frac{y(V_f - V_i)}{G_f - G_i} \right] \times 7.481$$

¹² The District recommends leak checking equipment during test to minimize lost data due to failure of post test leak check.