



SAN DIEGO AIR POLLUTION CONTROL DISTRICT
COMPLIANCE DIVISION
10124 OLD GROVE ROAD
SAN DIEGO CA 92131
PHONE (858) 586-2650

APCD USE ONLY	
SECTOR	
ID#	
NOV#	

VEEDER-ROOT VAPOR POLISHER OPERABILITY TEST PROCEDURE

Exhibit 11 of ARB E.O. VR 203-X or VR-204-X

Facility Name: _____ A/C or PO Number: _____ Date/Time of Test: _____

For ISD Alarm Response Purposes only: Processor ball valves in proper orientation, processor is in the on and automatic vapor processor mode and nozzle boots inspected for damage :Yes ☐ No ☐

FACILITY AND TEST EQUIPMENT INFORMATION	
Date and Time of Last Vapor Polisher Load or Purge:	
Date and Time of Last Fuel Delivery:	
Calibration Date of Flow Meter:	
Calibration Date of Electronic Pressure Measuring Device:	
Calibration Date of Thermometer:	

PRESSURE INTEGRITY TEST RESULTS

Date and Time the Vapor Valve was closed:		
Vapor Control Valve Manually Closed? ¹	☐ YES ☐ NO	
3-Way Ball Valve in Correct Testing Position? <i>Refer to Figure 1</i>	☐ YES ☐ NO	
Leak Detection Solution used during pressure integrity test to check for leaks at the compression fittings found at the bottom of the Vapor Polisher?	☐ YES ☐ NO	
	Initial Test	Retest (If Applicable) ☐ N/A
Initial Pressure Reading	_____ inches W.C.	_____ inches W.C.
Start Pressure Reading [After 1 minute (60 seconds)] ²	_____ inches W.C.	_____ inches W.C.
Final Pressure Reading [After 2 minutes (120 seconds)] ²	_____ inches W.C.	_____ inches W.C.
Difference in Start & Final Pressure Readings	_____ inches W.C.	_____ inches W.C.
Final Pressure Greater than 7.0 inches W.C.?	☐ YES ☐ NO	☐ YES ☐ NO
Final Pressure Greater than Start Pressure?	☐ YES ☐ NO	☐ YES ☐ NO
If No, is the Decrease in Pressure less than 0.5 inches W.C.?	☐ YES ☐ NO	☐ YES ☐ NO
RESULTS: PASS/FAIL		

FLOW TEST RESULTS

Vapor Control Valve Manually Opened? ³	☐ YES ☐ NO
Flow Rate ⁴	_____ SCFH
Pressure Reading at Inlet ²	_____ inches W.C.
Is the Pressure Reading between 1.69 and 2.25 inches W.C.?	☐ YES ☐ NO
Vapor Valve in Automatic Mode after completing Flow Test ⁵	☐ YES ☐ NO
Inlet Test Port in Normal Operating Position after completing Flow Test?	☐ YES ☐ NO
RESULTS: PASS/FAIL	

THERMOMETER TEST RESULTS								
VAPOR VALVE THERMOMETER								
		Ambient Temperature ⁶ (°F)	Outlet Temperature ⁷ (°F)	Calibrated Thermometer Reading (°F)	Difference in Temperatures ⁷ (°F)	Pass/ Fail		
☐ Initial Test Only	Initial Test Results							
Re-test Results ☐ N/A	Introduced Nitrogen into Canister for 2 minutes prior to printing Temperature Diagnostic Report? ☐ YES ☐ NO							
Additional Test Results ☐ N/A	Removed Outlet Temperature Probe from the Canister & waited at least 15 minutes prior to comparing temperatures? ☐ YES ☐ NO							
GASOLINE UST TANK THERMOMETER								
Product Grade of the Gasoline Storage Tank	Gasoline Tank Thermometer Values							
	Initial Test Results			Additional Test Results			Pass/ Fail	
	T5 ⁸ (°F)	T4 ¹⁰ (°F)	Difference in Temperatures (T5-T4) (°F)	Removed tank probe & waited at least 15 minutes prior to comparing temperatures? ☐ YES ☐ NO	T5 ¹⁰ (°F)	Calibrated Thermometer Reading (Cal) ¹⁰ (°F)		Difference in Temperatures (T5-Cal) (°F)
				☐ YES ☐ NO				
				☐ YES ☐ NO				
				☐ YES ☐ NO				
				☐ YES ☐ NO				
				☐ YES ☐ NO				

ATMOSPHERIC PRESSURE SENSOR TEST RESULTS	
Atmospheric Pressure Reading from TLS Console ⁹	____ PSI
Atmospheric Pressure Reading from a Local Independent Source	____ inches Hg
Difference in Pressure Reading Between Local Source and TLS Console ¹⁰	____ inches Hg
Value for 10% of Local Source ¹¹	____ inches Hg
Difference between Local Source and TLS Pressure Reading less than 10% of Local Source?	☐ YES ☐ NO
RESULTS: PASS/FAIL	

¹ Attach the IV8000 RS232 Command Report to this test result form indicating the date and time the valve was last closed automatically as well as the date and time the valve was manually closed.

² Record the pressure reading, in inches water column (W.C.), to the nearest hundredth (e.g. 0.01 inches W.C.).

³ Attach the IV8000 RS232 Command Report to this test result form indicating the date and time the valve was manually opened.

⁴ Record the flow rate, in standard cubic feet per hour (SCFH), to the nearest tenth (e.g. 0.1 SCFH).

⁵ If the Hydrocarbon Verification Test per Exhibit 12 of VR-203-X/VR-204-X will be performed after this test, then the ball valve can be closed after the hydrocarbon verification test has been completed.

⁶ Attach the Vapor Valve Diagnostic Report(s) from the TLS Console to this test result form indicating the Vapor Polisher Ambient and Outlet Temperatures.

⁷ Difference in Temperatures = | Ambient Temperature – Outlet Temperature | or vice versa.

⁸ Attach the In-Tank Diagnostic Report(s) from the TLS Console to this test result form for each gasoline tank tested indicating the T4 and T5 temperature values.

⁹ Attach the ATMP Sensor Smartsensor Diagnostic Report to this test result form indicating the atmospheric pressure, in pounds per square inch (PSI). To convert the pressure from PSI (P_{PSI}) to inches Hg (inches Mercury, P_{Hg}), use the following equation:

$$P_{Hg} = (P_{PSI} + 14.7) * 2.036$$

¹⁰ Difference in Pressure Reading = | TLS Console Pressure Reading – Local Source Pressure Reading | or vice versa, inches Hg.

¹¹ Value for 10% of Local Source = 0.10 * Pressure Reading from Local Source, inches Hg.