SAN DIEGO AIR POLLUTION CONTROL DISTRICT
COMPLIANCE DIVISION
10124 OLD GROVE ROAD
SAN DIEGO CA 92131
PHONE (858) 586-2650

APCD USE ONLY
SECTOR _____
ID#_____
NOV#_____

Exhibit 13 of VR-203/4, and Exhibit 8 of VR-208 or VR-501
Hirt VCS 100 Processor Operability Test

Facility Name: _ **A/C or PO Number: __** **Date/Time of Test*: _**

For ISD Alarm Response Purposes only: Processor is on and processing vapors: **Yes ☐** **No☐**

Was TP-201.3 (Including Exhibit 4) conducted in the last 24 hours? ☐**Yes or** ☐**No**

Was TP-201.4 (Including Exhibit 6) conducted in the last 24 hours? ☐**Yes or** ☐**No**

Was Exhibit 5 conducted in the last 24 hours? ☐ **Yes or** ☐**No**

Was there a fuel delivery within the last 3 hours? ☐**Yes or** ☐**No**

Is the total ullage 70% or less of the total capacity of the GDF storage tank(s): ☐**Yes or** ☐**No**

STEP 5.1	Is POWER switch lit? ☐**Yes or** ☐**No**
STEP 5.2	Is PROCESSING lamp ON? ☐**Yes or** ☐**No** If "YES", test cannot be performed until lamp goes off.
STEP 5.9	Time for PROCESSING Lamp to Light? _minutes Did PROCESSING Lamp light within three (3) minutes? ☐**Yes or** ☐**No**
STEP 5.10	Time for OVERPRESSURE Lamp to Light? _ minutes Did OVERPRESSURE Lamp light within sixty two (62) minutes? ☐**Yes or** ☐**No**

*Record exact time of test to demonstrate proper test sequencing as required in your testing Attachment.