



SAN DIEGO AIR POLLUTION CONTROL DISTRICT
COMPLIANCE DIVISION
10124 OLD GROVE ROAD
SAN DIEGO CA 92131-1649
PHONE (858) 586-2650

APCD USE ONLY
SECTOR
ID#
NOV#

LIQUID CONDENSATE TRAP (LCT) COMPLIANCE PROCEDURE
Exhibit 9 of VR-201 and Exhibit 11 of VR-202
And Exhibit 16 of VR 203/204

Facility Name:_____ **A/C or PO Number:**_____

Time of Test:_____ (Record exact time of test to demonstrate proper test sequencing as specified in Permit to Operate Attachments A or L).

Capacity of LCT in gallons:_____

Time in Minutes for alarm activation after adding fuel:_____

1) Gasoline below 90 percent capacity level of UST?	☐ Yes ☐ No
2) Is metal tag specifying LCT capacity installed above Fuel Entry Point?	☐ Yes ☐ No
3) Did control panel indicate both visual and audible alarms?	☐ Yes ☐ No
4) Did LCT evacuate and sensor alarms clear?	☐ Yes ☐ No

Attach alarm sensor status printout to this form.