



San Diego County  
Air Pollution  
Control District

SAN DIEGO AIR POLLUTION CONTROL DISTRICT  
COMPLIANCE DIVISION  
10124 OLD GROVE ROAD  
SAN DIEGO CA 92131-1649  
PHONE (858) 586-2650 FAX (858) 586-2651

APCD USE ONLY	
SECTOR	
ID#	
NOV#	

**DROP TUBE/DRAIN VALVE PRESSURE INTEGRITY**

TP 201.1C       TP 201.1D

Facility Name: \_\_\_\_\_ A/C or PO Number: \_\_\_\_\_ Time of Test: \_\_\_\_\_  
(Record exact time of test in order to demonstrate proper test sequencing as required in Attachment A)

Drop Tube Overfill Protection Device Installed?  Yes  No

UST INFORMATION: (Only required for TP 201.1D)

Product	Greatest Distance of SFP Measured From Bottom of Tank	Height of Product	Is Product > 4" above bottom of SFP? (If no do not conduct test) Check Yes or No	
			<input type="checkbox"/> Yes	<input type="checkbox"/> No
			<input type="checkbox"/> Yes	<input type="checkbox"/> No
			<input type="checkbox"/> Yes	<input type="checkbox"/> No
			<input type="checkbox"/> Yes	<input type="checkbox"/> No

TEST DATA: Pressure measuring device calibration date: \_\_\_\_\_ Flow meter calibration date: \_\_\_\_\_

Product Grade	Product Adaptor Make/ Model	Time (seconds) to reach 2.00 "w.c." at 0.17 CFH	30-second stabilizing flow rate (CFH) at 1.95" – 2.05"	PASS /FAIL	TP 201.1D only Time (seconds) to reach 2.00 "w.c" at 0.42 CFH	TP 201.1D only 30-second stabilizing flow rate (CFH) at 1.95" – 2.05"	Q <sub>OPD</sub> =Q <sub>Assembly</sub> -Q <sub>Drain</sub>	PASS /FAIL

Q<sub>OPD</sub> = The leak rate of the overfill prevention device cubic feet per hour, Q<sub>ASSEMBLY</sub>= The leak rate of the drop tube assembly, cubic feet per hour, Q<sub>DRAIN</sub>= The leak rate of the drain valve, cubic feet per hour REV 03/21