GENERATOR LOG

DATE	Operator Name/Co.	Hour Meter		Time of Day[1]		Reason For Run[2, 3] (e.g., emergency, test, maintenance, etc.)
		Start	Stop	Start	Stop	

1. **Time of day is required for emergency standby *diesel* engines located within 500 feet of school grounds, except for engines that emit no more than 0.01 g/bhp-hr of diesel particulate matter, or meet the requirements specified in Title 17 CCR, Section 93115.13(f).**
2. **For an external power outage, documentation from the serving utility is required for the hours to count as "emergency" use; for an internal power outage, a description of what caused the failure and receipts and/or work orders are required for the hours to count as "emergency" use.**
3. **Engine maintenance must include the date *and* a description of the maintenance that was performed (i.e., a separate checklist of items or components that were inspected and/or replaced, work orders or receipts from third-party servicing companies, etc.).**