

SAN DIEGO AIR POLLUTION CONTROL DISTRICT  
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131-1649  
PHONE (858) 586-2600

|  |
|--|
| CERTIFICATE OF COMPLIANCE &<br>CERTIFICATE OF REGISTRATION |
| <b>RULE 12</b><br><b>BEC/FS: <u>000000/13W</u></b>         |

|                                |
|--------------------------------|
| <i>San Diego APCD Use Only</i> |
| <b>Reg. No.:</b>               |
| <b>ID No.:</b>                 |
| <b>Existing P/O No.:</b>       |

**Existing Boilers Over 2MMBtu/hr and less than 5MMBtu/hr**

Certificate Holder(DBA): \_\_\_\_\_

Legal Owner(if different from DBA): \_\_\_\_\_

Equipment Location: \_\_\_\_\_

Year of initial installation in San Diego\*: \_\_\_\_\_

Maximum Heat Input: \_\_\_\_\_ Btu/hr

Manufacturer: \_\_\_\_\_

Model: \_\_\_\_\_ Serial Number: \_\_\_\_\_

This Unit is fueled on:    natural gas            lpg/propane            liquid fuel - specify type: \_\_\_\_\_

I, \_\_\_\_\_, certify that I will be in compliance with all applicable District Rules and regulations and the following conditions:

1. No person shall operate any existing or relocated unit unless it is initially tuned no later than January 1, 2022, and tuned at least once every calendar year thereafter. No two tuning events shall occur within 90 days of each other. Boiler tuning shall be conducted in accordance with the recommended tuning procedure of the manufacturer or boiler tuning contractor, or the tuning procedure specified in 40 CFR Part 63, Sections 63.7540(a)(10)(i) through (vi). [Rule 69.2.2(d)(3)]
2. An owner or operator of an existing or relocated unit shall maintain documentation verifying the required annual tune-ups. [Rule 69.2.2(h)(3)]
3. All records shall be maintained on site for at least three calendar years in electronic and/or hardcopy format and shall be made available to the District upon request. [Rule 12 and/or 69.2.2(h)]
4. This equipment shall not discharge into the atmosphere from any single source of emissions, any air contaminant for a period or periods aggregating more than three minutes in any one hour which has an opacity such as to obscure an observer's view to a degree equal to or greater than does smoke of a shade designated Ringelmann 1 or equivalent 20 percent opacity. (Rule 12 and/or Rule 50)
5. Equipment shall not discharge such quantities of air contaminants or other material which cause injury, detriment, nuisance or annoyance to any considerable number of persons or to the public; or which endanger the comfort, repose, health or safety of any such persons or the public; or which cause or have a natural tendency to cause injury or damage to business or property. (Rule 12 and/or Rule 51)
6. Any person who holds a valid Certificate and who desires to change the location of the registered emission unit shall first apply for and obtain a revised Certificate from the Air Pollution Control Officer. The application shall be accompanied by the applicable application and processing fees specified in Rule 40 – Permit and Other Fees. This provision shall not apply to any change of location within a stationary source or any change of location for a portable emission unit. [Rule 12(f)(3)]
7. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District.
8. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
9. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Title: \_\_\_\_\_ Affiliation: \_\_\_\_\_

**CERTIFICATE OF REGISTRATION (FIRST YEAR)**

*A copy of this registration certificate must be kept with the equipment and presented upon request to the Air Pollution Control District. Every person who operates this equipment is required to comply with all Air Pollution Control District Rules and Regulations, including Rule 12. Any person who violates a rule or regulation of the Air Pollution Control District or any of the conditions listed above is guilty of a misdemeanor and may be subject to civil and criminal penalties. To remain valid, this certificate must be renewed annually in accordance with District Rule 12.*

Approved by: \_\_\_\_\_ Date: \_\_\_\_\_  
*(APCD Engineer's Signature)*

\* To qualify as an existing unit per Rule 69.2.2, a boiler must have been installed in San Diego County and capable of operation prior to July 1, 2021. Attach proof of installation or operation such as work orders or maintenance receipts etc.