

SAN DIEGO AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131-1649
PHONE (858) 586-2600 • FAX (858) 586-2601

**CERTIFICATE OF COMPLIANCE &
CERTIFICATE OF REGISTRATION**

RULE 12

BEC/FS: 10929/34W

San Diego APCD Use Only

APP/Reg. No.:

ID No.:

Existing P/O No.:

Existing Non-Diesel Internal Combustion Emergency Standby Engines

Certificate Holder (DBA): _____

Legal Owner (if different from DBA): _____

Equipment Location: _____

Equipment Description: Manufacturer: _____

Model No.: _____ Serial No.: _____

HP Rating: _____ Type of Fuel: _____

Date first operated in San Diego County: _____

Emission Control, if any: _____

I, _____, certify that I will be in compliance with all applicable District Rules and
(Print or type name)

Regulations and the following conditions:

1. The engine shall not be operated for more than 52 hours per calendar year for non-emergency purposes. (Rule 12)
2. Air contaminant emissions shall not be more dense than 20% (or number 1 on Ringelmann Chart) for more than three (3) minutes in any consecutive 60 minute period. Crankcase smoke shall also be in compliance with Rule 50.
3. The engine shall not cause or contribute to a public nuisance. (Rule 51)
4. All records required by this Certificate of Registration, including but not limited to the following records, shall be maintained on site for a minimum of three years and made available to the District upon request: cumulative hours of operation per calendar year, dates and times of operation, whether the operation was for non-emergency or emergency purposes and the nature of the emergency, if known, and engine maintenance including dates maintenance was performed and the nature of the maintenance. (Rule 12)
5. By November 15, 2002, the engine shall be equipped with either a non-resettable totalizing fuel meter or a non-resettable elapsed operating time meter. (Rule 69.4.1, 17CCR §93115)
6. On or after November 15, 2002, the registrant shall conduct maintenance of the engine, in accordance with the maintenance procedures recommended by the engine manufacturer or approved by the District, at least once each calendar year. (Rule 69.4.1)
7. On or after November 15, 2002, the registrant shall maintain a copy of the maintenance procedures recommended by the engine manufacturer or other maintenance procedures approved in writing by the District. (Rule 69.4.1, 17CCR §93115)
8. The registrant shall provide access, facilities, utilities and any necessary safety equipment for source testing and inspection upon request of the Air Pollution Control District. (Rule 19)

Signature: _____ Date: _____

Title: _____ Affiliation: _____

CERTIFICATE OF REGISTRATION (FIRST YEAR)

A copy of this registration certificate must be kept with the equipment and presented upon request to the Air Pollution Control District. Every person who operates this equipment is required to comply with all Air Pollution Control District Rules and Regulations, including Rule 12. Any person who violates a rule or regulation of the Air Pollution Control District or any of the conditions listed above is guilty of a misdemeanor and may be subject to civil and criminal penalties. To remain valid, this certificate must be renewed annually in accordance with District Rule 12.

Approved by: _____ Date: _____

PROPOSED RULE 12.1 - SELECTED APPLICABLE REQUIREMENTS

(APCD Engineer's Signature)