

E19 - ENGINES, NATURAL GAS FIRED, 4 STROKE, RICH BURN, WITH NON-SELECTIVE CATALYTIC REDUCTION

CALCULATION METHODS

$E_a = U_a \times EF$ (lbs/mmft³)

$E_h = U_h$ (scfm) \times (60/1000000) \times EF (lbs/mmft³)

NOTES:

- The trace organic factors listed below are based on detected AB 2588 compounds listed in AP-42 Table 3.2-3 (7/00).
- The AP-42 (7/00) emission factors have been converted into lbs/mmscf by assuming a natural gas BTU content of 1020 BTU/scf.
- PM10 and TSP emission factors include filterable and condensable PM in accordance with the District's definition of particulate matter.
- The listed AP-42 emission factors for 1,1,2-trichloroethane, 1,1-dichloroethane, 1,2-dichloroethane, 1,2-dichloropropane, 1,3-dichloropropene, carbon tetrachloride, chloroform, ethylene dibromide, styrene, and vinyl chloride are NOT included since these values are based on nondetectable test results.
- The listed AP-42 emission factors for 1,1,2,2-tetrachloroethane, 1,2,4-trimethylbenzene, 2,2,4-trimethylpentane, 2-methylnaphthalene, acenaphthalene, acenaphthylene, anthracene, benz(a)anthracene, benzo(a)pyrene, benzo(b)fluoranthene, benzo(g,h,i)perylene, benzo(k)fluoranthene, biphenyl, chlorobenzene, chrysene, cyclohexane, fluoranthene, fluorene, indeno(1,2,3-c,d)pyrene, perylene, phenanthrene, and pyrene are NOT included since these values were based on insignificant and/or nondetectable test results.
- Trace metal emission factors were not reported in AP-42 and are NOT included since natural gas fired engines are not expected to emit metals.
- The AP-42 emission factors for 1,2,3-trimethylbenzene, 1,3,5-trimethylpentane, butane, butyr/isobutyraldehyde, cyclopentane, ethane, isobutane, methylcyclohexane, n-nonane, n-octane, n-pentane, and propane are not included since these are not listed toxic air contaminants.
- The AP-42 acrolein emission factor is NOT included since this value is based on test data and detection limits from incorrect sampling methods. A District factor based on local test results and adjusted for equipment VOC controls is considered more accurate than the AP-42 value.

Pollutant	District Emission Factor (lbs/million ft ³ fuel burned)	EPA Reference Document	EPA Factor	Units	Comments
NOx	225.42	AP-42, Sect 3.2.5, Table 3.2-3	2.21E+00	lbs/MMBTU	NSCR 90% control for NOx value shown in Table 3.2-3.
CO	379.44	AP-42, Sect 3.2.5, Table 3.2-3	3.72E+00	lbs/MMBTU	NSCR 90% control for CO value shown in Table 3.2-3.
SOx	0.60	AP-42, Sect 3.2.5, Table 3.2-3	5.88E-04	lbs/MMBTU	Assume a sulfur content of 0.05% and a fuel density of 7 lbs/gal
TOG	36.52	AP-42, Sect 3.2.5, Table 3.2-3	3.58E-01	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
ROG	3.02	AP-42, Sect 3.2.5, Table 3.2-3	2.96E-02	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
TSP	19.80	AP-42, Sect 3.2.5, Table 3.2-3	1.94E-02	lbs/MMBTU	TSP includes filterable (9.50 E-03) and condensable (9.91 E-03) PM.
PM10	19.80	AP-42, Sect 3.2.5, Table 3.2-3	1.94E-02	lbs/MMBTU	PM10 includes filterable (9.50 E-03) and condensable (9.91 E-03) PM.
1,3-Butadiene	0.07	AP-42, Sect 3.2.5, Table 3.2-3	6.63E-04	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
Acetaldehyde	0.29	AP-42, Sect 3.2.5, Table 3.2-3	2.79E-03	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
Acrolein	0.01	AP-42, Sect 3.2.5, Table 3.2-3	2.63E-03	lbs/MMBTU	District uncontrolled emission factor adjusted assuming 90% control efficiency.
Benzene	0.16	AP-42, Sect 3.2.5, Table 3.2-3	1.58E-03	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
Ethylbenzene	0.003	AP-42, Sect 3.2.5, Table 3.2-3	2.48E-05	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.

		3.2-3			control efficiency.
Formaldehyde	2.09	AP-42, Sect 3.2.5, Table 3.2-3	2.05E-02	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
Methanol	0.31	AP-42, Sect 3.2.5, Table 3.2-3	3.06E-03	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
Methylene Chloride	0.004	AP-42, Sect 3.2.5, Table 3.2-3	4.12E-05	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
Naphthalene	0.01	AP-42, Sect 3.2.5, Table 3.2-3	9.71E-05	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
PAH	0.01	AP-42, Sect 3.2.5, Table 3.2-3	1.41E-04	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
Toluene	0.06	AP-42, Sect 3.2.5, Table 3.2-3	5.58E-04	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.
Xylenes	0.02	AP-42, Sect 3.2.5, Table 3.2-3	1.95E-04	lbs/MMBTU	Uncontrolled VOC factors adjusted assuming 90% control efficiency.

Last Updated on 7/20/01 (E08)
By D. Byrnes / A. Mar