

FOR YOUR INFORMATION

The Following Notice was Published by the District

**NOTICE OF PRELIMINARY DECISION
TO APPROVE A SOURCE OF AIR POLLUTION BY THE
SAN DIEGO AIR POLLUTION CONTROL DISTRICT**

The San Diego Air Pollution Control District has made a preliminary decision to approve Authorities to Construct for three diesel emergency engines, Application Nos. APCD2018-APP-005211, APCD2018-APP-005212, and APCD2018-APP-005213, to be operated at Naval Air Station North Island in San Diego.

An evaluation of the air pollution impacts of this proposal was performed by the District and it was determined that all applicable District Rules and Regulations will be met when the equipment complies with conditions prescribed by the District. An Air Quality Impact Analysis was conducted for Oxides of Nitrogen (NOx). Results indicate that the operation of this equipment will not result in the violation of any State or Federal ambient air quality standard or interfere with the attainment or maintenance of any State or Federal ambient air quality standard.

The Air Quality Impact Analysis is available for review at the Air Pollution Control District, 10124 Old Grove Road, San Diego, CA 92131. Please refer to Application Nos. APCD2018-APP-005211, APCD2018-APP-005212, and APCD2018-APP-005213 on all correspondence regarding this project. Written comments concerning the District's proposed action may be submitted for a period of 30 days commencing May 4, 2018, and ending on June 4, 2018. Questions regarding this notice may be directed to Arthur Carbonell at (858) 586-2741 or John Annicchiarico at (858) 586-2733.

.....
Published: May 4, 2018

AC:cm – 05/04/2018