

---

---

**San Diego County Air Pollution Control District**

10124 Old Grove Rd  
San Diego, CA 92131-1649  
(858) 586-2600

---

---

**TITLE V OPERATING PERMIT**

**APCD2013-TVP-00036**

**Issued To:**

El Cajon Energy LLC  
Site ID # APCD2009-SITE-06554

**Site Address:**

222 N Johnson Ave  
San Diego, CA 92020  
(619) 579-9002

**Mailing Address**

650 Bercut Dr #C  
Sacramento, CA 95811

**Responsible Official** – Paul Z. Cummins

**Facility Contact** – Stephen Cobbe

**Permit Information Contact** – Stephen Cobbe

---

---

Issued by the San Diego County Air Pollution Control District on 2024.

This Title V Operating Permit expires on 2028.

---

Mohsen Nazemi, Chief of Engineering

Date

## **TABLE OF CONTENTS**

	<b>PAGE</b>
<b>PREAMBLE</b>	<b>2</b>
<b>SECTION I. REGULATION XIV PERMIT REQUIREMENTS</b>	<b>3</b>
A. ADMINISTRATIVE PERMIT TERMS	3
B. RENEWAL REQUIREMENTS AND TERMS	3
C. MONITORING, RECORDKEEPING & REPORTING REQUIREMENTS	4
D. GENERAL PERMIT REQUIREMENTS	5
<b>SECTION II. FACILITY-WIDE REQUIREMENTS</b>	<b>6</b>
A. GENERAL PERMIT PROGRAM APPLICABLE REQUIREMENTS	6
B. GENERAL PROHIBITORY APPLICABLE REQUIREMENTS	6
C. PERMIT SHIELDS	7
D. ADDITIONAL TERMS	7
E. TITLE IV PERMIT (ACID RAIN)	7
<b>SECTION III. EMISSION UNIT REQUIREMENTS</b>	<b>8</b>
A. DISTRICT PERMITTED EMISSION UNITS	8
B. REGISTERED AND LEASED EMISSION UNITS	8
C. INSIGNIFICANT EMISSION UNITS AND ACTIVITIES	8
<b>SECTION IV. VARIANCE PROCEDURES</b>	<b>8</b>
<b>SECTION V. APPENDICES</b>	<b>A-1</b>
A. DISTRICT PERMITS AND REGISTERED UNITS	A-1
B. RULE REFERENCE TABLE	B-1
C. ABBREVIATIONS	C-1

## PREAMBLE

This Title V Operating Permit consists of this document and all appendices, including District permits incorporated by reference. The facility is subject to all applicable requirements identified within this permit, unless a specific permit shield is specified within this permit. If an applicable requirement is omitted from this permit, the facility is still obligated to comply with such an applicable requirement. The permittee must comply with all of the terms listed in each section of this permit.

This permit contains five major sections: Section I contains the Regulation XIV requirements required to carry out the Title V Operating Permit program. Section II contains the requirements that are applicable to the facility on a facility-wide basis. Section III contains the requirements that are applicable to individual emission units which have been issued District permits or District registration, or which have been determined to be insignificant emission units. Section IV contains terms and requirements pertaining to variance procedures and compliance schedules, if applicable to the facility. Section V contains three appendices. Appendix A contains all the District permits incorporated within this permit. Appendix B contains a table of all SIP approved and District approved rules. Appendix C contains a list of abbreviations used within this permit.

Copies of the Rules and Regulations of the Air Pollution Control District of San Diego County and the Rules and Regulations for San Diego County contained in the State Implementation Plan (SIP) approved by EPA may be obtained at the District. Copies are also available for review at the following locations:

SD Air Pollution Control District  
10124 Old Grove Rd  
San Diego, CA 92131-1649  
(858) 586-2600

The current Rules and Regulations of the Air Pollution Control District of San Diego County may also be viewed and downloaded using the following internet address:

[http://www.sdapcd.org/content/sdc/apcd/en/Rule\\_Development/Rules\\_and\\_Regulations.html](http://www.sdapcd.org/content/sdc/apcd/en/Rule_Development/Rules_and_Regulations.html)

The following addresses should be used to submit any certifications, reports or other information required by this permit:

SD Air Pollution Control District  
Compliance Division  
10124 Old Grove Rd.  
San Diego, CA 92131

USEPA Region IX  
ECAD Attn: ENF 2-1  
75 Hawthorne Street  
San Francisco, CA 94105

*For reports sent to the District, in lieu of a hardcopy, reports may be emailed to [apcdcomp@sdapcd.org](mailto:apcdcomp@sdapcd.org)*

## **SECTION I. REGULATION XIV PERMIT REQUIREMENTS**

### **A. ADMINISTRATIVE PERMIT TERMS**

1. This Title V Operating Permit expires 5 years from date of issuance. [Rule 1410]
2. Commencing or continuing operation under this permit to operate shall be deemed acceptance of all terms and conditions specified within this permit. This does not limit the right of the applicant to seek judicial review or seek federal EPA review of a permit term or condition. [Rule 1421]
3. This permit may be modified, revoked, reopened and reissued, or terminated by the District for cause. [Rule 1421]
4. The filing of a request by the facility for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay the applicability of any permit condition. [Rule 1421]
5. This permit does not convey any property rights of any sort, or any exclusive privilege. [Rule 1421]
6. The need for the permittee to halt or reduce a permitted activity in order to maintain compliance with any term or condition of this permit shall not be a defense for any enforcement action brought as a result of a violation of any such term or condition. [Rule 1421]
7. In the event of challenge to any portion of this permit, the rest of the permit remains valid. [Rule 1421]
8. For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any applicable requirement in this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed. [Rule 1421]

### **B. RENEWAL REQUIREMENTS AND TERMS**

1. The permittee shall submit a complete application for renewal of this permit to the Air Pollution Control Officer at least 12 months, but not more than 18 months, prior to permit expiration. [Rule 1410]
2. If an administratively complete application for renewal of this permit has been submitted to the Air Pollution Control Officer within the timeframe specified in Section I.B.1. , the terms and conditions of this permit shall remain in effect and the source may continue operations under these terms and conditions until the Air Pollution Control Officer issues or denies the permit renewal. [Rule 1410]

**C. MONITORING, RECORDKEEPING & REPORTING REQUIREMENTS**

1. The permittee shall provide the District access to the facility and all equipment subject to this permit, and access to all required records pursuant to California Health and Safety Code Section 41510. [Rule 1421]
2. The permittee shall maintain all records required by this permit including any calibration, maintenance, and other supporting information and copies of all reports required by this permit for at least five (5) years from their date of creation. Such records shall be maintained on-site for a minimum of three years. This requirement controls and supersedes any other record retention requirement under this permit as it pertains to, and is required by, District Rule 1421 and Title V of the Clean Air Act. [Rule 1421]
3. Records required by this permit shall be considered as being maintained "on-site" if records for the previous 12-month period are available at the stationary source and any additional records are maintained at a location to be specified by the source and made readily available to the District upon request. [Rule 21]
4. The permittee shall submit monitoring and recordkeeping summary reports and all other monitoring and recordkeeping reports required by this permit to the District every six months, unless a shorter time frame is required by a specific permit condition contained in Section III of this permit. Unless other dates are specified in Section III, reports for data required to be collected from January 1 through June 30, shall be submitted no later than September 1 of the calendar year, and reports for data required to be collected from July 1 through December 31, shall be submitted no later than March 1 of the following calendar year. The report for the final six months of the year may be consolidated with the annual compliance certification required below. All instances of noncompliance from federally enforceable applicable requirements shall be clearly identified in these reports. (Timely completion of District Certification Reports Form 1401-J1 and Form 1401-J2, if applicable, and all indicated attachments, fulfills the requirements of this condition.) [Rule 1421]
5. Each calendar year, the permittee shall submit to the District and to the federal EPA an annual compliance certification, in a manner and form approved in writing by the District, for the previous calendar year that includes the identification of each applicable term or condition of the final permit for which the compliance status is being certified, the compliance status and whether the facility was in continuous or intermittent compliance during the previous calendar year, identification of the method used to determine compliance during the previous calendar year, and any other information required by the District to determine the compliance status. The annual compliance certification for a calendar year shall be submitted no later than March 1 of the following calendar year and may be consolidated with the monitoring and recordkeeping report for the last six months of the year for which compliance is certified. (Timely completion of District Certification Reports Form 1401-J1 and Form 1401-J2, if applicable, and all indicated attachments, fulfills the requirements of this condition.) [Rule 1421]
6. Any report submitted to the District or federal EPA pursuant to this permit to comply with a federally enforceable applicable requirement, shall be certified by a responsible

official stating that, based on information and belief formed after reasonable inquiry, the report is true, accurate and complete. [Rule 1421]

7. The permittee shall make any trade secret designations of records, documents, or other information submitted to the District or federal EPA in accordance with District Rule 176. [Rule 176]
8. The permittee shall report all deviations from any and all federally enforceable permit terms and conditions including: (a) breakdowns, whether or not they result in excess emissions, (b) deviations that result in excess emissions of any regulated air pollutant, and (c) deviations from monitoring, recordkeeping, reporting and other administrative requirements that do not result in excess emissions. For deviations that result from breakdowns under District Rule 98, the permittee shall report the breakdown within two hours of detection of the breakdown and provide a follow-up written report after corrective actions have been taken. For deviations not due to a breakdown but which result in excess emissions, the permittee shall report the deviation within ten calendar days of detection. For all other deviations where no specific time frame for reporting a deviation applies, the permittee shall report the deviation at the time of the next semi-annual monitoring summary or annual compliance certification, whichever occurs first. If an underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, then the criteria for the applicable requirement shall apply. The report must include the probable cause of such deviations and any corrective actions or preventive measures taken. [Rule 1421]

#### **D. GENERAL PERMIT REQUIREMENTS**

1. The permittee shall comply with all terms and conditions of this permit. This permit consists of this document and Appendices A, B and C. Any noncompliance with the federally applicable terms and conditions of this permit shall constitute a violation of the federal Clean Air Act. Noncompliance with any federally applicable permit term or condition of this permit is grounds for federal enforcement action or enforcement action by the District; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. Noncompliance with any District permit term or condition is grounds for enforcement action by the District. [Rule 1421]
2. Upon a written request by the District, the permittee shall furnish to the District any information needed to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit; any information required to determine compliance with this permit; or any records required to be maintained pursuant to this permit. Such information shall be provided within a reasonable time, as specified within the District's written request. [Rule 1421]
3. The permittee shall pay annual fees in accordance with District Rule 40. [Rule 1421]
4. The permittee shall provide access, facilities, utilities and any necessary safety equipment for source testing and inspection upon request from the District. [Rule 19]
5. This permit shall be maintained on-site at all times and be made available to the District upon request. [Rule 1410]

6. The Rule Reference Table provided in Appendix B shall be used to determine whether a cited rule is a federally and District enforceable requirement or a District only enforceable requirement. Any new or revised District rule shall not be considered federally enforceable until the rule is approved by EPA into the SIP. In cases where SIP approval is pending for a revised District rule, the rule citation shall refer to both the current SIP approved rule and the revised District rule. [Rule 1421]

## SECTION II. FACILITY-WIDE REQUIREMENTS

### A. GENERAL PERMIT PROGRAM APPLICABLE REQUIREMENTS

The permittee shall comply with the applicable requirements specified in the Rules and Regulations cited below, unless specifically exempted by the same Rule or Regulation.

Regulation	Rule Citation	Title
SDCAPCD Reg. II	10(a) 10(b)	Permits Required – (a) Authority to Construct Permits Required – (b) Permit to Operate
SDCAPCD Reg. II	19	Provision of Sampling & Testing Facilities
SDAPCD Reg. II	19.2	Continuous Emission Monitoring Requirements
SDCAPCD Reg. II	19.3	Emission Information
SDCAPCD Reg. II	20	Standards for Granting Permits
SDCAPCD Reg. II	20.1, 20.2	New Source Review (NSR)
SDCAPCD Reg. II	21	Permit Conditions
SDCAPCD Reg. II	24	Temporary Permit to Operate
SDCAPCD Reg. II	25	Appeals
SDCAPCD Reg. IV	60	Circumvention
SDCAPCD Reg. V	98*	Breakdown Conditions: Emergency Variance
SDCAPCD Reg. VI	101	Burning Control
SDCAPCD Reg. VIII	131	Stationary Source Curtailment Plan
40 CFR Part 68	Part 68	Risk Management Plan (Ammonia Storage)
40 CFR Part 82	Subpart B	Servicing of Motor Vehicle Air Conditioners
40 CFR Part 82	Subpart F	Recycling and Emission Reducing

\*Breakdowns/variances are not recognized by EPA and cannot grant relief from federal enforcement of requirements

### B. GENERAL PROHIBITORY REQUIREMENTS

The permittee shall comply with the generally applicable requirements specified in the Rules and Regulations cited below, unless specifically exempted by the same Rule or Regulation. These generally applicable requirements apply on a facility-wide basis to all permitted equipment, registered equipment, and insignificant activities. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more permitted emission units, the requirement is also included in Section III.A. of this permit.

#### Facility-wide Prohibitory Requirements

Regulation	Rule Citation	Title
SDAPCD Reg. II	19.2	Continuous Emission Monitoring Requirements
SDCAPCD Reg. IV	50	Visible Emissions
SDCAPCD Reg. IV	51	Nuisance
SDCAPCD Reg. IV	53	Specific Contaminants
SDCAPCD Reg. IV	62	Sulfur Content of Fuels
SDCAPCD Reg. XII	1200	Toxic Air Contaminants – New Source Review
SDCAPCD Reg. XII	1206**	Asbestos Removal, Renovation, and Demolition
SDCAPCD Reg. X	Subpart A	NSPS - General Provisions
SDCAPCD Reg. XI	Subpart A	NESHAPS - General Provisions
SDCAPCD Reg. XI	Subpart M**	NESHAPS – Asbestos
40 CFR Part 72	Part 72	Acid Rain
40 CFR Part 73	Part 73	Sulfur Dioxide Allowance System

\*\* The District issued its own Asbestos Rule 1206 intended to be as stringent as Subpart M. The facility is subject to the most stringent requirements of either rule

**C. PERMIT SHIELDS**

1. No permit shield applies.

**D. ADDITIONAL TERMS**

1. Any emission unit described in this Title V operating permit as being fired on natural gas, shall only use Public Utility Commission (PUC)-quality natural gas, unless the emission unit permit specifies otherwise. [Rules 53, 62]
2. The permittee shall comply with all applicable requirements, including but not limited to, those applicable requirements of 40 CFR Parts 60 and 63.

**E. TITLE IV (ACID RAIN) REQUIREMENTS**

1. The permittee shall not exceed any emission allowances that are lawfully held under Title IV of the federal Clean Air Act or the regulations promulgated thereunder. [Rule 1421]
2. The permittee shall install, operate, and maintain equipment for the continuous monitoring of CO<sub>2</sub> and NO<sub>x</sub> on each applicable exhaust stack in accordance with 40 CFR Parts 72 and 75. [40 CFR Parts 72 and 75]
3. The permittee shall prepare and maintain onsite a written Quality Assurance program in accordance with 40 CFR Part 75, Appendix B for the continuous monitoring of NO<sub>x</sub> emissions from each applicable exhaust stack. The components of the Quality Assurance program include, but are not limited to, procedures for daily calibration testing, quarterly linearity testing, recordkeeping and reporting implementation, and relative accuracy testing. [40 CFR Parts 72 and 75]



4. The permittee shall monitor SO<sub>2</sub> emissions in accordance with 40 CFR Part 72 and 75. [40 CFR Parts 72 and 75]
5. The permittee shall submit quarterly electronic data reports (EDRs) to EPA for the emissions from each applicable exhaust stack in a accordance with 40 CFR Part 75. These reports must be submitted within 30 days following the end of each calendar quarter and shall include all information required in § 75.64. [40 CFR Part 75]

### SECTION III. EMISSION UNIT REQUIREMENTS

#### A. EMISSION UNITS

The District Permits listed and attached in Appendix A, including all terms and conditions of such permits, constitute the emission unit portion of this Title V Operating Permit.

#### B. REGISTERED AND LEASED EMISSION UNITS

The permittee shall comply with the source specific applicable requirements specified in the Rules and Regulations cited below for all registered emission units, unless specifically exempted by the same Rule or Regulations.

Regulation	Rule Citation	Title
SDCAPCD Reg. IV	19.2	Continuous Emission Monitoring Requirements
SDCAPCD Reg. IV	20.1, 20.2	New Source Review (NSR)
SDCAPCD Reg. IV	52	Particulate Matter
SDCAPCD Reg. IV	53	Specific Contaminants
SDCAPCD Reg. IV	54	Dust and Fumes
SDCAPCD Reg. IV	62	Sulfur Content of Fuels

#### C. INSIGNIFICANT EMISSION UNITS AND ACTIVITIES

The permittee shall comply with all applicable requirements for any Insignificant Units located at this facility that are listed at District Regulation XIV, Appendix A. Insignificant Units at this facility include the following:

1. Refrigeration units except those used as, or with, air pollution control equipment with a charge of < 50 lbs of a Class I or II ozone depleting compound.

### SECTION IV. DISTRICT-ONLY PROVISIONS

#### VARIANCE PROCEDURES

The permittee may seek relief from District enforcement action from District-only provisions in the event of a breakdown in accordance with District Rule 98. Notwithstanding the foregoing, the granting by the District of breakdown relief or the

issuance by the Hearing Board of a variance does not provide relief from federal enforcement or citizen's suits. [Rule 98]

**SECTION V. APPENDICES**

**APPENDIX A: DISTRICT PERMITS**

<b>Permit No.</b>	<b>Description</b>
APCD2011-PTO-000946	Gas Turbine Engine Generator



**COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT**  
**10124 OLD GROVE ROAD, SAN DIEGO, CA 92131**  
**PHONE (858) 586-2600 Fax (858) 586-2601**  
**www.sdapcd.org**

**Sectors:** 4, L  
**Site ID:** APCD2009-SITE-06554  
**App ID:** APCD2015-APP-003978

**PERMIT ID**  
**APCD2011-PTO-000946**  


El Cajon Energy Center LLC  
 Plant Manager Ty Cheesbrough  
 222 N Johnson Ave  
 El Cajon CA, 92020

**EQUIPMENT ADDRESS**  
 El Cajon Energy, LLC  
 Stephen Cobbe  
 222 N Johnson Avenue  
 El Cajon CA 92020

## PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

**EQUIPMENT OWNER**

El Cajon Energy, LLC Paul Cummins 650 Bercut Dr #C, Sacramento, CA 95811

**EQUIPMENT DESCRIPTION**

The permitted emission unit ("Emission Unit") consists of the following: Gas Turbine Engine Generator: General Electric, Model LM-6000PC Sprint, 49.95 MW capacity, 472.5 MMBtu/hr (HHV) heat input, natural gas-fired, simple-cycle, S/N 191-619 with an integrated water injection system; a Cormetech selective catalytic reduction ("SCR") system, including an automatic ammonia injection control system; an oxidation catalyst; a Continuous Emission Monitoring System ("CEMS") for NOx, CO and O2; and a data acquisition and handling system ("DAS"); two (2) Cambridge Engineering Industrial Process Heaters, Model S1600, rated at 1.375 MMBtu/hr each.

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [93A] Test Witness and Report Review (T&M)  
 1 [20F] Non- Aircraft Turbine Engine

BEC: APCD2011-CON-000374

**FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES**

**A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS**

1. In the event that the gas turbine engine with S/N 191-619 is removed from service for required repair, the permit holder may install an identical gas turbine engine (General Electric, Model LM-6000, 46.5 MW capacity) as a temporary replacement. The temporary turbine may be operated for a time period not to exceed 120 calendar days for each time the gas turbine engine with S/N 191-619 is repaired. This time period shall begin on the day that construction has been completed on the installation of the temporary gas turbine engine. Prior to operating the temporary gas turbine engine, the applicant shall notify the District, in writing, that this construction has been completed. The time period shall end on the day that construction has been completed on the re-installation of the gas turbine engine with S/N 191-619 after it has been repaired. Prior to operating the gas turbine engine with S/N 191-619, the applicant shall notify the District, in writing, that this construction has been completed. [NSR]



**COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT**  
**10124 OLD GROVE ROAD, SAN DIEGO, CA 92131**  
**PHONE (858) 586-2600 Fax (858) 586-2601**  
**www.sdapcd.org**

**Sectors:** 4, L  
**Site ID:** APCD2009-SITE-06554  
**App ID:** APCD2015-APP-003978

**PERMIT ID**  
**APCD2011-PTO-000946**  


2. The temporary gas turbine engine shall not be operated unless the air pollution control equipment, CEMS, and data acquisition and recording system specified in the equipment description are in full operation at all times. All conditions specified in this Permit to Operate shall apply to the temporary gas turbine engine. [NSR]
3. This equipment shall be properly maintained and kept in good operating condition at all times. [NSR]
4. The Emission unit shall be fired on Public Utility Commission (PUC) quality natural gas only. The permittee shall maintain quarterly records of sulfur content (grains/100 dscf) and higher and lower heating values (Btu/dscf) of the natural gas and provide such records to the District personnel upon request. [Rule 62]
5. Hourly, monthly and annual records of fuel usage shall be maintained and made available to the District upon request. [NSR; Rule 69.3 or Rule 69.3.1]
6. Except during startup and shutdown conditions, the water injection system, the SCR system and oxidation catalyst control system, including the ammonia injection system serving the turbine, shall be in full operation at all times when the Emission Unit is in operation. [NSR]
7. In the event of a breakdown in an automatic ammonia injection control system, the unit shall be shut down or a trained operator shall operate the ammonia injection control system manually and the breakdown shall be reported to the District Compliance Division pursuant to Rule 98(b)(1) and 98(e). [Rule 98]
8. All records required by this permit shall be kept for a minimum of three (3) years and made available to District personnel upon request.
9. For this Emission Unit, the applicant shall hold allowances in accordance with 40 CFR 72.9(c)(i).
10. The emission from the Emission Unit, except during startups and shutdowns, shall not exceed the following emissions limits, as determined by the continuous emission monitoring system (CEMS) and /or District-approved emission testing that calculates an average of three subtests. Compliance with each limit shall be as follows:

Oxides of Nitrogen:	4.4 lbs/hr on a 1 clock-hour basis
Carbon Monoxide:	6.4 lbs/hr on a 3 clock-hour basis
Volatile Organic Compounds (VOC)	1.2 lbs/hr on a 1 clock-hour basis

[NSR]

11. This Emission Unit shall not be operated more than 2500 hours per calendar year. [NSR]
12. The Emission Unit shall not exceed the following emissions limits:
 

Oxides of Nitrogen (NOx):	7.4 tons/year;
Oxides of Sulfur (SOx):	1.2 tons/year;
Particulate Matter (PM10):	4.2 tons/year;
Carbon Monoxide (CO):	14.1 tons/year
Volatile Organic Compounds (VOC):	2.5 tons/year

 [NSR]
13. Emissions of oxides of nitrogen (NOx), calculated as nitrogen dioxide, from the emission unit exhaust stack shall not exceed 2.5 parts per million volume on a dry basis (ppmvd) corrected to 15% oxygen and averaged over each clock 1-hour period. Compliance with this limit shall be demonstrated continuously based on CEMS data and based upon source testing calculated as the average of three subtests. This limit shall not apply during startups or shutdowns. [NSR]
14. Emissions of carbon monoxide (CO) from the emission unit exhaust stack shall not exceed 6.0 parts per million volume on a dry basis (ppmvd) corrected to 15% oxygen and averaged over each rolling 3-hour period. Compliance with this limit shall be demonstrated continuously based on CEMS data and based upon source testing calculated as the average of three subtests. This limit shall not apply during startup or shutdowns. [NSR]



**COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT**  
**10124 OLD GROVE ROAD, SAN DIEGO, CA 92131**  
**PHONE (858) 586-2600 Fax (858) 586-2601**  
**www.sdapcd.org**

**Sectors:** 4, L  
**Site ID:** APCD2009-SITE-06554  
**App ID:** APCD2015-APP-003978

**PERMIT ID**  
**APCD2011-PTO-000946**  


- 15. Emissions of volatile organic compounds (VOC), standardized and reported as methane per Test Methods 25A and/or 18, from the emission unit exhaust stack shall not exceed 2.0 parts per million volume on a dry basis (ppmvd) corrected to 15% oxygen and averaged over each clock hour period. At the time of the initial compliance test, a District-approved CO/VOC surrogate relationship shall be established. Compliance with this limit shall be demonstrated continuously based on CEMS data, using the established CO/VOC surrogate relationship, and based upon source testing calculated as the average of three test runs. The CO/VOC surrogate relationship shall be verified and/or modified, if necessary, based on subsequent source testing. This limit and the corresponding CO/VOC surrogate relationship shall not apply during startups and shutdowns. [NSR]
- 17. For the purpose of this permit to operate, startup period shall be defined as the 30-minute time period starting when fuel flow begins. Shutdown period shall be defined as the 15-minute period preceding the moment at which fuel flow ceases. The data acquisition and handling system (DAS), as required by 40 CFR 75, shall record these events. [NSR; Rule 21]
- 18. During a startup, the emissions from this emission unit shall not exceed the following emission limits as determined by the continuous emissions monitoring system (CEMS), and/or District-approved emission testing.

Pollutant	Startup Emission Limit, lbs/event
Oxides of Nitrogen, NOx (calculated as NO2)	19.3
Carbon Monoxide, CO	14.3
Volatile Organic Compounds, VOC	1.4

- 19. During a shutdown that occurs after the commissioning period, the emissions from this emission unit shall not exceed the following emission limits as determined by the continuous emissions monitoring system (CEMS), and/or District-approved emission testing.

Pollutant	Shutdown Emission limit, lbs/event
Oxide of Nitrogen, NOx (calculated as NO2)	7.8
Carbon Monoxide, CO	8.9
Volatile Organic Compounds, VOC	1.4

- 20. For each startup and shutdown, the DAS shall record the actual times, duration and amount of fuel used. [NSR]
- 21. Operating logs or Data Acquisition System (DAS) records shall be maintained to record the following:
  - a. beginning and end times, to the nearest minute, of all startups and shutdowns;
  - b. fuel usage, in standard cubic feet, for each clock hour, calendar month, and 12-calendar month period;
  - c. hours of daily operation; and
  - d. total cumulative hours per calendar year.
 [NSR]
- 22. A Continuous Emission Monitoring System (CEMS) shall be installed and calibrated to measure, calculate and record the concentration and hourly mass emission rate of oxides of nitrogen (NOx), the hourly average concentration and daily mass emission rate of carbon monoxide (CO), and the percent oxygen (O2) in the exhaust gas, including during the commissioning period. [NSR]
- 23. The Oxides of Nitrogen (NOx) and Oxygen (O2) CEMs shall be certified and maintained in accordance with applicable Federal Regulations including the requirements of: -Sections 75.10 and 75.12 of Title 40 -Code of Federal Regulations Part 75 (40 CFR 75) -the performance specifications of Appendix A of 40 CFR 75 -the quality assurance procedures of Appendix B of 40 CFR 75 -the CEMs protocol approved by the District. The Carbon Monoxide (CO) CEMS shall be certified and maintained in accordance with 40 CFR 60. (40 CFR Part 75, 40 CFR Part 60), and a CEMS protocol approved by the District, unless otherwise specified in this permit. [NSR; 40 CFR Parts 60 and 75]
- 24. The District shall be notified at least two weeks prior to any changes made in CEMS software that affect the measurement, calculation or correction of data displayed and/or recorded by the CEMS. [NSR]



**COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT**  
**10124 OLD GROVE ROAD, SAN DIEGO, CA 92131**  
**PHONE (858) 586-2600 Fax (858) 586-2601**  
**www.sdapcd.org**

**Sectors:** 4, L  
**Site ID:** APCD2009-SITE-06554  
**App ID:** APCD2015-APP-003978

**PERMIT ID**  
**APCD2011-PTO-000946**  


25. When the CEMS is not recording data and the emission unit is operating, hourly NO<sub>x</sub> emissions for the annual emission calculations shall be determined in accordance with 40 CFR 75 Subpart C. Additionally, hourly CO emissions for annual emission calculations shall be determined using CO emission factors to be determined from source test emission factors, recorded CEMS data, and fuel consumption data, in terms of pounds per hour of CO for the gas turbine. Emission calculations used to determine hourly emission rates shall be reviewed and approved by the District, in writing, before the hourly emission rates are incorporated into the CEMS emission data. [NSR]
26. Any violation of any emission standard as indicated by the CEMS shall be reported to the District's Compliance Division within 96 hours after such occurrence. [Rule 98; NSR]
27. The emission unit shall be equipped with continuous parametric monitors to measure, calculate and to record the following operational characteristics:
  - Hours of operation (hours)
  - Natural Gas flow rate (KSCFH)
  - Exhaust gas temperature (° F)
  - Ammonia injection rate (LBS/hr)
  - Water injection rate (lbs/hr)
  - Ratio of water injection rate to fuel consumption rate (lb of water to lb of fuel)
  - Ratio of Ammonia injection rate to outlet NO<sub>x</sub> mass emission rate (lb of ammonia to lb of NO<sub>x</sub>)
  - Inlet temperature of the SCR and Oxidation Catalyst Beds (° F)
  - Net Power output (MW)These monitors shall be installed, calibrated and maintained in accordance with the manufacturer's recommended procedures and a protocol approved by the District. [NSR; Rule 69.3.1; Rule 21]
28. Fuel flow meters shall be installed and maintained to measure the fuel flow rate corrected for temperature and pressure. Correction factors and constants shall be maintained on site and made available to the District upon request. The fuel flow meters shall meet the applicable quality assurance requirements of 40 CFR Part 75 Appendix D, Section 2.1.6. [NSR; 40 CFR Part 75]
29. The ammonia injection flow rate shall be continuously monitored, recorded and controlled. Records of ammonia injection rate and flow rate device calibration shall be maintained and made available to the District. [NSR; Rule 1200]
30. A monitoring plan in conformance with 40 CFR 75.53 shall be submitted to U.S EPA Region 9 and the District at least 45 days prior to the Relative Accuracy Test Audit test, as required in 40 CFR 75.62. [NSR; 40 CFR Part 75]
31. The permittee shall comply with the applicable requirements in 40 CFR Parts 60, 72, 73, and 75. [Rule 1421]
32. This unit shall be source tested to demonstrate compliance with the NO<sub>x</sub>, CO, VOC, and Ammonia emission standards of this permit, using District approved methods. The source test and the NO<sub>x</sub> and CO RATA tests shall be conducted in accordance with the RATA frequency requirements of 40 CFR 75 Appendix B, Sections 2.3.1 and 2.3.3. It is the responsibility of the permittee to schedule the source test with the District. The source test shall be performed or witnessed by the District. [NSR, Rule 1200]
33. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. [Rule 19]



**COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT**  
**10124 OLD GROVE ROAD, SAN DIEGO, CA 92131**  
**PHONE (858) 586-2600 Fax (858) 586-2601**  
**www.sdapcd.org**

**Sectors:** 4, L  
**Site ID:** APCD2009-SITE-06554  
**App ID:** APCD2015-APP-003978

**PERMIT ID**  
**APCD2011-PTO-000946**  


**B. DISTRICT-ONLY ENFORCEABLE CONDITIONS**

16. Ammonia emissions from the emission unit exhaust stack shall not exceed 10 ppmvd corrected to 15% oxygen averaged over each clock 1-hour period. Compliance with this limit shall be demonstrated based upon source testing calculated as the average of three test runs and utilizing one the following procedures:
- a. Calculate 1-hour average ammonia ppmvd levels (ppmvd @ 15% oxygen) using the following equation:
- $$NH_3 = ((a-(b*c/1,000,000))*(1,000,000/b))*d$$
- Where: a= ammonia injection rate (lbs/hr)/(17.0 lbs lb-mole),  
b= exhaust flow rate @ 15% oxygen / (29 lbs/lb-mole),  
c= change in measured NOx concentration (ppmvd @ 15% oxygen) across the catalyst,  
d= ratio of measured ammonia slip to calculated ammonia slip as derived during compliance testing;
- b. Other calculation method using measured surrogated parameters to determine the daily ammonia emissions in ppmvd @ 15% oxygen, as approved, in writing by the District.  
[Rule 1200]
34. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
35. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.)



## APPENDIX B: RULE REFERENCE TABLE

Rule Citation <sup>1</sup>	RULE TITLE	A/R <sup>2</sup>	District Adoption Date <sup>3</sup>	SIP FR Approval Date
	<b>REGULATION I - GENERAL PROVISIONS</b>			
1	Title	F	04/30/80	09/28/81
2	Definitions	F	7/11/17	11/12/20
4	Review of Rules	F	01/01/70 <sup>†</sup>	09/22/72
5	Authority to Arrest	F	03/24/76 <sup>†</sup>	NA
6	Minor Violations	D	12/15/99	N/A
	<b>REGULATION II - PERMITS</b>			
10	Permits Required	F	07/25/95	03/11/98
10.1 <sup>††</sup>	NSPS & NESHAPS Requirements	D	11/8/76	N/A
11	Exemptions from Rule 10 Permit Requirements	F D	07/08/20 10/13/22	10/28/22 Pending
12	Registration of Specified Equipment	D	11/15/00	N/A
12.1	Portable Equipment Registration	D	05/21/97	N/A
14	Applications	F	04/30/80	09/28/81
15	Permit Process - Public Notifications	D	09/18/90	N/A
17	Cancellation of Applications	F	04/06/93	03/11/98
18	Action on Applications	D	09/18/90	N/A
19	Provision of Sampling and Testing Facilities	F	04/06/93	03/11/98
19.1 <sup>††</sup>	NSPS & NESHAPS Provision of Sampling and Testing Facilities Requirements	D	11/08/76	N/A
19.2	Continuous Emission Monitoring Requirements	F D	01/12/79 10/12/23	09/28/81 Pending
19.3	Emission Information	F D	05/15/96 12/09/21	03/09/00 Pending
20	Standards for Granting Permits	F	04/25/89	10/04/18
20.1	NSR - General Provisions	F	10/14/21	09/28/22
20.2*	NSR - Non-major Stationary Sources	F	06/26/19	09/16/20
20.3*	NSR - Major Stationary Source and PSD Stationary Source	F	10/14/21	09/28/22
20.4*	NSR - Portable Emission Units	F	10/14/21	09/28/22
20.5	Power Plants	F	07/05/79	04/14/81
20.6	Standards for Permit to Operate - Air Quality Analysis	F	04/27/16	10/04/18
20.8	Special Offset Requirement Relating to Banking	D	2/16/83	N/A
21	Permit Conditions	F	11/29/94	03/11/98
22	Denial of Applications	D	01/01/69 <sup>†</sup>	N/A
23	Further Information	D	01/01/69 <sup>†</sup>	N/A
24	Temporary Permit to Operate	F	06/29/16	10/04/18
25	Appeals	F	01/01/69 <sup>†</sup>	09/22/72
25	Appeals	D	06/21/00	N/A

26.0	Banking of Emission Reduction Credits (ERCs) - General Requirements	D	06/26/19	N/A
26.1	Standards for Granting Emission Reduction Credits (ERCs)	D	10/22/97	N/A
26.2	Use of Emission Reduction Credits (ERCs)	D	10/22/97	N/A
26.3	Reclassification of Class B Emission Reduction Credits (ERCs)	D	10/22/97	N/A
26.4	Permanency of Banked Emission Reduction Credits (ERCs)	D	10/22/97	N/A
26.5	Transfer of Emission Reduction Credits (ERCs)	D	10/22/97	N/A
26.6	District Banking of Emission Reduction Credits (ERCs)	D	10/22/97	N/A
26.7	Shutdown and Related Emission Unit	D	10/22/97	N/A
26.8	Banking of Limited Emission Reductions	D	10/22/97	N/A
26.9	Emission Reduction Credit Certificates and The Emission Reduction Credit Register	D	10/22/97	N/A
26.10	Banking For BRAC Military Base Closure or Realignment Actions	D	10/22/97	N/A
27	Banking of Mobile Source Emission Reduction Credits	D	11/29/94	N/A
27.1	Federal Requirements for San Diego County APCD Alternative Mobile Source Emission Reduction Program Approved On 9/8/2000	F	08/06/08	06/03/09
	<b>REGULATIONS III - FEES</b>			
40	Permit Fees	D	01/12/23	N/A
42	Hearing Board Fees	D	04/14/22	N/A
44	Technical Reports, Charges for	D	12/7/83	N/A
45	Federally Mandated Ozone Nonattainment Fees	D	6/9/2022	Pending
	<b>REGULATIONS IV - PROHIBITIONS</b>			
50	Visible Emissions	F	08/13/97	12/7/98
50.1††	NSPS & NESHAPS Visible Emissions Requirements	D	11/08/76	N/A
51	Nuisance	F	01/01/69†	09/22/72
52	Particulate Matter	F	01/22/97	12/9/98
52.1††	NSPS & NESHAPS Particular Matter Requirements	D	11/08/76	N/A
53	Specific Contaminants	F	01/22/97	12/9/98
53.1	Scavenger Plants	F	01/01/69†	09/22/72
53.2††	NSPS & NESHAPS Specific Contaminants Requirements	D	11/08/76	N/A
54	Dusts and Fumes	F	01/22/97	12/9/98
54.1	NSPS & NESHAP Dust and Fumes Requirement	D	11/08/76	N/A
55	Fugitive Dust Control	D	06/24/09	N/A
58	Incinerator Burning	F	01/17/73†	05/11/77
59	Control of Waste Disposal - Site Emissions	D	11/03/87	N/A
59.1	Municipal Solid Waste Landfills	D	06/17/98	N/A
60	Circumvention	F	05/17/94	03/09/00
60.1	Limiting Potential to Emit – Small Sources	D	04/04/12	N/A
60.2	Limiting Potential to Emit - Synthetic Minor Sources	D	04/04/12	N/A
61.0	Definitions Pertaining to the Storage & Handling of Organic Compounds	F	10/16/90	09/13/93
61.1	Receiving & Storing Volatile Organic Compounds at Bulk Plants & Bulk Terminals	F	01/10/95	08/08/95

61.2	Transfer of Volatile Organic Compounds into Mobile Transport Tanks	F	02/10/21	12/16/22
61.3	Transfer of Volatile Organic Compounds into Stationary Storage Tanks	F	10/16/90	06/30/93
61.3.1	Transfer of Gasoline into Stationary Underground Storage Tanks	D	03/01/06	09/03/21
61.4	Transfer of Volatile Organic Compounds into Vehicle Fuel Tanks	F	10/16/90	05/13/93
61.4	Transfer of Volatile Organic Compounds into Vehicle Fuel Tanks	F	03/26/08	01/7/13
61.4.1	Transfer of Gasoline from Stationary Underground Storage Tanks into Vehicles Fuel Tanks	D	03/01/06	N/A
61.5	Visible Emission Standards for Vapor Control Systems	F	09/20/78 <sup>†</sup>	04/14/81
61.6	NSPS Requirements for Storage of Volatile Organic Compounds	D	01/13/87	Withdrawn
61.7	Spillage and Leakage of Volatile Organic Compounds	F	01/13/87	03/11/98
61.8	Certification Requirements for Vapor Control Equipment	F	01/13/87	03/11/98
62	Sulfur Content of Fuels	F	10/21/81	07/06/82
62.1 <sup>††</sup>	NSPS Requirements for Sulfur Content of Fuels	D	11/08/76	N/A
64	Reduction of Animal Matter	F	08/21/81	07/06/82
66.1	Miscellaneous Surface Coating Operations and Other Processes Emitting VOCs	F D	2/24/10 5/11/16	08/09/12 ?
67.0.1	Architectural Coatings	F	02/10/21	12/14/22
67.1	Alternative Emission Control Plans	F	05/15/96	03/27/97
67.2	Dry Cleaning Equipment Using Petroleum - Based Solvent	F	05/15/96	03/27/97
67.3	Metal Parts and Products Coating Operations	F	04/09/03	11/14/03
67.4	Metal Container, Metal Closure and Metal Coil Coating Operations	F	11/09/11	09/20/12
67.5	Paper, Film and Fabric Coating Operations	F	05/15/96	03/27/97
67.6.1	Cold Solvent Cleaning and Stripping Operations	F	02/10/21	10/22/21
67.6.2	Vapor Degreasing Operations	F	02/10/21	10/22/21
67.7	Cutback and Emulsified Asphalts	F	05/15/96	03/27/97
67.9	Aerospace Coating Operations	F	04/30/97	08/17/98
67.10	Kelp Processing and Bio-Polymer Manufacturing	F	06/25/97	06/22/98
67.11	Wood Parts and Products Coating Operations	F	06/27/12	04/11/13
67.12.1	Polyester Resin Operations	F	05/11/16	04/02/18
67.15	Pharmaceutical and Cosmetic Manufacturing Operations	F	05/15/96	03/27/97
67.16	Graphic Arts Operations	F	05/09/12	09/20/12
67.17	Storage of Materials Containing Volatile Organic Compounds	F	05/15/96	03/27/97
67.18	Marine Coating Operations	F	05/15/96	03/27/97
67.19	Coating and Printing Inks Manufacturing Operations	F	05/15/96	05/26/00
67.20.1	Motor Vehicle and Mobile Equipment Coating Operations	D	06/30/10	N/A
67.21	Adhesive Material Application Operations	D	11/14/08	N/A
67.22	Expandable Polystyrene Foam Products Manufacturing Operations	D	05/15/96	N/A

67.24	Bakery Ovens	F	05/15/96	03/27/97
68	Fuel-Burning Equipment – Oxides of Nitrogen	F	09/20/94	04/09/96
68.1††	NSPS Requirements for Oxides of Nitrogen from Fuel-Burning Equipment	D	11/08/76	N/A
69	Electrical Generating Steam Boilers, Replacement Units & New Units	D	12/12/95	N/A
69.2	Industrial & Commercial Boilers, Process Heaters & Steam Generators	F	09/27/94	02/09/96
69.2.1	Small Boilers, Process Heaters and Steam Generators	D/F	07/08/20	Pending
69.2.2	Medium Boilers, Process Heaters and Steam Generators	F	09/09/21	8/23/23
69.3**	Stationary Gas Turbine Engines	F	Repealed	06/17/97 (Withdrawal Pending)
69.3.1**	Stationary Gas Turbine Engines – BARCT	D	12/9/21	Pending
69.4**	Stationary Internal Combustion Engines	F	Repealed	01/04/06 (Withdrawal Pending)
69.4.1**	Stationary Internal Combustion Engines - BARCT	D	07/08/20	Pending
69.5.1	Natural Gas-Fired Water Heaters	D	06/24/15	N/A
69.6	Natural Gas-Fired Fan-Type Central Furnaces	D	06/17/98	N/A
69.7	Landfill Gas Flares	D/F	03/09/23	Pending
70	Orchard Heaters	F	01/17/72	09/22/72
71	Abrasive Blasting	F	03/30/77	08/31/78
	<b>REGULATION V - PROCEDURES BEFORE THE HEARING BOARD</b>			
75	Procedure Before the Hearing Board	D	09/17/85	N/A
75.1††	NSPS & NESHAPS Variance Procedures	D	09/17/85	N/A
97	Emergency Variance	D	07/25/95	N/A
98	Breakdown Conditions: Emergency Variance	D	07/25/95	N/A
	<b>REGULATION VI - BURNING CONTROL</b>			
101	Burning Control	F	09/25/02	04/30/03
	<b>REGULATION VII - VALIDITY AND EFFECTIVE DATE</b>			
140	Validity	F	01/01/69†	09/22/72
141	Effective Date	F	01/01/69†	09/22/72
	<b>REGULATION VIII - SAN DIEGO AIR POLLUTION EMERGENCY PLAN</b>			
126	Applicability	F	05/25/77	08/31/78
127	Episode Criteria Levels	F	09/17/91	03/18/99
128	Episode Declaration	F	09/17/91	03/18/99
129	Episode Termination	F	05/25/77	08/31/78
130	Episode Actions	F	09/17/91	03/18/99
131	Stationary Source Curtailment Plan	F	04/01/81	06/21/82

132	Traffic Abatement Plan	F D	05/01/81 12/17/97	06/21/82 N/A
133	Schools	F	05/25/77	08/31/78
134	Source Inspection	F	04/01/81	06/21/82
135	Air Monitoring Stations	F	05/25/77	08/31/78
136	Interdistrict and Interbasin Coordination	F	05/25/77	08/31/78
137	Emergency Action Committee	F	05/25/77	08/31/78
138	Procedures and Plans	F	05/25/77	08/31/78
	APPENDIX A - Persons to be Notified on Episode Declaration	F		
<b>REGULATION IX - PUBLIC RECORDS</b>				
175	General	F	05/22/74†	05/11/77
176	Information Supplied to District	F	05/22/74†	05/11/77
177	Inspection of Public Records	F D	03/30/77 06/20/01	08/31/78 N/A
<b>REGULATION XII - TOXIC AIR CONTAMINANTS</b>				
1200	Toxic Air Contaminants - New Source Review	D	09/19/23	N/A
1202	Hexavalent Chromium - Cooling Towers	D	07/25/95	N/A
1203	Ethylene Oxide Sterilizers and Aerators	D	07/26/00	N/A
1205	Control of Dioxins Emissions from Medical Waste Incinerators	D	01/01/94	N/A
1206	Asbestos Removal, Renovation, and Demolition	D	11/15/17	N/A
1210	Toxic Air Contaminant Public Health Risks - Public Notification and Risk Reduction	D	09/19/23	N/A

<b>REGULATION XIV - TITLE V OPERATING PERMITS</b>				
1401	General Provisions	F	10/14/21	02/27/04
1410	Permit Required	F	02/27/04	02/27/04
1411	Exemption from Permit to Operate for Insignificant Units	F	03/07/95	11/30/01
1412	Federal Acid Rain Program Requirements	F	01/18/94	11/30/01
1413	Early Reduction of Hazardous Air Pollutants	F	03/07/95	11/30/01
1414	Applications	F	03/07/95	11/30/01
1415	Permit Process-Public Notification	F D	02/27/04 10/12/23	02/27/04 Pending
1417	Pendency & Cancellation of Applications	F	03/07/95	11/30/01
1418	Action on Applications	F	02/27/04	11/30/01
1419	Provisions of Sampling & Testing Facilities & Emission Information	F	03/07/95	11/30/01
1420	Standards for Granting Permits	F	03/07/95	11/30/01
1421	Permit Conditions	F	02/27/04	02/27/04
1422	Denial or Cancellation Of Applications	F	03/07/95	11/30/01
1423	Further Information	F	01/18/94	11/30/01
1424	Applications Deemed Denied	F	01/18/94	11/30/01
1425	Appeals & Judicial Review	F	02/27/04	02/27/04
	APPENDIX A - Insignificant Units	F	02/27/04	11/30/01
<b>REGULATION XV - FEDERAL CONFORMITY</b>				
1501	Conformity of General Federal Actions	F	06/22/99	04/23/99

The following NSPS and NESHAP have been adopted locally by the District. EPA has granted the District delegation for each of these rules. Therefore, these rules, as adopted by the District are the federally applicable requirements. In addition, if an NSPS or NESHAP is revised by EPA and the revised rule not adopted by the District, both versions of the rule are considered federally applicable requirements and the most stringent requirement applies until such time as the District adopts the revised version.

<b>Subpart &amp; Citation</b>	<b>RULE TITLE</b>	<b>District Adoption Date(s)</b>	<b>Federal Delegation Date</b>
<b>Part 60</b>	<b>REGULATION X - STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES</b>	04/06/2021	As shown below
A	General Provisions	04/06/2021	04/08/2021
D	Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978	01/29/2020	04/08/2021
Da	Standards of Performance for Industrial-Commercial -Institutional Steam Generating Units	01/29/2020	04/08/2021
Db	Standards of Performance for Small Industrial-Commercial - Institutional Steam Generating Units	01/29/2020	04/08/2021
Dc	Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978	01/29/2020	04/08/2021
E	Standards of Performance for Incinerators	01/29/2020	04/08/2021
Eb	Standards of Performance for Large Municipal Waste Combustors for Which Construction is Commenced After September 20, 1994 or for Which Modification Or Reconstruction Commenced After June 19, 1996	06/20/2007	01/03/2008
Ec	Standards of Performance for Hospital/Medical/Infectious Waste Incinerators	01/29/2020	04/08/2021
I	Standards of Performance for Hot Mix Asphalt Facilities	01/29/2020	04/08/2021
J	Standards of Performance for Petroleum Refineries	01/29/2020	04/08/2021
K	Standards of Performance for Storage Vessels for Petroleum Liquids Construct After June 11, 1973 and Prior to May 19, 1978	06/20/2007	01/03/2008
Ka	Standards of Performance for Storage Vessels for Petroleum Liquids Construction after May 18, 1978	06/20/2007	01/03/2008
Kb	Standards of Performance for Volatile Organic Liquid Storage Vessels (Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984	06/20/2007	01/03/2008
L	Standards of Performance for Secondary Lead Smelters	01/29/2020	04/08/2021
M	Standards of Performance for Secondary Brass and Bronze Ingot Production Plants	01/29/2020	04/08/2021
O	Standards of Performance for Sewage Treatment Plants	01/29/2020	04/08/2021
DD	Standards of Performance for Grain Elevators	01/29/2020	04/08/2021
EE	Standards of Performance for Surface Coating Metal Furniture	01/29/2020	04/08/2021
GG	Standards of Performance for Stationary Gas Turbines	01/29/2020	04/08/2021
QQ	Standards of Performance for the Graphic Arts Industry: Publication Rotogravure Printing	01/29/2020	04/08/2021
RR	Standards of Performance for Pressure Sensitive Tape and Label Surface Coating Operations	01/29/2020	04/08/2021
SS	Standards of Performance for the Industrial Surface Coating Large Appliances	01/29/2020	04/08/2021
TT	Standards of Performance for Metal Coil Surface Coating	01/29/2020	04/08/2021
AAA	Standards of Performance for New Residential Wood Heaters	04/06/2021	04/08/2021
BBB	Standards of Performance for the Rubber Tire Manufacturing Industry	01/29/2020	04/08/2021

FFF	Standards of Performance for Flexible Vinyl and Urethane Coating and Printing	01/29/2020	04/08/2021
JJJ	Standards of Performance for Petroleum Dry Cleaners	01/29/2020	04/08/2021
OOO	Standards of Performance for Nonmetallic Mineral Processing Plants	01/29/2020	04/08/2021
UUU	Standards of Performance for Calciners and Dryers in Mineral Industries	01/29/2020	04/08/2021
VVV	Standards for Polymeric Coating of Supporting Substrates Facilities	05/23/2007	01/03/2008
WWW	Standards of Performance for Municipal Solid Waste Landfills	04/06/2021	04/08/2021
AAAA	Standards of Performance for Small Municipal Waste Combustion Units	06/20/2007	01/03/2008
CCCC	Standards of Performance for Commercial and Industrial Solid Waste Incineration Units	04/06/2021	04/08/2021
EEEE	Standards of Performance for Other Solid Waste Incineration Units	01/29/2020	04/08/2021
III	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines	04/06/2021	04/08/2021
JJJ	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines	04/06/2021	04/08/2021
KKKK	Standards of Performance for Stationary Combustion Turbines	04/06/2021	04/08/2021
QQQQ	Standards of Performance for New Residential Hydronic Heaters and Forced-Air Furnaces	04/06/2021	04/08/2021
TTTT	Standards of Performance for Greenhouse Gas Emissions for Electric Generating Units	04/06/2021	04/08/2021
<b>Part 61 REGULATION XI- NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS (NESHAPS)</b>			
A	General Provisions	01/13/87	05/24/82
C	National Emission Standard for Beryllium	Unknown	11/08/76
D	National Emission Standard for Beryllium Rocket Motor Firing	Unknown	11/08/76
E	National Emission Standard for Mercury	03/27/90	05/17/91
F	National Emission Standard for Vinyl Chloride	08/17/77 06/16/78	11/21/77



The following ATCM and NESHAP have not been adopted by the District, but are being implemented and enforced by the District as ATCM's.

Subpart & Citation	RULE TITLE
<b>DISTRICT RULES AND REGULATIONS APPENDIX A - CALIFORNIA AIRBORNE TOXIC CONTROL MEASURES (ATCM)</b>	
17 CCR § 93102	Hexavalent Chromium ATCM for Chrome Plating & Chromic Acid Anodizing Operations
17 CCR § 93109	ATCM For Emissions of Perchloroethylene From Dry Cleaning Operations
17 CCR § 93101.5	ATCM to Reduce Emissions of Hexavalent Chromium and Nickel from Thermal Spraying
17 CCR § 93105	ATCM for Construction, Grading, Quarrying, and Surface Mining Operations
17 CCR § 93106	Asbestos ATCM for Surface Applications
17 CCR § 93107	ATCM For Emissions of Toxic Metals From Non-Ferrous Metal Melting
17 CCR § 93111	ATCM for Emissions of Chlorinated Toxic Air Contaminants from Automotive Maintenance & Repair Activities
17 CCR § 93112	ATCM for Emissions of Hexavalent Chromium and Cadmium from Motor Vehicle and Motor Equipment Coatings
17 CCR § 93113	ATCM to Reduce Emissions of Toxic Air Contaminants from Outdoor Residential Waste Burning
17 CCR § 93115	ATCM for Stationary Compression Ignition Engines
17 CCR § 93116	ATCM for Portable Diesel-Fueled Engines
<b>Part 63 DISTRICT RULES AND REGULATIONS APPENDIX B - NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS (NESHAP) FOR SOURCE CATEGORIES</b>	
A	General Provisions
N	Hard and Decorative Chromium Electroplating and Chromium Anodizing Tanks
O	Ethylene Oxide Sterilization Facilities
R	Gasoline Distribution
T	Halogenated Solvent Cleaning
DD	Off-site Waste & Recovery Operations
GG	Aerospace Manufacturing and Rework Facilities
II	Shipbuilding and Ship Repair (Surface Coating)
JJ	Wood Furniture Manufacturing Operations
VVV	Publicly Owned Treatment Works
AAAA	Municipal Solid Waste Landfills
EEEE	Organic Liquids Distribution (non-gasoline)
MMMM	Surface Coating of Miscellaneous Metal Parts and Products
PPPP	Plastic Parts (surface coating)
SSSS	Surface Coating of Metal Coil
VVVV	Boat Manufacturing
WWWW	Reinforced Plastic Composites Production
YYYY	Stationary Combustion Turbines
ZZZZ	Stationary Reciprocating Internal Combustion Engines
DDDDD	Industrial, Commercial, and Institutional Boilers and Process Heaters

GGGGG	Site Remediation
HHHHH	Miscellaneous Coating Manufacturing
PPPPP	Engine Test Cells/Stands
WWWWW	Hospital Ethylene Oxide Sterilizers Area Sources
BBBBBB	Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities
CCCCC	Gasoline Dispensing Facilities
HHHHHH	Paint Stripping and Miscellaneous Surface Coating Operations at Area Sources
JJJJJ	Area Sources: Industrial, Commercial, and Institutional Boilers
QQQQQ	Wood Preserving Area Sources
VVVVV	Chemical Manufacturing Area Sources
WWWWW	Plating and Polishing Operations Area Sources
XXXXX	Metal Fabrication and Finishing Area Sources
AAAAA	Asphalt Processing and Asphalt Roofing Manufacturing Area Sources
CCCCCC	Paint and Allied Products Manufacture Area Sources

1. Rule Citations marked with an “††” contain no substantive requirements and are listed for informational purposes only.
2. ‘A/R’ Denotes enforceability of the listed applicable requirement as follows:
  - ‘F’ Denotes a Federal applicable requirement that is federally enforceable and District enforceable.
  - ‘D/F’ Denotes a District applicable requirement which is pending SIP approval. For some rules, there are separate versions denoted as “F” and “D” which indicates when there is a SIP version of the rule, denoted by “F”, which is federally enforceable, and an amended version of the rule which has been approved by the District but has not been approved into the SIP. At the time a pending rule is approved into the SIP, it will become fully federally enforceable and replace the previous version of the rule.
  - ‘D’ Denotes a District only applicable requirement. This may include some state requirements that are enforceable by the District.
3. District adoption dates marked with an “†” are the effective date of the rule, the actual adoption date is uncertain.
4. For rules 20.2-20.4 as marked with a “\*”, certain provisions were not submitted to EPA as denoted in the SIP submittals, and these provisions are therefore not federally enforceable
5. Rules 69.3 and 69.4 were repealed by the District because the applicable provisions were incorporated into Rules 69.3.1 and 69.4.1 which were submitted to EPA for SIP approval. However, these rules have not been approved due to concerns with startup/shutdown exemptions from emission limits.

## APPENDIX C: ABBREVIATIONS THAT MAY APPEAR IN THIS PERMIT

APCO	Air Pollution Control Officer
ASTM	American Society for Testing and Methods
BACT	Best Available Control Technology
CAA	federal Clean Air Act
CFR	Code of Federal Regulations
CO	Carbon Monoxide
CO <sub>2</sub>	Carbon Dioxide
District	San Diego County Air Pollution Control District
EF	Emission Factor
EPA	US Environmental Protection Agency
HAP	Hazardous Air Pollutant
I&M	Inspection and Maintenance
NESHAP	National Emission Standard for Hazardous Air Pollutants
NSPS	New Source Performance Standards
NSR	New Source Review
[NSR]	New Source Review based condition
NO <sub>x</sub>	Oxides of nitrogen
O <sub>2</sub>	Oxygen
OES	Office of Environmental Services
O&M	Operation and maintenance
Pb	Lead
PM	Total Particulate Matter
PM <sub>10</sub>	Particulate matter with aerodynamic equivalent diameter of ≤ 10 microns
PSD	Prevention of Significant Deterioration
RMP	Risk Management Plan
SDCAPCD	San Diego County Air Pollution Control District
SIP	State Implementation Plan
SO <sub>x</sub>	Oxides of sulfur
Title IV	Title IV of the federal Clean Air Act
Title V	Title V of the federal Clean Air Act
VOC	Volatile organic compound

### Units of Measure:

dscf	=	Dry standard cubic foot
g	=	grams
gal	=	gallon
gr/dscf	=	Grains per dry standard cubic foot
hr	=	hour
lb	=	pound
in	=	inches
max	=	maximum
min	=	minute
MM Btu	=	Million British thermal units
psia	=	pounds per square inch, absolute
scf	=	Standard cubic foot
scfm	=	standard cubic feet per minute
yr	=	year