

MM San Diego LLC – Miramar & Miramar Energy One North Lexington Avenue White Plains, New York 10601 Tel. (914) 705-4000 Fax. (914) 705-4019

September 16, 2022

Jim Swaney San Diego County Air Pollution Control District 10124 Old Grove Road San Diego, CA 92131-1649

Subject: Risk Reduction Plan MM San Diego LLC – Miramar & Miramar Energy LLC

Mr. Swaney,

As required, please find enclosed the Risk Reduction Plan for the aforementioned facility that was prepared on our behalf by SCS Engineers. This plan is being submitted prior to the September 18, 2022 deadline and includes a check for \$7,870.00 to cover the application fee estimate.

Please direct all questions regarding this submittal to Suparna Chakladar at (951) 833-4153.

Sincerely,

Anthony J. Falbo Chief Operating Officer OPAL Fuels MM San Diego LLC – Miramar Miramar & Miramar Energy LLC

Enclosure Modification Application for Risk Reduction Activities

cc: Suparna Chakladar, OPAL Benjamin Wong, SDAPCD

Modification Application for Risk Reduction Activities MM San Diego LLC – Miramar & Miramar Energy

MM San Diego LLC 5087 Junction Road Lockport, NY 14094 (951) 833-4153

SCS ENGINEERS

01222225.00 Task 2 | September 2022

7041 Koll Center Parkway, Suite 135 Pleasanton, CA 94566

Table of Contents

Sect	ion			Page
1.0	Intro	duction.		1
	1.1	Overvie	ew	1
	1.2	Backgr	round Information	2
		1.2.1	Applicant Name and Address	2
		1.2.2	Facility Address	2
		1.2.3	Nature of Business	2
		1.2.4	Persons to Contact Regarding Application	2
		1.2.5	Operation Schedule	2
		1.2.6	Status of Application	3
		1.2.7	Facility Status	3
2.0	Proje	ct Desc	ription	3
	2.1	Existin	g Operation	3
	2.2	Reaso	n for Permitting Action	3
3.0	Risk	Reducti	ion	3
	3.1	Risk Co	ontribution	4
	3.2	Risk R	eduction Evaluation	4
		3.2.1	Formaldehyde	4
		3.2.2	Arsenic	6
		3.2.3	Hydrogen Chloride	6
	3.3	Risk R	eduction Schedule	7
	3.4	Risk R	eduction Demonstration	7
	3.5	Progre	ss Reports	8
4.0	Appli	cation F	Form and Fee	8
5.0				

Tables

Table 1.	Emission Unit Health Risk Contribution4
Table 2.	Specific TAC Health Risk Contribution4
Table 3.	Proposed HRA Risk Reduction7

Appendices

Appendix A	SCAQMD Formaldehyde Testing Results
Appendix B	HCI Study for EPA
Appendix C	General Permit Application Form

Appendix C General Permit Application Appendix D SDAPCD Fee Estimate This document is dated September 2022 and was prepared and reviewed by the following:

Gabrielle F. Stephens Senior Project Manager

Patrick S. Sullivan, REPA, CPP, BCES

Senior Vice President SCS ENGINEERS

1.0 INTRODUCTION

1.1 OVERVIEW

This application, prepared by SCS Engineers (SCS), on behalf of MM San Diego LLC – Miramar and Miramar Energy (Facility) details the risk reduction activities that will be implemented at the landfill gas to energy (LFGTE) plant at the Miramar Landfill (Miramar or landfill) to reduce health risk. This document serves as both a modification application to have these risk reduction activities permitted, as well as serving as the risk reduction audit and plan (RRAP) detailed in San Diego Air Pollution Control District (SDAPCD) Rule 1210 (e).

SDAPCD Rule 1210 (e) reads as follows:(1) Except as provided in Subsections (e)(2), (e)(3) and (e)(4), within six months of receipt of written notice from the Air Pollution Control Officer that a stationary source's most recent approved public health risk assessment indicates potential public health risks equal to or greater than one or more of the following significant risk mitigation levels, the owner or operator shall submit to the Air Pollution Control Officer, for review for completeness, a stationary source toxic air contaminant risk reduction audit and plan:

(i) Maximum incremental cancer risks equal to or greater than 100 in one million, or

- (ii) Cancer burden equal to or greater than 1.0, or
- (iii) Total acute noncancer health hazard index equal to or greater than 1.0, or
- (iv) Total chronic noncancer health hazard index equal to or greater than 1.0.

The risk reduction audit and plan shall contain airborne toxic risk reduction measures proposed by the owner or operator which will be sufficient to reduce the stationary source emissions to levels that result in potential public health risks below the significant risk mitigation levels specified above. Such emission reductions shall be accomplished within five years of the date the plan is submitted to the Air Pollution Control Officer.

(5) The risk reduction audit and plan submitted by the owner or operator shall contain all of the following:

(i) The name, location and standard industrial classification (SIC) code of the stationary source.

(ii) The identification of the emission units and toxic air contaminants emitted by each emission unit that contribute to potential public health risks above the significant risk mitigation levels specified in Subsection (e)(1). Emission units shall be listed by decreasing contribution to the total potential public health risks estimated for the stationary source. Toxic air contaminants shall be listed for each emission unit by decreasing contribution to the potential public health risk estimated for that unit.

The plan need not include identification of emission units which emit toxic air contaminants in amounts which the approved public health risk assessment indicates Regulation XII -14-Rule 1210 do not cause maximum incremental cancer risks greater than 1.0 in a million,

nor a total acute noncancer health hazard index of 1.0 or greater, nor a total chronic noncancer health hazard index of 1.0 or greater. The plan shall include identification of all emission units for which the owner or operator proposes to reduce toxic air contaminant emissions as part of the risk reduction audit and plan.

1.2 BACKGROUND INFORMATION

1.2.1 Applicant Name and Address

MM San Diego LLC – Miramar and Miramar Energy 5087 Junction Road Lockport, NY 14094

1.2.2 Facility Address

MM San Diego LLC – Miramar and Miramar Energy 5244 Convoy Street San Diego, CA 92111

1.2.3 Nature of Business

Landfill Gas to Energy

1.2.4 Persons to Contact Regarding Application

Ms. Suparna Chakladar Vice President OPAL Fuels 5087 Junction Road Lockport, NY 14094 (951) 833-4153

Mr. Patrick Sullivan Senior Vice President SCS Engineers 3117 Fite Circle, Suite 108 Sacramento, California 95827 (916) 503-2956

1.2.5 Operation Schedule

24 hours per day 7 days per week 52 weeks per year

1.2.6 Status of Application

This is a modification application for risk reduction activities.

1.2.7 Facility Status

Existing

2.0 PROJECT DESCRIPTION

2.1 EXISTING OPERATION

The MM San Diego Energy LLC LFGTE facility is located at the Miramar Landfill in San Diego, California. The Landfill is owned and operated by the City of San Diego, Environmental Services Department and has been in operation since 1983. The Landfill is equipped with a landfill gas (LFG) collection and control system (GCCS) whereby the Landfill's Central Blower Station sends LFG via conveyance pipeline to the LFGTE Facility, which is comprised of the following:

- Four generators each driven by tandem LFG-fired reciprocating engines, eight engines total (Inventory Devices 1, 2, 3, 4, 5, 6, 7, 8) Caterpillar Engines, each engine rated at 1,138 brake horsepower (bhp)
- Two generators each driven by a single LFG-fired reciprocating engine (Inventory Devices 1632 and 1633) Caterpillar Engines 3520, each engine rated at 2,233 bhp

In addition, at the time of the 2018 inventory and subsequent health risk assessment (HRA), the Facility owned and operated two (2) LFG-fired flares A and B (Inventory Devices 1 and 2). The flares have been returned to the Landfill since January 1, 2019.

Last, the Facility owns and operates one (1) diesel-fired engine driving an emergency generator (Inventory Device 984491) – Caterpillar Diesel Engine rated at 587 bhp. This was also transferred to the Landfill on January 1, 2019.

2.2 REASON FOR PERMITTING ACTION

The Facility received notice from the SDAPCD that the 2018 HRA indicated that public risk was above the significant risk mitigation levels under Rule 1210. This requires the Facility to submit a RRAP within six months. This document will define risk reduction measures that can be implemented into the Facility's air permits for the LFG-fired engines (APCD2006-PTO-950731 and APCD2013-PTO-001632).

3.0 RISK REDUCTION

The 2018 emission inventory included the following emission units that contribute to public health risks above the significant mitigation levels:

- Eight (8) LFG I.C. engines (point source) permitted by PTO No. 950731
- Two (2) LFG I.C. engines (point source) permitted by PTO Nos. 001362/001633

- Two (2) enclosed LFG flares (point source) permitted by PTO No. 950804 that City of San Diego assumed ownership and operation since January 1, 2019
- One (1) diesel-fired engine (point source) that City of San Diego assumed ownership and operation since January 1, 2019

3.1 RISK CONTRIBUTION

According to the 2018 HRA approval, dated March 22, 2022, the LFG-fired engines contribute the most to total health risk at the facility, as seen in **Table 1**.

Source	Worker	Worker 8-Hour	Maximum	
	Chronic	Chronic	Acute	
LFG-fired Engines	100%	100%	100%	

 Table 1.
 Emission Unit Health Risk Contribution

Specific toxic air contaminants (TACs) that contribute the most to overall health risk under each risk condition are available in **Table 2**, including actual and percent contribution.

Table 2.	Specific TAC Health Risk Contribution
----------	---------------------------------------

TAC	Worker Chronic	Worker 8-Hour Chronic	Maximum Acute
Arsenic	31% (0.56)	-	-
Formaldehyde	57% (1.04)	98% (1.04)	99% (20.65)
Hydrogen Chloride (HCl)	11% (0.2)	-	-
Total Risk	1.82	1.06	20.86

By far, the largest contributors to total risk are post-combustion byproducts and a non-volatile metal presumed to being released from the LFG-fired engines. The RRAP is required due to chronic, non-cancer risks in excess of a hazard index (HI) of 1.0. Therefore, sources and TACs contributing to the chronic, non-cancer risk per Tables 1 and 2 will be the focus of this RRAP.

3.2 **RISK REDUCTION EVALUATION**

Tables 1 and 2 above show that the largest contribution to health risk for the Facility are postcombustion byproducts and metals from the LFG-fired engines, specifically arsenic, formaldehyde, and HCI.

3.2.1 Formaldehyde

The industry standard for reducing post-combustion formaldehyde from these types of emission units is by implementing and maintaining an enhanced operation and maintenance (O&M) plan.

The Facility has been following a regimented 0&M plan to reduce this health risk since the 2018 emission inventory year. The LFG-fired engines are serviced as follows:

- 500 hour Service:
 - Oxygen Sensor calibration ensures accurate measurement of exhaust and optimum air/fuel ratio for the engine.
 - Calibrated on the CAT 3516 engines
 - Replaced on the CAT 3520 engines
 - o Inspect/clean spark plugs.
- 1000 hour Service -
 - Calibrate oxygen sensors
 - Perform valve lash and recession readings
 - o Remove and replace spark plugs
 - Replace all air filters
- 6 month Service
 - o Cylinder heads are removed and all buildup cleaned, if any
 - o Software replaced
- Annual Service -

Top End Overhauls includes the following work that impacts efficiency and combustion:

- 1. The following components will be replaced with rebuilt or new components as specified:
 - Cylinder Heads Rebuilt
 - Turbochargers and Turbo Wastegate Rebuilt
 - Gas Regulator and Throttle Plate (if applicable) Rebuilt
 - MAP Sensor New
- 2. Clean and inspect the following components:
 - Complete engine fuel delivery, control and metering components to include rod and ball joints, governor, Woodward E³ System; adjust as needed
 - Intake and Exhaust System including Wastegate Seat and Turbo Manifold
 - Rocker Arms, Valve Bridges, Valve Lifters
- 40,000 hour Service -

In frame overhauls includes the following work that impacts efficiency and combustion:

- 1. The following components will be replaced with rebuilt or new components as specified:
 - Cylinder Heads Rebuilt
 - Turbochargers and Wastegate Rebuilt
 - Gas Regulator and Throttle Plate Rebuilt
 - Woodward E³ Consumables New
 - Engine to Gen Coupling New
 - Cylinder Packs, Main and Rod Bearings New
 - Valvetrain (Rockers, Bridges, Pushrods, etc.) New/Rebuilt
- 2. Clean and inspect the following components:
 - Complete engine fuel delivery, control and metering components to include rod and ball joints, governor, Woodward E³ System; adjust as needed

- Intake and Exhaust System including Wastegate seat and Turbo Manifold
- Valve Lifters
- 80,000 hour Service -

Out of frame overhaul includes the following work that impacts efficiency and combustion:

- 1. The following components will be replaced with rebuilt or new components as specified:
 - Cylinder Heads Remanufactured
 - Turbochargers, Turbo WG/Seat/Body Rebuilt/Remanufactured
 - Gas Regulator and Throttle Plate (if applicable) Rebuilt
 - Woodward E³ consumables (if applicable) New
 - Cylinder Packs, Main and Rod Bearings New
 - Valve Train (rockers, pushrods, adjusters, bridges) Remanufactured/Replace
- 2. Clean and inspect the following components:
 - Complete engine fuel delivery, control and metering components to include rod and ball joints, governor, Woodward E³ System; adjust as needed
 - Intake and Exhaust System

In addition, the Facility believes that the testing method used for formaldehyde emissions may be overestimating the actual emissions from the LFG engines. As used in the South Coast Air Quality Management District (SCAQMD), the California Air Resource Board (CARB) Method 430 may be more accurate for purposes of determining formaldehyde emissions from LFG engines. The emissions from engines tested in the SCAQMD region indicate concentrations on average four times lower than the emissions used by SDAPCD, but as high as thirty-four times lower than the emissions used by SDAPCD. Example testing results from facilities within the SCAQMD can be found in Appendix A.

3.2.2 Arsenic

The SDAPCD based the arsenic emissions for the LFG engines on sampling results for arsine and trimethylarsine from May 4, 2016, June 15, 2016, and February 28, 2017. However, the analysis was not performed using a United Stated Environmental Protection Agency (EPA) or other regulatory agency approved method nor from an accredited laboratory. We do not believe that all arsine and trimethylarsine is converted to arsenic during combustion; therefore, the emissions used for the 2018 HRA may be overstated. This was the case for a landfill facility in the Santa Barbara County Air Pollution Control District (SBCAPCD) where the SBCAPCD assumed arsenic would be emitted in a significant amount but recent stack testing data showed arsenic emissions were non-detect for all three runs. We believe that the arsenic emissions and risk contribution were overestimated in the 2018 emission inventory and HRA. Therefore, the Facility will conduct arsenic testing to verify the actual emissions of arsenic for the LFG engines and update the HRA accordingly. A sampling protocol will be submitted to the SDAPCD for approval prior to testing, as the time to prepare and submit the protocol, receive approval, provide notifications, complete the testing, and receive the report in time for evaluation prior to the RRAP due date was not feasible.

3.2.3 Hydrogen Chloride

The SDAPCD based the HCl emissions from the LFG engines on a default emission factor of 7.43 pounds per million cubic feet (lb/mmscf) burned from the EPA's Compilation of Air Emission Factors (known as AP-42), Section 2.4, Table 2.4-1. The default emission factor assumes that total chloride

is fully converted (100%) to HCI emissions and the individual chlorinated compounds are present at the concentrations listed in AP-42. SCS has seen from testing data that this is not the case, and emissions of HCI are lower than assuming 100% conversion of chlorides. Furthermore, we also know that the AP-42 concentration for chlorinated compounds are overstated. A copy of this documentation can be found in Appendix B. Therefore, the Facility may consider conducting HCI testing to verify the actual emissions of HCI for the LFG engines and update the HRA, if necessary. A sampling protocol will be submitted to the SDAPCD for approval prior to testing. A sampling protocol will be submitted to the SDAPCD for approval prior to testing, as the time to prepare and submit the protocol, receive approval, provide notifications, complete the testing, and receive the report in time for evaluation prior to the RRAP due date was not feasible.

3.3 RISK REDUCTION SCHEDULE

Risk reduction activities (i.e. 0&M Plan) planned for the Facility is expected to reduce the risk to below the significant risk mitigation thresholds. The Facility will conduct a one-time testing for the risk drivers (i.e. arsenic and HCl) and implement the Enhanced O&M plan to achieve better combustion for formaldehyde control. After performing one year of Enhanced O&M and testing for Arsenic and HCl, the Facility will evaluate their O&M plan and RRAP, and adjust as necessary.

3.4 **RISK REDUCTION DEMONSTRATION**

As noted above, the Facility has implemented a robust O&M plan that will create the emission reductions necessary to reduce risk. In addition, actual emissions from the LFG engines will be revised and updated with testing for the risk drivers (i.e. arsenic and if needed, HCl) using the methodologies noted in Section 3.2. The significant risk mitigation levels for the Facility are the following:

- Total acute noncancer health hazard index equal to or greater than 1.0
- Total chronic noncancer health hazard index equal to or greater than 1.0

We believe that enhanced O&M will improve combustion efficiency, which will reduce emissions of formaldehyde and to the arsenic and HCI emissions to a lesser degree. Since we believe that the arsenic and HCI emissions and subsequent risk are overstated, the Facility plans to perform testing and then re-evaluate the health risk.

Table 3 below shows the revised forecast for a future risk assessment within the 5-year timeframefor risk reductions requirements per Rule 1210.

Risk Type	2018 HRA	2026 HRA	Units
Chronic Maximum Worker	1.82	<1	Hazard Index (HI)
Acute Maximum	20.86	<]	Hazard Index (HI)
Chronic Maximum 8- Hour Worker	1.06	<1	Hazard Index (HI)

Table 3.	Proposed HRA	Risk Reduction
TUDIC J.	Troposed they	KISK RECOULION

3.5 PROGRESS REPORTS

Rule 1210(e) requires progress reports to be submitted at least annually under this RRAP. The Facility will provide progress reports as required on an annual basis incorporated into the toxic air contaminant emission inventory report. This report will detail actions taken by the Facility to reduce TAC emissions and the estimated public health risk reduction achieved, as supported by annual testing.

4.0 APPLICATION FORM AND FEE

The General Permit or Registration Application Form can be found in Appendix C. Enclosed with the application are fees in the amount of \$7,870. The fee estimate provided by the SDAPCD can be found in Appendix D.

5.0 CONCLUSION

The Facility has included all required information from Rule 1210(e) regarding the RRAP. The risk reduction activities detailed in this permit modification application serve to update the current permit and show that the Facility is taking all necessary steps to reduce health risk.

Appendix A

SCAQMD Formaldehyde Testing Results



6.0 TEST RESULTS SUMMARY

Emissions Compliance Data Summary

E1 Engine Stack Outlet

Sylmar, California

September 30, 2021

Parameter	Run 1 Min Load	Run 2 Mid Load	Run 3 Full Load	Emission Limits
Охуgen (O₂)	•			
%	10.11	10.16	10.11	
Carbon Dioxide (CO ₂)	·			
%	9.94	9.81	9.82	
Nitrogen Oxide (NO _x as NO ₂)	·			·
ppmvd	13.5	16.62	14.6	
ppmvd @ 15% O ₂	7.40	9.13	7.96	11
lb/day	19.5	25.5	24.2	34
Carbon Monoxide (CO)				
ppmvd	391	389	396	
ppmvd @ 15% O ₂	214	214	217	250
lb/day	341	364	401	459
ROG, NMOC, & Methane ¹	·			•
NMOC as Carbon, ppmvd			16.4	
ppmvd @ 15% O2, as Carbon			9.01	30
lb/day, as Carbon			6.45	31
ppmvd @ 3% O ₂ (as Hexane)			4.56	20
methane @ 15% O ₂			1,649	3,000
Particulate (PM)	·			•
mg			8.40	
gr/dscf			0.0020	gr/scf @8,829 dscfm flow rate
lb/day			3.6	24
Stack Flow Data (Measured Volumetric Flo	w)			
dscfm			8,508	
Moisture Fraction				
%			0.099	

¹ The ROC, NMOC, & Methane was taken during RATA runs six thru seven RATA.



Fuel Gas Data Summary E1 Engine Landfill Gas Inlet Sylmar, California September 30, 2021

Parameter ¹	Run 1 Low Load	Run 2 Mid Load	Run 3 Full Load	Emission Limits		
xhaust Data						
Stack Flow Rate, dscfm (Fuel Based Calculation)	8,356	8,938	9,672			
Fuel Data						
fuel flow, ft³/hr	56,373	60,019	68,282			
F-Factor _{dry}	9,525	9,525	9,525			
Fuel Gas Calorific Values	uel Gas Calorific Values					
GCV, BTU/lb	6,458	6,458	6,458			
GCV, BTU/ft ₃	482	482	482			
Heat Input						
MMBtu/hr (average)	27.17	28.93	31.47			
Fuel Sulfur / Sulfur Dioxide (SO _x as SO ₂)	uel Sulfur / Sulfur Dioxide (SO _x as SO ₂)					
H₂S in Fuel, ppmv			4.62	150		
lb/day			1.20	27		

¹ The landfill gas sample was taken during RATA runs six thru seven.

Ammonia Emissions Compliance Data Summary E1 Engine Stack Outlet Sylmar, California September 30, 2021

Parameter	Run 1	Run 2	Average	Emission Limits		
Ammonia (NH₃)						
ppmvd	0.12	0.29	0.20			
ppmvd @ 15% O ₂	0.07	0.16	0.11	10		



CARB 430 Emissions Data Summary E1 Engine Stack Outlet Sylmar, California September 30, 2021

Parameter	Run 1	Run 2	Run 3	Average	Emission Limits		
Oxygen (O ₂)							
%	10.17	10.21	10.18	10.19			
Formaldehyde	ormaldehyde						
ppmvd	0.25	0.31	0.40	0.32			
ppmvd @ 15% O ₂	0.14	0.17	0.22	0.17			
Acetaldehyde	Acetaldehyde						
ppmvd	3.28E-03	3.75E-03	3.28E-03	3.43E-03			
ppmvd @ 15% O ₂	1.80E-03	2.07E-03	1.80E-03	1.89E-03			

SCAQMD Rule 218.1 Facility CEMS Relative Accuracy E1 Engine Stack Outlet Sylmar, California September 30, 2021

	Emission	Reference	CEMS	Rela	tive Accur	асу	A	Performance
Parameter	Standard		Mean	RM %	AES %	APS	Acceptance Criteria	Specifications Number (Rule 218.1)
Oxygen (O ₂)								
%		10.16	10.01	1.70			≤ 20% RM	3
Nitrogen Oxide (NO _x)	Nitrogen Oxide (NO _x)							
ppmvd		11.40	10.42	11.59			≤ 20% RM	2
ppmvd @ 15% O ₂		6.28	5.65	13.24			≤ 20% RM	2

RM = Reference Method

APS = Alternative Performance Specification

AES = Applicable Emissions Standard

1.1 SUMMARY OF RESULTS

Facility:	Prima Deshecha
Source:	ICE #1
Load:	Normal
Date:	6/2/2022

Parameter	Units	Full	Limits	Pass/ Fail
Engine Load		Load		
Outlet ROCs [Duplicate Average]				
NMOC, as methane	ppmv	25.85		
NMOC @ 15% O ₂	ppmv	14.18	40	Pass
NMOC, as hexane	ppmv	4.31		
NMOC, as hexane @ 3% O ₂	ppmv	7.17	20	Pass
Emission Rate	lb/hr	0.62		
Emission Rate	lb/day	14.90	46	Pass
Emission Rate	Ib/MMBTU	0.020		
Emission Rate	g/bhp-hr	0.066		
Inlet ROCs				
NMOC, as methane	ppmv	3893		
Emission Rate	lb/hr	10.17		
Outlet Methane				
Methane	ppmv	1379.5		
Methane @ 15% O2	ppmv	759.80	3000	Pass
Emission Rate	lb/hr	33.13		
Inlet Methane				
Methane	ppmv	482,447		
Emission Rate	lb/hr	1,285.3		
Aldehydes [Triplicate Average]				
Formaldehyde	ppmv	1.382		
Emission Rate	lb/hr	0.062		
Acetaldehyde	ppmv	0.056		
Emission Rate	lb/hr	0.0037		
Inlet Sulfur	ppmv	90.86		
Emission Rate	lb/hr	0.514		
Outlet Sulfur	ppmv	5.35		
Emission Rate	lb/day	12.345	27	Pass
Particulate Matter	gr/dscf	0.0014		
Emission Rate	lb/hr	0.11		
Emission Rate	lb/day	2.69	113	Pass
Emission Rate	g/bhp-hr	0.012		
0 ₂	%	10.15	-	
CO ₂	%	10.03	-	
Fuel Usage	SCFM	1,051.9	-	
Heat Input	MMBtu/hr	30.80	35	Pass
Load Generated, avg	KW	3,032	-	
BHP, Rated	Bhp	4,235	-	
Flow, Calculated	dscfm	9,482	-	

Facility:	Prima Deshecha
Source:	ICE #2
Load:	Normal
Date:	6/3/2022

1.1 SUMMARY OF RESULTS

Parameter	Units	Full	Limits	Pass/ Fail
Engine Load		Load		
Outlet ROCs [Duplicate Average]				
NMOC, as methane	ppmv	28.90	-	
NMOC @ 15% O ₂	ppmv	15.65	40	Pass
NMOC, as hexane	ppmv	4.82	-	
NMOC, as hexane @ 3% O ₂	ppmv	7.91	20	Pass
Emission Rate	lb/hr	0.64		
Emission Rate	lb/day	15.40	46	Pass
Emission Rate	lb/Mmbtu	0.020		
Emission Rate	g/bhp-hr	0.069	-	
Inlet ROCs				
NMOC, as methane	ppmv	3299	-	
Emission Rate	lb/hr	8.71	-	
Outlet Methane				
Methane	ppmv	1313.50	-	
Methane @ 15% O ₂	ppmv	714.11	3000	Pass
Emission Rate	lb/hr	32.76	-	
Inlet Methane				
Methane	ppmv	504,623	-	
Emission Rate	lb/hr	1,359.14	-	
Aldehydes [Triplicate Average]				
Formaldehyde	ppmv	9.350	-	
Emission Rate	lb/hr	0.389	-	
Acetaldehyde	ppmv	0.210	-	
Emission Rate	lb/hr	0.0129	-	
Inlet Sulfur	ppmv	102.45		
Emission Rate	lb/hr	0.59		
Outlet Sulfur	ppmv	5.88		
Emission Rate	lb/day	14.07	27	
Particulate Matter	gr/dscf	0.0017		
Emission Rate	lb/hr	0.13		
Emission Rate	lb/day	3.05	113	Pass
Emission Rate	g/bhp-hr	0.014		
02	%	10.01	-	
CO ₂	%	10.21	-	
Fuel Usage	SCFM	1,063.4	-	
Heat Input	MMBtu/hr	32.54	35	Pass
Load Generated, avg	KW	3,050	-	
BHP, Rated	Bhp	4,235	-	
Flow, Calculated	dscfm	9,846	-	

Appendix B

HCI Study for EPA

September 1, 2022 Project 796949

Mr. Roy Huntley Emission Factor And Inventory Group (MD-14) Office of Air Quality Planning and Standards U. S. Environmental Protection Agency Research Triangle Park, NC 27711

Re: Submission of Hydrogen Chloride Test Data from Landfill Gas Fired Combustion Devices

Dear Mr. Huntley:

As discussed in a meeting with you in June and October 1999, the Waste Industry Air Coalition (WIAC) has compiled and reviewed 19 stack-test reports to develop an emission factor for hydrogen chloride (HCl) from landfill gas-fired devices, specifically flares. This review focused on two main items: 1) validity of the stack test methods used, and 2) a review of the HCl concentrations to determine if the stack tests would indeed prove that HCl concentrations are overstated based on methodologies presented in the EPA AP-42, Section 2.4.

Stack Test Methods

There are four stack-test methods used in the enclosed stack-test reports: 1) EPA Method 26, 2) EPA Method 0050, 3) South Coast Air Quality Management District (SCAQMD) Method 5/California Air Resources Board (CARB) Method 421, and 4) Method referenced as EPA 600-325.3. EPA Method 26 is an approved stack-test method for HCl; if the test is conducted consistent with EPA protocol, the results are technically valid and useable. EPA Method 0050 is referenced from *Measurement of HCl and Cl₂ (EPA Methods Manual for Compliance with BIF Regulations, EPA/530-SW-91-010, December 1990)*. The BIF Regulations are EPA regulations for the treatment of hazardous waste in boilers, furnaces and other thermal treatments. The final two methods appear to have relatively similar preparation, sampling and analytical methodologies as EPA Method 26 and would be appropriate for use in this comparison.

Mr. Roy Huntley September 1, 2022 Page 2

Review of Hydrogen Chloride Concentrations

AP-42 Section 2.4 has a table of compounds typically found in landfill gas—some of these compounds are chlorinated. The methodology used to determine the HCl concentration in the outlet of a landfill gas-fired device is to *assume* that the device oxidizes at least 98 percent of the chlorinated compound during combustion and converts the free chlorine atoms into HCl (i.e., mass balance). Additionally, AP-42 provides a calculation methodology that assumes a default concentration for total chloride (Ccl) of 42.0 ppmv. In AP-42, page 2.4-9 it states that "This value was derived from the default LFG constituent concentrations presented in Table 2.4-1". The use of this methodology and the derivation of the default concentration is very confusing and potentially not technically correct. Because of this confusion, the use a a default HCL outlet concentration based on the attached stack tests would greatly simplify the derivation of HCl emissions.

The stack-test results reviewed show a much lower and more reasonable concentration of HCl than using the methods described in AP-42. According to the reports, the maximum tested HCl concentration is 55.53 ppmv, an average maximum concentration of 12.68 ppmv, and an average average concentration of 9.43 ppmv (see summary attached). If you have any questions about the above information or attachments, please call me at (978) 682-1980.

Sincerely,

EMCON

Edwin P. Valis, Jr. Project Manager

Attachments: Summary of Hydrogen Chloride Concentrations Stack Test Reports

cc: Mike Michels – SWANA w/o Attachments Michele Laur - EPA Susan Thornloe - EPA Ed Repa – EIA w/o Attachments The emission test results are summarized in Tables 2 through 4. Detailed emission calculations are presented in Appendix IV.

Run	One	Two	Three	Average		
Date	7/19/05	7/19/05	7/20/05			
Time	0950-1255	1345-1530	0645-0814			
Front Half PM						
Grains/dscf	0.0041	0.0044	0.0011	0.0032		
Pounds/mmBtu	0.0174	0.0178	0.0053	0.0135		
Pounds/hour	0.253	0.239	0.076	0.189		
	Condens	able Organic PM				
Grains/dscf	ND < 0.0001	0.0014	ND < 0.0001	0.0005		
Pounds/mmBtu	ND < 0.0001	0.0058	ND < 0.0001	0.0019		
Pounds/hour	ND < 0.0001	0.0776	ND < 0.0001	0.0259		
	Condensa	ble Inorganic PM	[
Grains/dscf	0.0021	0.0055	0.0022	0.0033		
Pounds/mmBtu	0.0087	0.0225	0.0107	0.0140		
Pounds/hour	0.1255	0.3009	0.1537	0.1934		
	Total C	ondensable PM				
Grains/dscf	0.0021	0.0069	0.0022	0.0037		
Pounds/mmBtu	0.0087	0.0283	0.0107	0.0159		
Pounds/hour	0.1255	0.3785	0.1537	0.2193		
	Total PM (F	ront and Back Ha	ulf)			
Grains/dscf	0.0062	0.0113	0.0033	0.0069		
Pounds/mmBtu	0.0261	0.0462	0.0160	0.0294		
Pounds/hour	0.3785	0.6175	0.2297	0.4086		
Grains/dscf=grains per dry standard cubic feetPounds/MMBtu=pounds per million British thermal unitsPounds/hour=pounds per hour						

TABLE 2 -	- SUMMARY OF	TOTAL PARTICU	LATE MATTER EMISS	SIONS



7

Run	1	2	3	Average
Date	7/19/05	7/19/05	7/20/05	
Time	0950-1255	1345-1530	0645-0814	
	Carbon M	onoxide		
ppmv, dry	<1.0	<1.0	<1.0	<1.0
ppmv, dry @ 7% O ₂	<2.0	<1.9	<2.3	. <2.1
pounds/hour	< 0.031	<0.028	< 0.036	< 0.031
pounds/MMBtu	< 0.0022	< 0.0021	< 0.0025	< 0.0022
	Nitrogen Oxi	des as NO ₂		
ppmv, dry	13.7	13.8	10.7	12.7
ppmv, dry @ 7% O ₂	27.4	26.5	24.9	26.3
pounds/hour	0.70	0.63	0.63	0.65
pounds/MMBtu	0.048	0.047	0.044	0.047
	Sulfur D	ioxide		
ppmv, dry	<1.0	1.4	1.0	<1.1
ppmv, dry @ 7% O ₂	<2.0	2.7	2.2	<2.3
pounds/hour	< 0.071	0.087	0.078	< 0.078
pounds/MMBtu	<0.0049	0.0065	0.0055	< 0.0056
Total Not	n-methane Hydr	ocarbons (as M	lethane)	
ppmv, dry	<1.1	<1.1	1.3	<1.1
ppmv, dry @ 7% O ₂	<2.4	<2.4	2.6	<2.5
pounds/hour	< 0.022	< 0.023	0.024	< 0.023
pounds/MMBtu	< 0.0015	< 0.0015	0.0016	< 0.0015
ann an	Destruction	Efficiency	anten en e	
Percent (%)	>99.4	>99.6	99.6	>99.6
ppmv, dry=parts per million by volume, dry basisppmv, dry @ 7% O2=parts per million by volume, dry basis corrected to 7% oxygepounds/hour=pounds per hour				

TABLE 3- SUMMARY OF CO, NO_x, SO₂ AND VOC EMISSIONS

pounds per million British thermal units

pounds/MMBtu

=



TABLE 4-SUMMARY OF HYDROGEN CHLORIDE EMISSIONS

Run	1	2	3	Average
Date	7/20/05	7/20/05	7/20/05	
Time	0935-1035	1207-1307	1400-1500	
ppmv, dry	0.55	0.63	0.71	0.63
ppmv, dry @ 7% O ₂	1.2	1.4	1.4	1.4
pounds/hour	0.025	0.030	0.029	0.028
ppmv, dry	= par	ts per million by volu	ume, dry basis	

ppmv, dry

parts per million by volume, dry basis

ppmv, dry @ 7% O₂ pounds/hour

-

parts per million by volume, dry basis corrected to 7% oxygen pounds per hour

TABLE 1. HYDROCHLORIC ACID EMISSIONS LOPEZ CANYON LANDFILL LOS ANGELES, CALIFORNIA

A	В	С	D	E
		Rep. Conc. of Compounds	Maximum Uncontrolled	Maximum Uncontrolled
	Molecular	Found in	LFG	LFG
	Weight	LFG	Emissions	Emissions
COMPOUNDS	(g/Mol)	(ppmv)	(lb/hr)	(tons/yr)
Hydrochloric acid (AP-42)	36 50	27 639	0.163	0.712
Hydrochloric acid (source test)	NA	NA	0.21	0.920

INPUT MODEL VARIABLES

Landfill Gas Flow to Flare Estimated methane content of LFG 1010 cfm 50% Appendix C

General Permit Application Form

Internal Use Only					
APP ID: APCD	-APP/CER-				
SITE ID: APCD	-SITE-				



Submittal of this application does not grant perm	ission to constru	ct or to operate equipment e	xcept as specified in Rule 24(c).
REASON FOR SUBMITTAL OF APPLICATIO	N:		
Amendment to Existing Authority to		ng Unpermitted Equipment Change e of Equipment Location	 Modification of Existing Permitted Equipment Change of Equipment Ownership (please provide proof of ownership)
Change of Permit Conditions	Change Permit to Operate Status to Inactive		<u> </u>
			Banking Emissions
Registration of Portable Equipment Other (Specify)			
List affected APP/PTO Record ID(s): <u>APCD20</u>	06-PTO-950731	APCD	02013-PTO-001632
APPLICANT INFORMATION Name of Business (DBA) <u>MM San Diego LLC – Mi</u> Does this organization own or operate any other APO If yes, list assigned Site Record IDs listed on your Po Name of Legal Owner (if different from DBA)	CD permitted equi	<u>ar Energy</u> ipment at this or any other adja	acent locations? □Yes ⊠No
Equipment Owner		Authority t	o Construct Mailing Address
Name: MM San Diego LLC – Miramar and Miramar E	nergy		C – Miramar and Miramar Energy
Mailing Address: 5087 Junction Road		Mailing Address: 5244 Cor	
City: Lockport State: NY	Zip: 14094	City: San Diego	State: CA Zip: 92111
Phone: (951) 833-4153		Phone: (951) 833-4153	
E-Mail Address: schakladar@opalfuels.com		E-Mail Address: schaklada	r@opalfuels.com
Permit To Operate Mailing Ad	dress		oice Mailing Address
Name: MM San Diego LLC - Miramar and Miramar En		Name: Same as Equipment	
Mailing Address: 5244 Convoy Street		Mailing Address:	
City: San Diego State: CA	Zip: 92111	City:	State: Zip:
Phone: (951) 833-4153		Phone: ()	
E-Mail Address: schakladar@opalfuels.com		E-Mail Address:	
EQUIPMENT/PROCESS INFORMATION: Typ equipment storage address. If portable, will opera Equipment Location Address <u>5244 Convoy Street</u> State: <u>CA</u> Parcel NoZip 92111	tion exceed 12 co	onsecutive months at the sam	ne location Yes No / <u>San Diego</u>
Site Contact Suparna Chakladar		1) 055-4155 E-mail:	Schakladar@opalfuels.com Phone (951) 833-4153
General Description of Equipment/Process Landfill C	ias to Energy		- HORE (231) 033-4133
		or 🛛 Consultant Affiliation	SCS Engineers
EXPEDITED APPLICATION PROCESSING: a) Expedited processing will incur additional fees and perm Expedited processing is contingent on the availability of qu processing does not guarantee action by any specific date n	I hereby requ	test Expedited Application P ed until the additional fees are pai	Processing and understand that:
	ication is	true and correct.	0/40/00
Frint Name Anthony Falbo		Date	9/16/22
Phone (716) 713-4135			MM San Diego LLC
1210/ 110-1100		E-mail /	Address afalbo@opalfuels.com

10124 Old Grove Rd. – San Diego - California 92131-1649 – (858) 586-2600 www.sdaped.org
 Internal Use Only

 APP ID: APCD
 -APP/CER

 SITE ID: APCD
 -SITE

GENERAL PERMIT OR REGISTRATION APPLICATION FORM



Appendix D

SDAPCD Fee Estimate

SAN DIEGO COUNTY AIR POLLUTION CONTROL DISTRICT APPLICATION FEE ESTIMATE

Applicant Site ID/EIF ID:	APCD1996-SITE-09778	Enter PTO/TVP for Modifications				
Applicant DBA:	Minnesota Methane LLC San Diego Faciliy	Fee Schedule:		91A		
	Jim Swaney		-	Risk Reduction		
		Existing Site? Estimate Date:		Yes 8/17/2022		
APCD Engineer:						
Equipment Description:	Risk Reduction Plan for 2018 HRA					
	EMPLOYEE	LABOR				
ACTIVITY	CLASSIFICATION	HOURS	COST	SUBTOTAL		
Initial Evaluation Fee - T&M (R	ule 40(d)(3)(i))					
Authority to Construct	Engineering Services	20.0	\$4,760.00	ETM		
Permit to Operate	Engineering Services	2.0	\$476.00	\$5,236.00 ETM		
T&M Application - No Fixed Fe	e see ahove					
T&M Application - No Fixed Fee, see above Authority to Construct/Permit to Operate		N/A	T+M	\$0.00 ETM		
		•				
Additional Evaluation and Proc New Source Review	Engineering Services	1	\$0.00	\$0.00 NSR		
	Monitoring Services		\$0.00	\$0.00 AQI		
Prev. Significant Deterioration	Engineering Services		\$0.00	\$0.00 PSD		
Toxics New Source Review	Engineering Services		\$0.00			
(Health Risk Assessment)	Monitoring Services		\$0.00			
	HRA Base Estimate	Standard	\$2,536.00	\$2,536.00 TNS		
Tile V	Engineering Services		\$0.00	\$0.00 TIV		
NESHAPS/ATCM/NSPS	Engineering Services		\$0.00	\$0.00 HAP		
CEQA	Engineering Services		\$0.00	\$0.00 CEQ		
AB 3205 Notice	Engineering Services		\$0.00			
	Public Notice Costs		\$0.00	\$0.00 AB3		
Equipment subject to Rule 11(a)(3) Engineering Services			\$0.00	\$0.00 R51		
H&SC 42301(e)	Engineering Services		\$0.00	\$0.00 HSC		
Testing or Test Witness	Engineering Services		\$0.00	STF		
	Source Testing Services		\$0.00	ad-hoo		
Fixed Test Fee Sched.	NA Fixed Testing Fees		\$0.00	\$0.00 ad-hoo		

Miscellaneous Fees

Processing Fee (Rule 40(d)(1)(ii))	1.0	\$98	\$98.00	EFX
Renewal Fee (Rule 40(e)(2)(ii))	N/A	N/A	\$0.00	REN
Emissions Fee (Rule 40(e)(2)(iv))		N/A	\$0.00	EMF

NOTES:

ESTIMATE TOTAL: \$7,870.00

(1) To avoid possible processing delays, this document should be submitted with your application forms.

(2) The fees contained in this estimate are are based on APCD Rule 40. Final fee may be more or less than this estimate (see Rule 40(d)(1)(iii)).

(3) Emissions determined to be greater than 5 tons per year will be charged a emission fee on a ton per year basis. (see Rule 40 (e)(2)(iv)(A))

(4) Fees paid by credit card will be assessed a 2.19% processing fee (see Rule 40(c)(5))

(5) Federal government payments made through DFAS: Please reference the above liste Site ID Record number in your DFAS submittal.

(6) This estimate is valid only for applications received by the District by June 30, 2023