
San Diego County Air Pollution Control District

10124 Old Grove Rd
San Diego, CA 92131-1649
(858) 586-2600

**TITLE V OPERATING PERMIT
APCD2007-TVP-978119**

Issued To:

Chula Vista Energy Center LLC
Site ID # APCD2000-SITE-03752

Site Address:

Street Address
3497 Main Street,
Chula Vista, CA. 91911
(559) 352-1441

Mailing Address

650 Bercut Drive, Suite C
Sacramento, CA, 95811

Responsible Official – Paul Z. Cummins

Facility Contact – Stephen Cobbe

Permit Information Contact – Stephen Cobbe

Issued by the San Diego County Air Pollution Control District on _____.

This Title V Operating Permit expires on _____.

Signed By: _____

Mohsen Nazemi, MS, PE.
Chief, Engineering Division

San Diego County Air Pollution Control District

Date: _____

TABLE OF CONTENTS

	PAGE
PREAMBLE	1
SECTION I. REGULATION XIV PERMIT REQUIREMENTS	2
A. ADMINISTRATIVE PERMIT TERMS	2
B. RENEWAL REQUIREMENTS AND TERMS	2
C. MONITORING, RECORDKEEPING & REPORTING REQUIREMENTS	3
D. GENERAL PERMIT REQUIREMENTS	4
SECTION II. FACILITY-WIDE REQUIREMENTS	5
A. GENERAL PERMIT PROGRAM APPLICABLE REQUIREMENTS	5
B. FACILITY-WIDE/OTHER PROHIBITORY & MISC. REQUIREMENTS	5
C. PERMIT SHIELDS	6
D. ADDITIONAL TERMS	6
E. TITLE IV PERMIT (ACID RAIN)	6
SECTION III. EMISSION UNIT REQUIREMENTS	7
A. DISTRICT PERMITTED EMISSION UNITS	7
B. REGISTERED AND LEASED EMISSION UNITS	7
C. INSIGNIFICANT EMISSION UNITS AND ACTIVITIES	7
SECTION IV. VARIANCE PROCEDURES	8
SECTION V. APPENDICES	A-1
A. DISTRICT PERMITS AND REGISTERED UNITS	A-1
B. RULE REFERENCE TABLE	B-1
C. ABBREVIATIONS	C-1

PREAMBLE

This Title V Operating Permit consists of this document and all appendices, including District permits incorporated by reference. The facility is subject to all applicable requirements identified within this permit, unless a specific permit shield is specified within this permit. If an applicable requirement is omitted from this permit, the facility is still obligated to comply with such an applicable requirement. The permittee must comply with all of the terms listed in each section of this permit.

This permit contains five major sections: Section I contains the Regulation XIV requirements required to carry out the Title V Operating Permit program. Section II contains the requirements that are applicable to the facility on a facility-wide basis. Section III contains the requirements that are applicable to individual emission units which have been issued District permits or District registration, or which have been determined to be insignificant emission units. Section IV contains terms and requirements pertaining to variance procedures and compliance schedules, if applicable to the facility. Section V contains three appendices. Appendix A contains all the District permits incorporated within this permit. Appendix B contains a table of all SIP approved and District approved rules. Appendix C contains a list of abbreviations used within this permit.

Copies of the Rules and Regulations of the Air Pollution Control District of San Diego County and the Rules and Regulations for San Diego County contained in the State Implementation Plan (SIP) approved by EPA may be obtained at the District. Copies are also available for review at the following locations:

SD Air Pollution Control District (Library & Public Review Area)	County of SD Law Library (Downtown)	County of SD Law Library (North County)
10124 Old Grove Rd	1105 Front St.	325 S. Melrose Suite 300
San Diego, CA 92131-1649	San Diego, CA 92101	Vista, CA 92083
(858) 586-2600	(619) 531-3900	(760) 940-4386

The current Rules and Regulations of the Air Pollution Control District of San Diego County may also be viewed and downloaded using the following internet address:

www.sdapcd.org

The following addresses should be used to submit any certifications, reports or other information required by this permit:

SD Air Pollution Control District Compliance Division 10124 Old Grove Rd San Diego, CA 92131-1649	USEPA Region IX Director of the Air Division Attn: Air-3 75 Hawthorne Street San Francisco, CA 94105
--	---

SECTION I. REGULATION XIV PERMIT REQUIREMENTS

A. ADMINISTRATIVE PERMIT TERMS

1. This Title V Operating Permit expires 5 years from date of issuance. [Rule 1410]
2. Commencing or continuing operation under this permit to operate shall be deemed acceptance of all terms and conditions specified within this permit. This does not limit the right of the applicant to seek judicial review or seek federal EPA review of a permit term or condition. [Rule 1421]
3. This permit may be modified, revoked, reopened and reissued, or terminated by the District for cause. [Rule 1421]
4. The filing of a request by the facility for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay the applicability of any permit condition. [Rule 1421]
5. This permit does not convey any property rights of any sort, or any exclusive privilege. [Rule 1421]
6. The need for the permittee to halt or reduce a permitted activity in order to maintain compliance with any term or condition of this permit shall not be a defense for any enforcement action brought as a result of a violation of any such term or condition. [Rule 1421]
7. In the event of challenge to any portion of this permit, the rest of the permit remains valid. [Rule 1421]
8. For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any applicable requirement in this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed. [Rule 1421]

B. RENEWAL REQUIREMENTS AND TERMS

1. The permittee shall submit a complete application for renewal of this permit to the Air Pollution Control Officer at least 12 months, but not more than 18 months, prior to permit expiration. [Rule 1410]
2. If an administratively complete application for renewal of this permit has been submitted to the Air Pollution Control Officer within the timeframe specified in Section I.B.1., the terms and conditions of this permit shall remain in effect and the source may continue operations under these terms and conditions until the Air Pollution Control Officer issues or denies the permit renewal. [Rule 1410]

C. MONITORING, RECORDKEEPING & REPORTING REQUIREMENTS

1. The permittee shall provide the District access to the facility and all equipment subject to this permit, and access to all required records pursuant to California Health and Safety Code Section 41510. [Rule 1421]
2. The permittee shall maintain all records required by this permit including any calibration, maintenance, and other supporting information and copies of all reports required by this permit for at least five (5) years from their date of creation. Such records shall be maintained on-site for a minimum of three years. This requirement controls and supersedes any other record retention requirement under this permit as it pertains to, and is required by, District Rule 1421 and Title V of the Clean Air Act. [Rule 1421]
3. Records required by this permit shall be considered as being maintained "on-site" if records for the previous 12-month period are available at the stationary source and any additional records are maintained at a location to be specified by the source and made readily available to the District upon request. [Rule 21]
4. The permittee shall submit monitoring and recordkeeping summary reports and all other monitoring and recordkeeping reports required by this permit to the District every six months, unless a shorter time frame is required by a specific permit condition contained in Section III of this permit. Unless other dates are specified in Section III, reports for data required to be collected from January 1 through June 30, shall be submitted no later than September 1 of the calendar year, and reports for data required to be collected from July 1 through December 31, shall be submitted no later than March 1 of the following calendar year. The report for the final six months of the year may be consolidated with the annual compliance certification required below. All instances of noncompliance from federally enforceable applicable requirements shall be clearly identified in these reports. (Timely completion of District Certification Reports Form 1401-J1 and Form 1401-J2, if applicable, and all indicated attachments, fulfills the requirements of this condition.) [Rule 1421]
5. Each calendar year, the permittee shall submit to the District and to the federal EPA an annual compliance certification, in a manner and form approved in writing by the District, for the previous calendar year that includes the identification of each applicable term or condition of the final permit for which the compliance status is being certified, the compliance status and whether the facility was in continuous or intermittent compliance during the previous calendar year, identification of the method used to determine compliance during the previous calendar year, and any other information required by the District to determine the compliance status. The annual compliance certification for a calendar year shall be submitted no later than March 1 of the following calendar year and may be consolidated with the monitoring and recordkeeping report for the last six months of the year for which compliance is certified. (Timely completion of District Certification Reports Form 1401-J1 and Form 1401-J2, if applicable, and all indicated attachments, fulfills the requirements of this condition.) [Rule 1421]
6. Any report submitted to the District or federal EPA pursuant to this permit to comply with a federally enforceable applicable requirement, shall be certified by a responsible

official stating that, based on information and belief formed after reasonable inquiry, the report is true, accurate and complete. [Rule 1421]

7. The permittee shall make any trade secret designations of records, documents, or other information submitted to the District or federal EPA in accordance with District Rule 176. [Rule 176]
8. The permittee shall report all deviations from any and all federally enforceable permit terms and conditions including: (a) breakdowns, whether or not they result in excess emissions, (b) deviations that result in excess emissions of any regulated air pollutant, and (c) deviations from monitoring, recordkeeping, reporting and other administrative requirements that do not result in excess emissions. For deviations that result from breakdowns under District Rule 98, the permittee shall report the breakdown within two hours of detection of the breakdown and provide a follow-up written report after corrective actions have been taken. For deviations not due to a breakdown but which result in excess emissions, the permittee shall report the deviation within ten calendar days of detection. For all other deviations where no specific time frame for reporting a deviation applies, the permittee shall report the deviation at the time of the next semi-annual monitoring summary or annual compliance certification, whichever occurs first. If an underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, then the criteria for the applicable requirement shall apply. The report must include the probable cause of such deviations and any corrective actions or preventive measures taken. [Rule 1421]

D. GENERAL PERMIT REQUIREMENTS

1. The permittee shall comply with all terms and conditions of this permit. This permit consists of this document and Appendices A, B and C. Any noncompliance with the federally applicable terms and conditions of this permit shall constitute a violation of the federal Clean Air Act. Noncompliance with any federally applicable permit term or condition of this permit is grounds for federal enforcement action or enforcement action by the District; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. Noncompliance with any District permit term or condition is grounds for enforcement action by the District. [Rule 1421]
2. Upon a written request by the District, the permittee shall furnish to the District any information needed to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit; any information required to determine compliance with this permit; or any records required to be maintained pursuant to this permit. Such information shall be provided within a reasonable time, as specified within the District's written request. [Rule 1421]
3. The permittee shall pay annual fees in accordance with District Rule 40. [Rule 1421]
4. The permittee shall provide access, facilities, utilities and any necessary safety equipment for source testing and inspection upon request from the District. [Rule 19]
5. This permit shall be maintained on-site at all times and be made available to the District upon request. [Rule 1410]

6. The Rule Reference Table provided in Appendix B shall be used to determine whether a cited rule is a federally and District enforceable requirement or a District only enforceable requirement. Any new or revised District rule shall not be considered federally enforceable until the rule is approved by EPA into the SIP. In cases where SIP approval is pending for a revised District rule, the rule citation shall refer to both the current SIP approved rule and the revised District rule. [Rule 1421]

SECTION II. FACILITY-WIDE REQUIREMENTS

A. GENERAL PERMIT PROGRAM APPLICABLE REQUIREMENTS

The permittee shall comply with the applicable requirements specified in the Rules and Regulations cited below, unless specifically exempted by the same Rule or Regulation.

Regulation	Rule Citation	Title
SDCAPCD Reg. II	10	Authority to Construct Required
SDCAPCD Reg. II	19	Provision of Sampling & Testing Facilities
SDCAPCD Reg. II	19.3	Emission Information
SDCAPCD Reg. II	20 20.1, 20.2, 20.3	New Source Review (NSR)
SDCAPCD Reg. II	21	Permit Conditions
SDCAPCD Reg. II	24	Temporary Permit to Operate
SDCAPCD Reg. II	25	Appeals
SDCAPCD Reg. IV	60	Circumvention
SDCAPCD Reg. IV	71	Abrasive Blasting
SDCAPCD Reg. V	98	Breakdown Conditions: Emergency Variance
SDCAPCD Reg. VI	101	Burning Control
SDCAPCD Reg. VIII	131	Stationary Source Curtailment Plan
40 CFR Part 68	Part 68	Risk Management Plan (Ammonia Storage)
40 CFR Part 82	Subpart B	Servicing of Motor Vehicle Air Conditioners
40 CFR Part 82	Subpart F	Recycling and Emission Reducing
40 CFR Part 89	Part 89	VOC Standards for Consumer Products

B. FACILITY-WIDE/OTHER PROHIBITORY & MISC. REQUIREMENTS

The permittee shall comply with the generally applicable requirements specified in the Rules and Regulations cited below, unless specifically exempted by the same Rule or Regulation. These generally applicable requirements apply on a facility-wide basis to all permitted equipment, registered equipment, and insignificant activities. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more permitted emission units, the requirement is also included in Section III.A. of this permit.

Regulation	Rule Citation	Regulation
SDCAPCD Reg. II	19.2	Continuous Emission Monitoring Systems
SDCAPCD Reg. IV	50	Visible Emissions
SDCAPCD Reg. IV	51	Nuisance
SDCAPCD Reg. IV	52	Particulate Matter
SDCAPCD Reg. IV	53	Specific Contaminants
SDCAPCD Reg. IV	62	Sulfur Content of Fuels
SDCAPCD Reg. IV	67.0.1	Architectural Coatings
SDCAPCD Reg. IV	67.17	Storage of Organic Materials Containing VOC
SDCAPCD Reg. XII	1200	Toxic Air Contaminants – New Source Review
SDCAPCD Reg. XII	1206*	Asbestos Removal, Renovation, and Demolition
40 CFR Part 60	Subpart A	NSPS General Provisions
40 CFR Part 63	Subpart A	NESHAP General Provisions
40 CFR Part 61	Subpart M*	NESHAP - Asbestos
40 CFR Part 73	Part 73	Sulfur Dioxide Allowance System
40 CFR Part 74	Part 74	Acid Rain

* The District issued its own Asbestos Rule 1206 intended to be as stringent as Subpart M. The facility is subject to the most stringent requirements of either rule, which at the time of this report is ensured by compliance with Rule 1206.

C. PERMIT SHIELDS

The facility does not request a permit shield.

D. ADDITIONAL TERMS

1. Any emission unit described in this Title V operating permit as being fired on natural gas, shall only use Public Utility Commission (PUC)-quality natural gas, unless the emission unit permit specifies otherwise. [Rules 53, 62]
2. The permittee shall comply with all applicable requirements, including but not limited to, those applicable requirements of 40 CFR Parts 60 and 63.

E. TITLE IV (ACID RAIN) REQUIREMENTS

1. The permittee shall not exceed any emission allowances that are lawfully held under Title IV of the federal Clean Air Act or the regulations promulgated thereunder. [Rule 1421]
2. The permittee shall install, operate, and maintain equipment for the determination of CO₂ and NO_x emissions on each applicable exhaust stack in accordance with 40 CFR Parts 72 and 75. [40 CFR Parts 72 and 75.10(a)]
3. The permittee shall prepare and maintain onsite a written Quality Assurance program in accordance with 40 CFR Part 75, Appendix B for the continuous monitoring of NO_x

emissions from each applicable exhaust stack. The components of the Quality Assurance program include, but are not limited to, procedures for daily calibration testing, quarterly linearity testing, recordkeeping and reporting implementation, and relative accuracy testing. [40 CFR Parts 72 and 75]

4. The permittee shall monitor SO2 emissions in accordance with 40 CFR Part 72 and 75. [40 CFR Parts 72 and 75]
5. The permittee shall submit quarterly electronic data reports to EPA for the emissions from each applicable exhaust stack in accordance with 40 CFR Part 75. These reports must be submitted within 30 days following the end of each calendar quarter and shall include all information required in § 75.64. [40 CFR Part 75]

SECTION III. EMISSION UNIT REQUIREMENTS

A. EMISSION UNITS

Facility Emission Units (EU) are listed below and attached in Appendix A, including all terms and conditions of such permits, and comprise the emission unit portion of this Title V Operating Permit.

EU Reference	Source
APCD2008-PTO-976039	Turbine twin-pack

B. REGISTERED AND LEASED EMISSION UNITS

The permittee shall comply with the source specific applicable requirements specified in the Rules and Regulations cited below for all registered emission units, unless specifically exempted by the same Rule or Regulations.

Regulation	Rule Citation	Title
SDCAPCD Reg. II	19.2	Continuous Emission Monitoring Requirements
SDCAPCD Reg. II	NSR	New Source Review
SDCAPCD Reg. IV	52	Particulate Matter
SDCAPCD Reg. IV	53	Specific Contaminants
SDCAPCD Reg. IV	54	Dust and Fumes
SDCAPCD Reg. IV	62	Sulfur Content of Fuels

C. INSIGNIFICANT EMISSION UNITS AND ACTIVITIES

The permittee shall comply with the applicable requirements specified in the District Rules and Regulations for any Insignificant Units located at this facility that are listed at District Regulation XIV, Appendix-A (no insignificant units were listed in the permittee's application).

SECTION IV. DISTRICT-ONLY PROVISIONS

VARIANCE PROCEDURES

The permittee may seek relief from District enforcement action from District-only provisions in the event of a breakdown in accordance with District Rule 98.

Notwithstanding the foregoing, the granting by the District of breakdown relief or the issuance by the Hearing Board of a variance does not provide relief from federal enforcement or citizen's suits. [Rule 98]

SECTION V. APPENDICES

APPENDIX A: EMISSION UNITS – SPECIFIC CONDITIONS

EU Reference	Source
APCD2008-PTO-976039	Stationary Gas Turbine Twin-Pack



Sectors: 5, R
Site ID: APCD2000-SITE-03752
App ID: APCD2015-APP-004073

PERMIT ID
APCD2008-PTO-976039

Chula Vista Energy Center LLC
Plant Manager Stephen Cobbe
650 Bercut Dr Suite C
Sacramento CA, 95811

EQUIPMENT ADDRESS
Chula Vista Energy Center LLC
Stephen Cobbe
3497 Main St
Chula Vista CA 91911

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

EQUIPMENT DESCRIPTION

Gas Turbine (twin pack): Pratt & Whitney, Model FT4/GG4, 44 MW, 688 MMBtu/hr heat input, natural gas fired, simple cycle; with dry low-NOx combustors; a selective catalytic reduction (SCR) system including an automatic ammonia injection control system; a continuous emissions monitoring system (CEMS); and a data acquisition and handling system.

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [20F] Non- Aircraft Turbine Engine
1 [93A] Test Witness and Report Review (T&M)

BEC: APCD2011-CON-000276

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

- 1. Only gas turbines identical to the one described above with either Serial No. 675318, 675221, 675352, 675401, 675454 or 675269 may be used at this facility. No more than two of these turbines shall be installed at this facility at any one time. [Rules 10 and 21]
2. Whenever one turbine of the twin pack is replaced with an allowable unit, the owner or operator of this equipment shall record the date of the replacement and the hours of operation of each unit at the time of the replacement. [NSR; Rule 21]
3. The permittee shall comply with the applicable requirements in 40 CFR Parts 60, 72, 73, and 75. [Rule 1421]
4. Provided the equipment subject to this permit is operated in compliance with all of the Section (A) conditions listed below as they exist on the date of issuance of this permit, a permit shield is granted from enforcement action for the following applicable requirements: Rule 53, Rule 62, Rule 68, Rule 69.3, 40 CFR Part 60 Subpart GG, and 40 CFR Part 75. [Rule 1421]



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 Fax (858) 586-2601
www.sdapcd.org

Sectors: 5, R
Site ID: APCD2000-SITE-03752
App ID: APCD2015-APP-004073

PERMIT ID
APCD2008-PTO-976039



5. The unit shall be fired on Public Utility Commission (PUC) quality natural gas only. The permittee shall maintain quarterly records of sulfur content (grains/100 dscf) and higher and lower heating values (Btu/dscf) of the natural gas and provide such records to the District personnel upon request. [Rule 62]
6. The permittee shall comply with all the applicable provisions of 40 CFR 73, including requirements to offset, hold and retire SO2 allowances. [40 CFR Part 73]
7. Except as specified herein, all records required by this permit shall be maintained on-site for a minimum of five years and made available to District personnel upon request. If this site becomes unmanned, the permittee shall submit an alternate site for the maintenance of records to District for approval. [Rule 1421(b)(1)(iii)]
8. Except during startups and shutdowns, the air pollution control system, including the automatic ammonia injection system serving the SCR, shall be in operation in accordance with manufacturer's specifications at all times when the unit is in operation. All manufacturer's specifications shall be maintained on-site and made available to District personnel upon request. [NSR]
9. In the event of a breakdown in an automatic ammonia injection control system, the unit shall be shut down or a trained operator shall operate the ammonia injection control system manually and the breakdown shall be reported to the District Compliance Division pursuant to Rule 98(B)(1) and 98(E). [Rule 98]
10. An application for modification of District permits for this equipment shall be required for any proposed physical or operational modification to the equipment described herein, including a modification to convert this simple cycle unit to a combined cycle unit. Applicable New Source Review requirements for the proposed equipment modification shall be re-evaluated at that time. [Rule 10]
11. For the purposes of this Permit to Operate, startup conditions shall be defined as the time when fuel flow begins until the time that the unit complies with the emission limits specified in this Permit to Operate but in no case exceeding 60 minutes per occurrence. Shutdown conditions shall be defined as the time preceding the moment at which fuel flow ceases and during which the unit does not comply with the emission limits specified in this Permit to Operate but in no case exceeding 30 minutes per occurrence. The Data Acquisition System (DAS), as required by 40 CFR 75, shall record these events. [Rule 69.3.1]
12. Total combined oxides of nitrogen (NOx) emissions from all turbines, and any other emission units at this stationary source, shall not exceed the major source threshold of 50 tons per calendar year. The daily NOx mass emissions from each turbine shall be recorded daily. The aggregate NOx mass emissions from all turbines for each calendar month and for each rolling 12-month period shall be calculated and recorded by the 15th calendar day of the following month. In the event that an annual major stationary source threshold is projected to be triggered, the permittee shall submit a complete application to modify this permit at least 6 months prior to the projected date of exceedance demonstrating how compliance with all applicable requirements will be achieved. [NSR]
13. The emissions of oxides of nitrogen (NOx) calculated as nitrogen dioxide from the unit exhaust stack shall not exceed 9 parts per million volume on a dry basis (PPMVD) corrected to 15% oxygen averaged over each clock hour and shall not exceed 5 PPMVD corrected to 15% oxygen averaged over each rolling 3-hour period. Compliance with these limits shall be demonstrated continuously based on CEMS data and based upon source testing calculated as the average of three substests. These limits shall not apply during startup and shutdown conditions. [Rule 69.3.1, NSR]
14. Total combined carbon monoxide (CO) emissions from all turbines and any other emission units at this stationary source shall not exceed the Prevention of Significant Deterioration (PSD) threshold of 250 tons per calendar year. The daily CO mass emissions from each unit shall be recorded daily. The aggregate CO mass emissions from all turbines for each calendar month and for each rolling 12-month period shall be calculated and recorded by the 15th calendar day of the following month. In the event that the annual PSD stationary source threshold is projected to be triggered, the permittee shall submit a complete application to modify this permit at least 6 months prior to the projected date of exceedance demonstrating how compliance with all applicable requirements will be achieved. [NSR]
15. Emissions of carbon monoxide (CO) from the unit exhaust stack shall not exceed 70 parts per million by volume on a dry basis (ppmvd) corrected to 15% oxygen averaged over each rolling three-hour period. Compliance with this limit shall be demonstrated continuously based on CEMS data and based upon source testing calculated as the average of three substests. This limit shall not apply during startup and shutdown conditions. [NSR]



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 Fax (858) 586-2601
www.sdapcd.org

Sectors: 5, R
Site ID: APCD2000-SITE-03752
App ID: APCD2015-APP-004073

PERMIT ID
APCD2008-PTO-976039


16. Emissions of volatile organic compounds (VOCs), calculated as methane, from the unit exhaust stack shall not exceed 2 parts per million volume on a dry basis (ppmvd) corrected to 15% oxygen. Compliance with this limit shall be demonstrated by source testing, calculated as the average of three subtests. This limit shall not apply during startup and shutdown conditions.
[NSR]
18. Operating Log or Data Acquisition System (DAS) records shall be maintained either on-site or at a District-approved alternate location to record:
 - actual times and durations of all startups and shutdowns;
 - quantity of fuel used (monthly and annual);
 - hours of daily operation;
 - total cumulative hours of operation during each calendar year.[Rule 69.3.1, NSR]
19. The District shall be notified at least two weeks prior to any changes made in CEMS software that affect the measurement, calculation or correction of data displayed and/or recorded by the CEMS. [Rule 69.3.1, 40 CFR PART 75, NSR]
20. The unit shall be equipped with continuous monitors to measure, calculate and record the following operational characteristics:
 - A. Hours of operation (hours);
 - B. Natural gas flow rate (kscfh);
 - C. Exhaust gas temperature (degrees Fahrenheit);
 - D. Ammonia injection rate (lbs/hr);
 - E. Power output (MW).

These parameters shall be continuously monitored. These monitors shall be calibrated and maintained in accordance with the manufacturer's recommended procedures and a protocol approved by the District. Calibration records for the continuous monitors shall be maintained on site and made available to the District upon request. [Rule 69.3.1]
21. The oxides of nitrogen (NOx) and oxygen (O2) CEMs shall be certified and maintained in accordance with applicable Federal Regulations including the requirements of:
 - Sections 75.10 and 75.12 of Title 40;
 - Code of Federal Regulations Part 75 (40 CFR 75);
 - the performance specifications of Appendix A of 40 CFR 75;
 - the quality assurance procedures of Appendix B of 40 CFR 75;
 - the CEMs protocol approved by the District.The carbon monoxide (CO) CEMS shall be certified and maintained in accordance with 40 CFR 60. [40 CFR Part 75, 40 CFR 60, Rule 69.3.1]
22. The CEMS shall be maintained and operated, and reports submitted, in accordance with the requirements of Rule 19.2 Sections (D), (E), (F)(2), (F)(3), (F)(4) and (F)(5) and CEMs Protocol approved by the District.
[Rule 19.2]
23. Fuel flow meters shall be installed and maintained to measure the fuel flow rate corrected for temperature and pressure. Correction factors and constants shall be maintained on site and made available to the District upon request. The fuel flow meters shall meet the applicable quality assurance requirements of 40 CFR Part 75 Appendix D, Section 2.1.6. [40 CFR Part 75]



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 Fax (858) 586-2601
www.sdapcd.org

Sectors: 5, R
Site ID: APCD2000-SITE-03752
App ID: APCD2015-APP-004073

PERMIT ID
APCD2008-PTO-976039


25. A Continuous Emission Monitoring System (CEMS) shall be installed and properly maintained and calibrated in accordance with an approved CEMS protocol to measure, calculate and record the following, in accordance with the approved CEMS protocol:
- A. Hourly average concentration of oxides of nitrogen (NO_x) corrected to 15% oxygen, in parts per million (ppm);
 - B. Hourly average concentration of carbon monoxide (CO) corrected to 15% oxygen, in parts per million (ppm);
 - C. Percent oxygen (O₂) in the exhaust gas (%);
 - D. Average concentration of oxides of nitrogen (NO_x) for each continuous rolling 3-hour period, in parts per million (ppm);
 - E. Daily mass emissions of oxides of nitrogen (NO_x), in pounds;
 - F. Monthly mass emissions of oxides of nitrogen (NO_x), in pounds;
 - G. Annual mass emissions of oxides of nitrogen (NO_x), in tons;
 - H. Daily mass emission of carbon monoxide (CO), in pounds;
 - I. Monthly mass emission of carbon monoxide (CO), in pounds; and
 - J. Annual mass emission of carbon monoxide (CO), in tons.
- The CEMS shall be operated in accordance with the approved CEMS monitoring protocol at all times when the unit is in operation. A copy of the CEMS monitoring protocol shall be maintained on site and made available to District personnel upon request. [Rule 69.3.1, NSR]
26. When the CEMS is not recording data and the unit is operating, hourly NO_x emissions shall be determined in accordance with 40 CFR 75 Appendix C. Additionally, hourly CO emissions shall be determined using the hourly emission rates recorded by the CEMS during the most recent hours in which the unit operated 3 continuous hours at no less than 80% of full power rating. Alternate hourly emission rates to be used shall be CO emission factors to be determined from compliance source test emissions and fuel consumption data, in terms of pounds per hour of CO for the gas turbine. Emission calculations used to determine alternate hourly emission rates shall be reviewed and approved by the District, in writing, before the alternative hourly emission rates are incorporated with the CEMS emission data. [NSR]
28. A Relative Accuracy Test Audit (RATA) and all other required certification tests shall be performed and completed on the CEMS in accordance with 40 CFR Part 75 Appendix A and B (Performance Specifications). At least 21 days prior to the test date, the permittee shall submit test protocol to the District for approval. Additionally, the District shall be notified a minimum of 21 days prior to the test so that observers may be present. [40 CFR Part 75]
29. This unit shall be source tested to demonstrate compliance with the NO_x, CO, VOC, and ammonia emission standards of this permit, using District approved methods. The source test and the NO_x and CO RATA tests shall be conducted in accordance with the RATA frequency requirements of 40 CFR 75 Appendix B, Sections 2.3.1 and 2.3.3. [NSR, Rule 1200]
30. The Source Test Protocol shall comply with the following requirements:
- A. Measurements of oxides of nitrogen (NO_x), carbon monoxide (CO), and stack gas oxygen content (O₂%) shall be conducted in accordance with U.S. Environmental Protection Agency (EPA) Method 7E and District Source Test Method 100, or the Air Resources Board (ARB) Test Method 100, as approved by the EPA.
 - B. Measurement of volatile organic compounds (VOCs) emissions shall be conducted in accordance with the San Diego Air Pollution Control District Methods 25A and/or 18.
 - C. Measurements of ammonia emissions shall be conducted in accordance with Bay Area Air Quality Management District (BAAQMD) Test Method ST-IB.
 - D. Source Testing shall be performed at the normal load level, as specified in 40 CFR Part 75 Appendix A, Section 6.5.2.1 (d), and at no less than 80% of the unit's rated load unless it is demonstrated to the satisfaction of the District that the unit cannot operate under these conditions. If this demonstration is accepted, then emissions source testing shall be performed at the highest achievable continuous power level.
[Rule 69.3.1, NSR]
31. Within 30 days after completion of the Renewal Source Test or RATA, a final test report shall be submitted to the District for review and approval. [Rule 69.3.1, NSR]
32. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. [Rule 19]



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 Fax (858) 586-2601
www.sdapcd.org

Sectors: 5, R
Site ID: APCD2000-SITE-03752
App ID: APCD2015-APP-004073

PERMIT ID
APCD2008-PTO-976039


B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

- 17. Ammonia emissions from the unit exhaust stack shall not exceed 10 parts per million volume on a dry basis (ppmvd) corrected to 15% oxygen. Compliance with this limit shall be demonstrated through source testing calculated as the average of three subtests. This limit shall not apply during startup and shutdown periods. [Rule 1200]
- 24. The ammonia injection flow rate shall be continuously monitored, recorded and controlled. The flowrate device shall be calibrated to an accuracy of at least +/-5% on an annual basis. Records of ammonia injection rate (pounds per hour) and flow rate device calibration shall be maintained and made available to District personnel upon request. [Rule 1200]
- 27. Any violation of any emission standard as indicated by the CEMS shall be reported to the District's Compliance Division within 96 hours after such occurrence. [CA Health and Safety Code]
- 33. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
- 34. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act [California Health and Safety Code Section 44300 et seq.]

APPENDIX B: RULE REFERENCE TABLE

Rule Citation ¹	RULE TITLE	A/R ²	District Adoption Date ³	SIP FR Approval Date
	REGULATION I - GENERAL PROVISIONS			
1	Title	F	04/30/80	09/28/81
2	Definitions	F	11/04/09	09/17/10
4	Review of Rules	F	01/01/70 [†]	09/22/72
5	Authority to Arrest	F	03/24/76 [†]	05/11/77
	REGULATION II - PERMITS			
10	Permits Required	F	07/25/95	03/11/98
10.1 ^{††}	NSPS & NESHAPS Requirements	D	11/8/76	N/A
11	Exemptions from Rule 10 Permit Requirements	D/F	09/20/78	07/06/82
12	Registration of Specified Equipment	D	11/15/00	N/A
12.1	Portable Equipment Registration	D	05/21/97	N/A
14	Applications	F	04/30/80	09/28/81
15	Permit Process - Public Notifications	D/F	09/18/90	Pending
17	Cancellation of Applications	F	04/06/93	03/11/98
18	Action on Applications	F	01/17/72	09/22/72
18	Action on Applications	D/F	09/18/90	Pending
19	Provision of Sampling and Testing Facilities	F	04/06/93	03/11/98
19.1 ^{††}	NSPS & NESHAPS Provision of Sampling and Testing Facilities Requirements	D	11/08/76	N/A
19.2	Continuous Emission Monitoring Requirements	F	01/12/79	09/28/81
19.3	Emission Information	F	5/15/96	03/09/00
20	Standards for Granting Permits	F	04/25/89	10/04/18
20.1	NSR - General Provisions	F	04/27/16	10/04/18
20.2	NSR - Non-major Stationary Sources	F	04/27/16	10/04/18
20.3	NSR - Major Stationary Source and PSD Stationary Source	F	04/27/16	10/04/18
20.4	NSR - Portable Emission Units	F	04/27/16	10/04/18
20.5	Power Plants	F	07/05/79	04/14/81
20.6	Standards for Permit to Operate - Air Quality Analysis	F	04/27/16	10/04/18
20.8	Special Offset Requirement Relating to Banking	D	2/16/83	N/A
21	Permit Conditions	F	11/29/94	03/11/98
22	Denial of Applications	D/F	01/01/69 [†]	N/A
23	Further Information	D/F	01/01/69 [†]	N/A
24	Temporary Permit to Operate	F	03/20/96	10/24/08
25	Appeals	F	01/01/69 [†]	09/22/72
25	Appeals	D/F	06/21/00	Pending
26.0	Banking of Emission Reduction Credits (ERCs) - General Requirements	D/F	10/22/97	Pending
26.1	Standards for Granting Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending

26.2	Use of Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.3	Reclassification of Class B Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.4	Permanency of Banked Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.5	Transfer of Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.6	District Banking of Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.7	Shutdown and Related Emission Unit	D/F	10/22/97	Pending
26.8	Banking of Limited Emission Reductions	D/F	10/22/97	Pending
26.9	Emission Reduction Credit Certificates and The Emission Reduction Credit Register	D/F	10/22/97	Pending
26.10	Banking For BRAC Military Base Closure or Realignment Actions	D/F	10/22/97	Pending
27	Banking of Mobile Source Emission Reduction Credits	D/F	11/29/94	Pending
27.1	Federal Requirements for San Diego County APCD Alternative Mobile Source Emission Reduction Program Approved On 9/8/2000	F	08/06/08	06/03/09
	REGULATIONS III - FEES			
40	Permit Fees	D	01/01/12	N/A
42	Hearing Board Fees	D	07/01/00	N/A
44	Technical Reports, Charges for	D	12/7/83	N/A
	REGULATIONS IV - PROHIBITIONS			
50	Visible Emissions	F	08/13/97	12/7/98
50.1††	NSPS & NESHAPS Visible Emissions Requirements	D	11/08/76	N/A
51	Nuisance	F	01/01/69†	09/22/72
52	Particulate Matter	F	01/22/97	12/9/98
52.1††	NSPS & NESHAPS Particulate Matter Requirements	D	11/08/76	N/A
53	Specific Contaminants	F	01/22/97	12/9/98
53.1	Scavenger Plants	F	01/01/69†	09/22/72
53.2††	NSPS & NESHAPS Specific Contaminants Requirements	D	11/08/76	N/A
54	Dusts and Fumes	F	01/22/97	12/9/98
54.1	NSPS & NESHAP Dust and Fumes Requirement	D	11/08/76	N/A
58	Incinerator Burning	F	01/17/73†	05/11/77
59	Control of Waste Disposal - Site Emissions	D	11/03/87	N/A
59.1	Municipal Solid Waste Landfills	D	06/17/98	N/A
60	Circumvention	F	05/17/94	03/09/00
60.2	Limiting Potential to Emit - Synthetic Minor Sources	D	04/04/12	N/A
61.0	Definitions Pertaining to the Storage & Handling of Organic Compounds	F	10/16/90	09/13/93
61.1	Receiving & Storing Volatile Organic Compounds at Bulk Plants & Bulk Terminals	F	01/10/95	08/08/95
61.2	Transfer of Volatile Organic Compounds into Mobile Transport Tanks	F	07/26/00	08/26/03
61.3	Transfer of Volatile Organic Compounds into Stationary Storage Tanks	F	10/16/90	06/30/93
61.3.1	Transfer of Gasoline into Stationary Underground Storage Tanks	D	03/01/06	Pending

61.4	Transfer of Volatile Organic Compounds into Vehicle Fuel Tanks	F	10/16/90	05/13/93
61.4	Transfer of Volatile Organic Compounds into Vehicle Fuel Tanks	D/F	03/26/08	Pending
61.4.1	Transfer of Gasoline from Stationary Underground Storage Tanks into Vehicles Fuel Tanks	D	03/01/06	N/A
61.5	Visible Emission Standards for Vapor Control Systems	F	09/20/78 [†]	04/14/81
61.6	NSPS Requirements for Storage of Volatile Organic Compounds	D	01/13/87	Withdrawn
61.7	Spillage and Leakage of Volatile Organic Compounds	F	01/13/87	03/11/98
61.8	Certification Requirements for Vapor Control Equipment	F	01/13/87	03/11/98
62	Sulfur Content of Fuels	F	10/21/81	07/06/82
62.1 ^{††}	NSPS Requirements for Sulfur Content of Fuels	D	11/08/76	N/A
64	Reduction of Animal Matter	F	08/21/81	07/06/82
66	Organic Solvents	F	07/25/95	Repealed
66.1	Miscellaneous Surface Coating Operations and Other Processes Emitting VOCs	D/F	2/24/10	08/09/12
67.0.1	Architectural Coatings	F	06/24/15	11/13/15
67.1	Alternative Emission Control Plans	F	05/15/96	03/27/97
67.2	Dry Cleaning Equipment Using Petroleum - Based Solvent	F	05/15/96	03/27/97
67.3	Metal Parts and Products Coating Operations	F	04/09/03	11/14/03
67.4	Metal Container, Metal Closure and Metal Coil Coating Operations	F	11/09/11	09/20/12
67.5	Paper, Film and Fabric Coating Operations	F	05/15/96	03/27/97
67.6.1	Cold Solvent Cleaning and Stripping Operations	F	5/23/07	10/13/09
67.6.2	Vapor Degreasing Operations	F	5/23/07	10/13/09
67.7	Cutback and Emulsified Asphalts	F	05/15/96	03/27/97
67.9	Aerospace Coating Operations	F	04/30/97	08/17/98
67.10	Kelp Processing and Bio-Polymer Manufacturing	F	06/25/97	06/22/98
67.11	Wood Parts and Products Coating Operations	F	06/27/12	04/11/13
67.12.1	Polyester Resin Operations	F	05/11/16	04/02/18
67.15	Pharmaceutical and Cosmetic Manufacturing Operations	F	05/15/96	03/27/97
67.16	Graphic Arts Operations	F	05/09/12	09/20/12
67.17	Storage of Materials Containing Volatile Organic Compounds	F	05/15/96	03/27/97
67.18	Marine Coating Operations	F	05/15/96	03/27/97
67.19	Coating and Printing Inks Manufacturing Operations	F	05/15/96	05/26/00
67.20.1	Motor Vehicle and Mobile Equipment Coating Operations	D	06/30/10	N/A
67.21	Adhesive Material Application Operations	D	11/14/08	N/A
67.22	Expandable Polystyrene Foam Products Manufacturing Operations	D	05/15/96	N/A
67.24	Bakery Ovens	F	05/15/96	03/27/97
68	Fuel-Burning Equipment – Oxides of Nitrogen	F	09/20/94	04/09/96
68.1 ^{††}	NSPS Requirements for Oxides of Nitrogen from Fuel-Burning Equipment	D	11/08/76	N/A

69	Electrical Generating Steam Boilers, Replacement Units & New Units	D	12/12/95	N/A
69.2	Industrial & Commercial Boilers, Process Heaters & Steam Generators	F	09/27/94	02/09/96
69.2.1	Small Boilers, Process Heaters and Steam Generators	D/F	03/25/09	Pending
69.2.2	Medium Boilers, Process Heaters and Steam Generators	D/F	07/08/20	Pending
69.3	Stationary Gas Turbine Engines	F	09/27/94	06/17/97
69.3	Stationary Gas Turbine Engines – RACT	D/F	12/16/98	Pending
69.3.1	Stationary Gas Turbine Engines – BARCT	D	02/24/10	N/A
69.4	Stationary Internal Combustion Engines	F	07/30/03	01/04/06
69.4	Stationary Internal Combustion Engines – RACT (withdrawal pending EPA approval of 69.4.1)	D/F	07/30/03	2/25/04 (Withdrawal Pending)
69.4.1	Stationary Internal Combustion Engines - BARCT	D/F	11/15/00	Pending
69.5	Natural Gas-Fired Water Heaters	D	01/01/99	N/A
69.5.1	Natural Gas-Fired Water Heaters	D	06/24/15	N/A
69.6	Natural Gas-Fired Fan-Type Central Furnaces	D	06/17/98	N/A
70	Orchard Heaters	F	01/17/72	09/22/72
71	Abrasive Blasting	F	03/30/77	08/31/78
	REGULATION V - PROCEDURES BEFORE THE HEARING BOARD			
75	Procedure Before the Hearing Board	D/F	09/17/85	Pending
75.1††	NSPS & NESHAPS Variance Procedures	D	09/17/85	7/30/79
97	Emergency Variance	D/F	07/25/95	Pending
98	Breakdown Conditions: Emergency Variance	D	07/25/95	Withdrawn
	REGULATION VI - BURNING CONTROL			
101	Burning Control	F	09/25/02	04/30/03
	REGULATION VII - VALIDITY AND EFFECTIVE DATE			
140	Validity	F	01/01/69†	09/22/72
141	Effective Date	F	01/01/69†	09/22/72
	REGULATION VIII - SAN DIEGO AIR POLLUTION EMERGENCY PLAN			
126	Applicability	F	05/25/77	08/31/78
127	Episode Criteria Levels	F	09/17/91	03/18/99
128	Episode Declaration	F	09/17/91	03/18/99
129	Episode Termination	F	05/25/77	08/31/78
130	Episode Actions	F	09/17/91	03/18/99
131	Stationary Source Curtailment Plan	F	04/01/81	06/21/82
132	Traffic Abatement Plan	F	04/01/81	06/21/82
132	Traffic Abatement Plan	D/F	12/17/97	Pending
133	Schools	F	05/25/77	08/31/78
134	Source Inspection	F	04/01/81	06/21/82

135	Air Monitoring Stations	F	05/25/77	08/31/78
136	Interdistrict and Interbasin Coordination	F	05/25/77	08/31/78
137	Emergency Action Committee	F	05/25/77	08/31/78
138	Procedures and Plans	F	05/25/77	08/31/78
	APPENDIX A - Persons to be Notified on Episode Declaration	F		
REGULATION IX - PUBLIC RECORDS				
175	General	F	05/22/74†	05/11/77
176	Information Supplied to District	F	05/22/74†	05/11/77
177	Inspection of Public Records	F	03/30/77	08/31/78
177	Inspection of Public Records	D/F	06/20/01	Pending
REGULATION XII - TOXIC AIR CONTAMINANTS				
1200	Toxic Air Contaminants - New Source Review	D	06/12/96	N/A
1202	Hexavalent Chromium - Cooling Towers	D	07/25/95	N/A
1203	Ethylene Oxide Sterilizers and Aerators	D	07/26/00	N/A
1205	Control of Dioxins Emissions from Medical Waste Incinerators	D	01/01/94	N/A
1210	Toxic Air Contaminant Public Health Risks - Public Notification and Risk Reduction	D	06/12/96	N/A

REGULATION XIV - TITLE V OPERATING PERMITS				
1401	General Provisions	F	02/27/04	02/27/04
1410	Permit Required	F	02/27/04	02/27/04
1411	Exemption from Permit to Operate for Insignificant Units	F	03/07/95	11/30/01
1412	Federal Acid Rain Program Requirements	F	01/18/94	11/30/01
1413	Early Reduction of Hazardous Air Pollutants	F	03/07/95	11/30/01
1414	Applications	F	03/07/95	11/30/01
1415	Permit Process-Public Notification	F	02/27/04	02/27/04
1417	Pendency & Cancellation of Applications	F	03/07/95	11/30/01
1418	Action on Applications	F	02/27/04	11/30/01
1419	Provisions of Sampling & Testing Facilities & Emission Information	F	03/07/95	11/30/01
1420	Standards for Granting Permits	F	03/07/95	11/30/01
1421	Permit Conditions	F	02/27/04	02/27/04
1422	Denial or Cancellation Of Applications	F	03/07/95	11/30/01
1423	Further Information	F	01/18/94	11/30/01
1424	Applications Deemed Denied	F	01/18/94	11/30/01
1425	Appeals & Judicial Review	F	02/27/04	02/27/04
	APPENDIX A - Insignificant Units	F	02/27/04	11/30/01
REGULATION XV - FEDERAL CONFORMITY				
1501	Conformity of General Federal Actions	F	06/22/99	04/23/99

The following NSPS and NESHAP have been adopted locally by the District. EPA has granted the District delegation for each of these rules. Therefore, these rules, as adopted by the District are the federally applicable requirements. For all other NSPS and NESHAP, the versions cited in the CFR are the federally applicable requirements.

Subpart & Citation	RULE TITLE	District Adoption Date(s)	Federal Delegation Date
Part 60	REGULATION X - STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES		
A	General Provisions	Unknown 11/03/92	11/08/76
E	Standards of Performance for Incinerators	Unknown	03/30/77
I	Standards of Performance for Asphalt Concrete Plants	Unknown 01/13/87	11/08/76
J	Standards of Performance for Petroleum Refineries	Unknown	11/08/76
L	Standards of Performance for Secondary Lead Smelters	Unknown	11/08/76
M	Standards of Performance for Secondary Brass and Bronze Ingot Production Plants	Unknown 09/17/85	03/30/77
O	Standards of Performance for Sewage Treatment Plants	01/13/87	09/17/87
DD	Standards of Performance for Grain Elevators	Unknown	05/24/82
EE	Standards of Performance for Surface Coating Metal Furniture	03/04/86 11/03/92	03/19/87
QQ	Standards of Performance for the Graphic Arts Industry: Publication Rotogravure Printing	08/24/83	12/22/83
RR	Standards of Performance for Pressure Sensitive Tape and Label Surface Coating Operations	09/17/86 11/03/92	03/19/87
SS	Standards of Performance for the Industrial Surface Coating Large Appliances	02/22/84 11/03/92	04/24/84
TT	Standards of Performance for Metal Coil Surface Coating	02/22/84 11/03/92	04/24/84
BBB	Standards of Performance for the Rubber Tire Manufacturing Industry	03/14/89	07/18/89
FFF	Standards of Performance for Flexible Vinyl and Urethane Coating and Printing	09/17/86	03/19/87
JJJ	Standards of Performance for Petroleum Dry Cleaners	12/15/87	07/18/89
Part 61	REGULATION XI- NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS (NESHAPS)		
A	General Provisions	01/13/87	05/24/82
C	National Emission Standard for Beryllium	Unknown	11/08/76
D	National Emission Standard for Beryllium Rocket Motor Firing	Unknown	11/08/76
E	National Emission Standard for Mercury	03/27/90	05/17/91
F	National Emission Standard for Vinyl Chloride	08/17/77 06/16/78	11/21/77

The following ATCM and NESHAP have not been adopted by the District, but are being implemented and enforced by the District as ATCM's.

Subpart & Citation	RULE TITLE	A/R	Most Recent Adoption Date
DISTRICT RULES AND REGULATIONS APPENDIX A - CALIFORNIA AIRBORNE TOXIC CONTROL MEASURES (ATCM)			
17 CCR § 93102	Hexavalent Chromium ATCM for Chrome Plating & Chromic Acid Anodizing Operations	D/F	12/7/06
17 CCR § 93109	ATCM For Emissions of Perchloroethylene From Dry Cleaning Operations	F	01/25/07
17 CCR § 93101.5	ATCM to Reduce Emissions of Hexavalent Chromium and Nickel from Thermal Spraying	D	09/30/05
17 CCR § 93105	ATCM for Construction, Grading, Quarrying, and Surface Mining Operations	D	07/26/01
17 CCR § 93106	Asbestos ATCM for Surface Applications	D	07/20/00
17 CCR § 93107	ATCM For Emissions of Toxic Metals From Non-Ferrous Metal Melting	D	01/14/93
17 CCR § 93111	ATCM for Emissions of Chlorinated Toxic Air Contaminants from Automotive Maintenance & Repair Activities	D	04/27/00
17 CCR § 93112	ATCM for Emissions of Hexavalent Chromium and Cadmium from Motor Vehicle and Motor Equipment Coatings	D	09/20/01
17 CCR § 93113	ATCM to Reduce Emissions of Toxic Air Contaminants from Outdoor Residential Waste Burning	D	02/03/03
17 CCR § 93115	ATCM for Stationary Compression Ignition Engines	D	05/19/11
17 CCR § 93116	ATCM for Portable Diesel-Fueled Engines	D	02/19/11
DISTRICT RULES AND REGULATIONS APPENDIX B - NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS (NESHAP) FOR SOURCE CATEGORIES			
Part 63			
A	General Provisions	F	05/16/07
N	Hard and Decorative Chromium Electroplating and Chromium Anodizing Tanks	F	04/20/06
O	Ethylene Oxide Sterilization Facilities	F	12/28/07
R	Gasoline Distribution	F	01/24/11
T	Halogenated Solvent Cleaning	F	09/08/00
DD	Off-site Waste & Recovery Operations	F	07/20/99
GG	Aerospace Manufacturing and Rework Facilities	F	12/08/00
II	Shipbuilding and Ship Repair (Surface Coating)	F	12/15/95
JJ	Wood Furniture Manufacturing Operations	F	12/28/98
VVV	Publicly Owned Treatment Works	F	10/21/02
AAAA	Municipal Solid Waste Landfills	F	01/16/03
EEEE	Organic Liquids Distribution (non-gasoline)	F	07/17/08
MMMM	Surface Coating of Miscellaneous Metal Parts and Products	F	04/26/04
PPPP	Plastic Parts (surface coating)	F	04/24/07
SSSS	Surface Coating of Metal Coil	F	03/17/03
VVVV	Boat Manufacturing	F	08/22/01
WWWW	Reinforced Plastic Composites Production	F	8/25/05

YYYY	Stationary Combustion Turbines	F	08/18/04
ZZZZ	Stationary Reciprocating Internal Combustion Engines	F	03/09/11
DDDDD	Industrial, Commercial, and Institutional Boilers and Process Heaters	F	05/18/11
GGGGG	Site Remediation	F	11/29/06
HHHHH	Miscellaneous Coating Manufacturing	F	10/04/06
PPPPP	Engine Test Cells/Stands	F	08/28/03
WWWWW	Hospital Ethylene Oxide Sterilizers Area Sources	F	12/28/07
BBBBBB	Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities	F	01/24/11
CCCCC	Gasoline Dispensing Facilities	F	01/24/11
HHHHHH	Paint Stripping and Miscellaneous Surface Coating Operations at Area Sources	F	01/09/08
JJJJJ	Area Sources: Industrial, Commercial, and Institutional Boilers	F	3/21/11
QQQQQ	Wood Preserving Area Sources	F	07/16/07
VVVVV	Chemical Manufacturing Area Sources	F	11/29/09
WWWWW	Plating and Polishing Operations Area Sources	F	07/01/08
XXXXXX	Metal Fabrication and Finishing Area Sources	F	7/23/08
AAAAAAA	Asphalt Processing and Asphalt Roofing Manufacturing Area Sources	F	12/02/09
CCCCCCC	Paint and Allied Products Manufacture Area Sources	F	12/03/09

The following NSPS have been adopted by the District by reference. The rules listed below are the CFR versions of these rules which are federally applicable requirements.

Subpart & Citation	RULE TITLE	Latest EPA Promulgation Date	District Adoption Date	Delegation Date
Part 60	DISTRICT RULES AND REGULATIONS APPENDIX C - STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES (NSPS)			
D	Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971	10/17/00 01/28/09	10/17/01 06/24/09	01/03/08 Pending
Da	Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978	06/11/01 01/28/09	10/17/01 06/24/09	01/03/08 Pending
Db	Standards of Performance for Industrial-Commercial - Institutional Steam Generating Units	10/01/01 01/28/09	04/25/01 06/24/09	01/03/08 Pending
Dc	Standards of Performance for Small Industrial-Commercial -Institutional Steam Generating Units	05/08/96 01/28/09	08/13/97 06/24/09	06/24/98 Pending
GG	Standards of Performance for Stationary Gas Turbines	06/27/89 02/24/06	10/17/01 02/25/09	01/03/08 Pending
K	Standards of Performance for Storage Vessels for Petroleum Liquids Construct After June 11, 1973 and Prior to May 19, 1978	10/17/00	06/20/07	01/03/08
Ka	Standards of Performance for Storage Vessels for Petroleum Liquids Construction after May 18, 1978	12/14/00	06/20/07	01/03/08
Kb	Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984	10/15/03	06/20/07	01/03/08
AAA	Standards of Performance for New Residential Wood Heaters	06/12/99 10/17/00	04/12/00 N/A	01/03/08 N/A
OOO	Standards of Performance for Nonmetallic Mineral Processing Plants	06/09/97 10/17/00	04/28/99 N/A	05/28/02 N/A
UUU	Standards of Performance for Calciners and Dryers in Mineral Industries	07/29/93 10/17/00	11/17/99 N/A	05/28/02 N/A
VVV	Standards for Polymeric Coating of Supporting Substrates Facilities	09/11/89	05/23/07	01/03/08
WWW	Standards of Performance for Municipal Solid Waste Landfills	04/10/00	08/13/97	06/24/98
AAAA	Standards of Performance for Small Municipal Waste Combustion Units	12/06/00	06/20/07	01/03/08
CCCC	Standards of Performance for Commercial and Industrial Solid Waste Incineration Units	12/01/00	06/20/07	01/03/08
EEEE	Standards of Performance for Other Solid Waste Incineration Units	12/16/05	06/20/07	01/03/08
KKKK	Standards of Performance for Stationary Combustion Turbines	07/06/06	02/25/09	06/01/09

The following NSPS have not been adopted by the District and are not delegated to the District. However, the District has the authority to enforce the NSPS through the Title V program. The rules listed below are the CFR versions of these rules, which are federally applicable requirements.

Subpart & Citation	RULE TITLE	Latest EPA Promulgation Date	District Adoption Date	Delegation Date
Part 60				
III	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines	07/11/06	N/A	N/A
JJJ	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines	01/18/08	N/A	N/A

1. Rule Citations marked with an “††” contain no substantive requirements and are listed for informational purposes only.
2. ‘A/R’ Denotes enforceability of the listed applicable requirement as follows:
 - ‘F’ Denotes a Federal applicable requirement that is federally enforceable and District enforceable.
 - ‘D/F’ Denotes a District applicable requirement which is pending SIP approval. When such a rule receives SIP approval, it supersedes the existing SIP rule and becomes the Federal applicable requirement.
 - ‘D’ Denotes a District only applicable requirement. This may include some state requirements that are enforceable by the District.
3. District adoption dates marked with an “†” are the effective date of the rule, the actual adoption date is uncertain.
4. On September 17, 2010, EPA approved the District’s November, 4, 2009, revision to the table of exempt compounds in Rule 2, which can be administratively amended without Board action to amend the rule.

APPENDIX C: ABBREVIATIONS THAT MAY APPEAR IN THIS PERMIT

APCO	Air Pollution Control Officer
ASTM	American Society for Testing and Methods
BACT	Best Available Control Technology
CAA	federal Clean Air Act
CFR	Code of Federal Regulations
CO	Carbon Monoxide
CO ₂	Carbon Dioxide
District	San Diego County Air Pollution Control District
EF	Emission Factor
EPA	US Environmental Protection Agency
HAP	Hazardous Air Pollutant
I&M	Inspection and Maintenance
NESHAP	National Emission Standard for Hazardous Air Pollutants
NSPS	New Source Performance Standards
NSR	New Source Review
[NSR]	New Source Review based condition
NO _x	Oxides of nitrogen
O ₂	Oxygen
OES	Office of Environmental Services
O&M	Operation and maintenance
Pb	Lead
PM	Total Particulate Matter
PM ₁₀	Particulate matter with aerodynamic equivalent diameter of ≤ 10 microns
PSD	Prevention of Significant Deterioration
RMP	Risk Management Plan
SDCAPCD	San Diego County Air Pollution Control District
SIP	State Implementation Plan
SO _x	Oxides of sulfur
Title IV	Title IV of the federal Clean Air Act
Title V	Title V of the federal Clean Air Act
VOC	Volatile organic compound

Units of Measure:

dscf	=	Dry standard cubic foot
g	=	grams
gal	=	gallon
gr/dscf	=	Grains per dry standard cubic foot
hr	=	hour
lb	=	pound
in	=	inches
max	=	maximum
min	=	minute
MM Btu	=	Million British thermal units
psia	=	pounds per square inch, absolute
scf	=	Standard cubic foot
scfm	=	standard cubic feet per minute
yr	=	year